

City of Portland, Maine
Inspections Division
Violations Report

Appointment Date Between 1/1/2015 And 2/7/2018

Dist. #	Sch. Date	CBL	Appl. Type	Schedule Type	Appl #	Location
	Contact:		Inspector	Comments		
HSL Yr	06/29/2016	190 G009001	Fire Company	FP Routine Inspection		1274 CONGRESS ST
	Swan Island Llc		Scott Corey	Inspections from Naviline Fire Inspections		
	ATLANTIC PRO					

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 1-1.12.5.13-8 038	Fire Alarm Inspection Sticker Required	Open				<input type="checkbox"/>	

3	12/07/2017	190 G009001	Fire Company	FP Routine Inspection		1274 CONGRESS ST
HSL Yr	SWAN ISLAND LLC		John Cenate			

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-7.9.3-80.16	Emergency lights Require Maintenance several e- light are not working	Open				<input type="checkbox"/>	

Total Listed: 2