

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that
GOULD CHARLES M

Located at
39 MITTON ST

PERMIT ID: 2017-00918 **ISSUE DATE:** 08/24/2017 **CBL:** 191 B001001

has permission to **Replace middle portion of rear foundation wall**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
single family

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Foundation/Backfill

Setbacks and Footings Prior to Pouring

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00918	Date Applied For: 06/12/2017	CBL: 191 B001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Single Family		Proposed Project Description: Replace middle portion of rear foundation wall		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 06/22/2017</p> <p>Note: R-5 Ok to Issue: <input checked="" type="checkbox"/></p> <p>- house was built around 1909 - work is taking place within original footprint of the house</p> <p>* Review of property showed a deck on the left side of the building that had not been permitted. Sent letter June 28, 2017 requiring the owner bring the property into compliance within 30 days.</p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 2) The deck on the left side of the building was built without a permit. An after the fact buiding permit must be applied for by July 28, 2017 to permit the deck. 3) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 				
<p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 08/24/2017</p> <p>Note: Ok to Issue: <input type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) All construction shall comply with City Code Chapter 10. 2) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 3) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 				