

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

THE JEWISH COMMUNITY ALLIANCE OF
SOUTHERN MAINE

Located at

1342 CONGRESS ST

PERMIT ID: 2016-00981

ISSUE DATE: 09/15/2016

CBL: 191 B016001

has permission to **Construction of a Community Center**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

Fire Official

/s/ Laurie Leader

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Community center

Building Inspections

Use Group: E/14/A3/ Type: 2B
B

Fire Department

Daycare
Education
Day Care - Infant Room
Assembly Hall
Business
Occupant load = 444
Sprinkler System NFPA 13
ENTIRE
MUBEC/IBC 2009

PERMIT ID: 2016-00981

Located at: 1342 CONGRESS ST

CBL: 191 B016001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - DRC
Site VISIT
Close-in Plumbing/Framing w/Fire & Draft Stopping
Above Ceiling Inspection
Electrical Close-in w/Fire & Draftstopping
Final - Electric
Final - Fire
Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00981	Date Applied For: 04/25/2016	CBL: 191 B016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Community Ctr - Jewish Community Ctr		Proposed Project Description: Construction of a Community Center		
Dept: Zoning Status: Approved Reviewer: Jean Fraser Approval Date: 06/23/2016		Ok to Issue: <input checked="" type="checkbox"/>		
Note: Planner Rec'd this 5.16.16; review delayed by family emergency				
Conditions:				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 09/15/2016		Ok to Issue: <input checked="" type="checkbox"/>		
Note:				
Conditions:				
<ol style="list-style-type: none"> 1) Energy Code compliance shall be confirmed via a ResCheck or ComCheck, http://www.energycodes.gov/software.stm#tabs-2 certificate or alternate program or testing standard for thermal envelope and MEP systems. This documentation is required prior to associated work for these items. 2) A State Fire Marshal permit is required for this project. A copy of this permit and any changes to the City's approved plans shall be submitted to the Inspections Division as soon as it is issued. 3) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7 and all penetrations shall be treated with approved materials and methods, including electrical fixtures and exhaust vents. 4) Firestopping Systems and Smoke Seal protocol shall be followed as established in the project specifications manual. These include products, systems, standards, design submittals and execution of field quality control. Design specification cut sheets shall be submitted in electronic format for review and approval for each penetrating item. 5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 6) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 7) Approval is subject to compliance with City and State Food Codes per the Portland Public Health Dept. It is strongly advised to contact the Health Inspector for approval of the kitchen/bar design compliance prior to commencing work in earnest. 8) Approval of City license is subject to health inspections per the Food Code. 				
Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 06/22/2016		Ok to Issue: <input checked="" type="checkbox"/>		
Note:				
Conditions:				
<ol style="list-style-type: none"> 1) All construction shall comply with 2009 NFPA 101, Chapter 16 New Day Care Occupancy. 2) All construction shall comply with City Code, Chapter 10. 3) All construction shall comply with 2009 NFPA 101, Chapter 12 New Assembly Occupancy. 4) All construction shall comply with 2009 NFPA 101, Chapter 38 New Business Occupancy. 5) Application requires State Fire Marshal approval. 6) All means of egress to remain accessible at all times. 7) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. 8) A Knox Box is required. 				

PERMIT ID: 2016-00981

Located at: 1342 CONGRESS ST

CBL: 191 B016001

