

From: Tom Errico <thomas.errico@tylin.com>
To: Jean Fraser <JF@portlandmaine.gov>
CC: David Margolis-Pineo <DMP@portlandmaine.gov>, Katherine Earley <KAS@port...>
Date: 5/13/2015 1:41 PM
Subject: Jewish Community Center

Jean - I have reviewed updated trip generation information provided by the applicant and have the following additional comments.

* I'm concerned that the ITE data is not a good source for estimating traffic for the proposed project. I would suggest that the applicant conduct traffic counts/surveys at existing facilities to better estimate traffic levels. I would also like to get a better understanding on historic traffic activity at St. Patrick's Church. I recognize that traffic volumes are not likely to be available, but information on daily services and other event details would be helpful for my review and understanding of project impacts. The applicant should attempt to provide specific church service information, if available.

* The pick-up and drop-off of daycare and others will need to be carefully managed. Accordingly, the applicant should provide specific details on how this process will take place. This should include what building entrances will be used, sidewalk facilities between parking spaces and the noted entrance, etc. I would note that the pick-up/drop-off program must be managed such that vehicles are not parking along the driveway off Congress Street.

If you have any questions, please contact me.

Best regards,

Thomas A. Errico, PE
Senior Associate
Traffic Engineering Director
[T.Y. Lin International]T.Y. Lin International
12 Northbrook Drive
Falmouth, ME 04105
207.781.4721 (main)
207.347.4354 (direct)
207.400.0719 (mobile)
207.781.4753 (fax)
thomas.errico@tylin.com<mailto:thomas.errico@tylin.com>
Visit us online at www.tylin.com<http://www.tylin.com>
Twitter | Facebook | LinkedIn | YouTube

"One Vision, One Company"

Please consider the environment before printing.