

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Please Read Application And Notes, If Any, Attached

PERMIT ISSUED
Permit Number: 050080
FEB 10 2005
CITY OF PORTLAND

This is to certify that Shaw's Realty Co/The Sign Center

has permission to 1 temporary banner on front of bldg.

AT 1372 Congress St

191 B019001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is altered or occupied enclosed-in.
HEAVY NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept

Health Dept.

Appeal Board

Other

Department Name

Joanie Bourke 2/8/05
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0080	Issue Date: PERMIT ISSUED FEB 10 2005	CBL: 191 B019001
-----------------------	--	---------------------

Location of Construction: 1372 Congress St	Owner Name: Shaw's Realty Co	Owner Address: P.o. box 20	Phone: FEB 10 2005
Business Name:	Contractor Name: The Sign Center	Contractor address: 40 Orchard St Haverhill	Phone: 9783723721
Lessee/Buyer's Name	Phone:	Permit Type: Signs - Temporary	Zone: 32
Past Use: Commercial	Proposed Use: Commercial 1 temporary banner on front of bldg.	Permit Fee: \$62.00	Cost of Work: \$62.00
		CEO District: 3	
Proposed Project Description: 1 temporary banner on front of bldg.		FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: B Type: Temp sign IBC 2003 Signature: JMB 2/9/05
for 30 days only beginning of the date of permit issue and ending 30 days following the issue date		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____	
Permit Taken By: dmartin	Date Applied For: 01/25/2005	Zoning Approval	

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <p>Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>ok with conditions Date: 2/7/05</p>	<p>Zoning Appeal</p> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied <p>Date: _____</p>	<p>Historic Preservation</p> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <p>Date: _____</p>
---	--	---	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0080	Date Applied For: 01/25/2005	CBL: 191 B019001
------------------------------	--	----------------------------

Location of Construction: 1372 Congress St	Owner Name: Shaw's Realty Co	Owner Address: P.o.box 20	Phone:
Business Name:	Contractor Name: The Sign Center	Contractor Address: 40 Orchard St Haverhill	Phone (978) 372-3721
Lessee/Buyer's Name	Phone:	Permit Type: Signs - Temporary	

Commercial 1 temporary banner on front of bldg. - for a thirty (30) day period only

1 temporary banner on front of bldg.

Dept: Zoning **Status:** Approved with Conditions **Reviewer:** Marge Schmuckal **Approval Date:** 02/07/2005

Note: **Ok to Issue:**

- 1) The time period for use of this 2'x8' banner is for thirty (30) days beginning on the date of permit issue and ending 30 days following the issue date.
- 2) Temporary banners shall only be permitted for thirty (30) day periods. No more than two temporary sign permits shall be issued to each business on the same lot in any calendar year. This is the first 30-day period approved.

Dept: Building **Status:** Approved with Conditions **Reviewer:** Jeanine Bourke **Approval Date:** 02/09/2005

Note: 2/8/05 left vm w/Jessica S. To call about flame resistance cert. & 30 day certain. **Ok to Issue:**
2/9 Elena Berry called from Sign Center, she will fax flame info, verified the sign start date as 2/14/05, ok to issue

- 1) This temporary sign will have a start date of 2/14/05 and must be removed no later than 3/17/05.
- 2) Signage Installation to comply with Chapter 31 of the IBC 2003 building code.

Signage/Awning Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: <u>1370 Congress St</u>		
Total Square Footage of Proposed Structure	Square Footage of Lot	
Tax Assessor's Chart, Block & Lot Chart# <u>191</u> Block# <u>B</u> Lot# <u>019</u>	Owner: <u>Banknorth Group</u>	Telephone:
Lessee/Buyer's Name (if Applicable)	Applicant name, address & telephone: <u>The Sign Center</u> <u>40 Orchard St</u> <u>Haverhill, MA 01830</u>	Total s.f. of signage x \$2.00 per s.f. plus \$30.00/\$45.00 for H.D. signage = Total Fee: <u>\$324.30</u> Awning Fee = Cost Of Work: \$ Total Fee: \$ <u>62.00</u>
Current use: <u>Bank</u>		
Approximately how long has it been vacant: _____		
Proposed use: <input checked="" type="checkbox"/> <u>Temporary banners</u>		
Project description: _____		
Contractor's name, address & telephone:		
Whom should we contact when the permit is ready: <u>Elena Berry</u>		
Mailing address: <u>40 Orchard St</u> <u>Haverhill, MA</u>		
We will contact you by phone when the permit is ready. You must come in and pick up the permit and review the requirements before starting any work, with a Plan Reviewer. A STOP WORK ORDER will be issued <u>9783</u>		

Signature of applicant: Elena Berry Date: 1/13/05

This is NOT a permit, you may not commence ANY work until the permit is issued.

*ok 4'x8' is max size
only showing 2'x8*

Small Business Loans. FREE Business Checking.

2' x 8' Vinyl temporary banner, anchor mounted
flush to exterior of building. Yellow and white with black copy.



Applicant/Installer: The Sign Center
40 Orchard Street
Haverhill, MA 01830
(978)372-3721

Client: Banknorth Group, Inc.
70 Gray Street
Falmouth, ME 04105
(807) 317-8954

©
COPYRIGHT © 2005
SIGN CENTER
UNAUTHORIZED USE OR
DUPLICATION PROHIBITED



January 11,2005

**Town Hall
Code Enforcement/Inspectional Svcs.**

Re: 2' x 8' Temporary Banner

To Whom It May Concern:

Please accept this letter as authorization for The Sign Center of Haverhill, MA to act on our behalf for the purpose of securing permits for the above referenced signage. Please contact me at (207) 317-8954 should you have any questions regarding this matter.

Sincerely,

A handwritten signature in cursive script that reads "Jessica A. Smith".

**Jessica Smith
AVP, Creative Services**

ACORD CERTIFICATE OF LIABILITY INSURANCE

OP ID YN
INSIG-1

DATE (MM/DD/YYYY)
12/07/04

PRODUCER S-Banknorth Ins Agency, Inc/MA P.O. Box 9040 Springfield MA 01102-9040 Phone: 413-781-5940 Fax: 413-733-7722	THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW.	
	INSURERS AFFORDING COVERAGE	NAIC #
INSURED Insignia Inc DBA Sign Center 40 Orchard St Haverhill MA 01830	INSURER A: HANOVER INSURANCE CO.	22292
	INSURER B: Twin city Fire Insurance Co.	29459
	INSURER C: Hartford Fire Insurance Co	19682

COVERAGES

THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN. THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. AGGREGATE LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS

INSR ADD'L LTR INSRD	TYPE OF INSURANCE	POLICY NUMBER	POLICY EFFECTIVE DATE (MM/DD/YY)	POLICY EXPIRATION		
C	GENERAL LIABILITY <input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS MADE <input checked="" type="checkbox"/> OCCUR H GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC	08SBAPJ4769	12/01/04	12/01/05	EACH OCCURRENCE	\$ 1,000,000
	DAMAGE TO RENTED PREMISES (Ea occurrence)				\$ 300,000	
	MED EXP (Any one person)				\$ 10,000	
	PERSONAL & ADV INJURY				\$ 1,000,000	
	GENERAL AGGREGATE				\$ 2,000,000	
	PRODUCTS - COMP/OP AGG				\$ 2,000,000	
A	AUTOMOBILE LIABILITY <input type="checkbox"/> ANY AUTO <input type="checkbox"/> ALL OWNED AUTOS <input checked="" type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> HIRED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS	BINDER	12/12/04	12/12/05	COMBINED SINGLE LIMIT (Ea accident)	\$ 1,000,000
	BODILY INJURY (Per person)				\$	
	BODILY INJURY (Per accident)				\$	
	PROPERTY DAMAGE (Per accident)				\$	
	GARAGE LIABILITY <input type="checkbox"/> ANY AUTO				AUTO ONLY - EA ACCIDENT	\$
					OTHER THAN EA ACC	\$
					AUTO ONLY AGG	\$
D	EXCESS/UMBRELLA LIABILITY <input checked="" type="checkbox"/> OCCUR <input type="checkbox"/> CLAIMS MADE <input type="checkbox"/> DEDUCTIBLE <input checked="" type="checkbox"/> RETENTION \$10,000	EBU6406740	06/08/04	06/08/05	EACH OCCURRENCE	\$ 2,000,000
	AGGREGATE				\$ 2,000,000	
					\$	
					\$	
B	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY (NY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED?) *yes, describe under SPECIAL PROVISIONS below	08WECGU7291	12/12/04	12/12/05	<input type="checkbox"/> WC STATUTORY LIMITS <input type="checkbox"/> OTHER	
	E.L. EACH ACCIDENT				\$ 500,000	
	E.L. DISEASE-EA EMPLOYEE				\$ 500,000	
	E.L. DISEASE - POLICY LIMIT				\$ 500,000	
OTHER						

DESCRIPTION OF OPERATIONS/ LOCATIONS/ VEHICLES/ EXCLUSIONS ADDED BY ENDORSEMENT/ SPECIAL PROVISIONS

To provide evidence of insurance.


CERTIFICATE HOLDER

GENERIC

CANCELLATION

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, THE ISSUING INSURER WILL ENDEAVOR TO MAIL 10 DAYS WRITTEN NOTICE TO THE CERTIFICATE HOLDER NAMED TO THE LEFT, BUT FAILURE TO DO SO SHALL IMPOSE NO OBLIGATION OR LIABILITY OF ANY KIND UPON THE INSURER, ITS AGENTS OR REPRESENTATIVES.

AUTHORIZED REPRESENTATIVE



1 All signs not expressly permitted under this ordinance or
2 exempt from regulation hereunder in accordance with section 14-371
3 are prohibited.

4 Sec. 14-370. Portable/temporary signs.

5 a. On *private property*. Portable and temporary signs shall
6 meet, in addition to the other requirements of this division, the
7 following requirements:

8 i. *Number of signs*. There shall be no more than one (1)
9 portable or one (1) temporary sign on any lot.

10 ii. *Term*. A portable or temporary sign permit shall allow
11 the use of a portable or temporary sign for a specified
12 thirty (30)-day period.

13 iii. *Number of permits*. No more than two (2) portable or
14 temporary sign permits shall be issued to each business
15 on the same lot in any calendar year. In no event shall
16 any lot have a portable or temporary sign for more than
17 sixty (60) days in one (1) calendar year.

18 iv. *other conditions*. A portable or a temporary sign shall
19 be allowed only in those districts indicated on Table 1
20 of section 14-369.5.

21 v. *Permit sticker*. Each portable sign and each temporary
22 sign shall display a permit sticker issued by the
23 building authority. The sticker shall contain the
24 expiration date of the permit.

25 b. *Additional requirements for freestanding portable or*
26 *temporary signs*. In addition to the requirements of subsection a
27 of this section, freestanding portable or temporary signs on
28 private property shall meet the following requirements:

29 i. No portable or temporary sign shall interfere with the
30 sight distance of traffic passing the site. The
31 determination of sight distance shall be made by the
32 traffic engineer.

33 ii. Portable and temporary signs shall be set back a minimum
34 of five (5) feet from the side line of the City right of
35 way and a minimum of five (5) feet from any property
36 line.

37 iii. No portable or temporary sign shall exceed four (4) feet
38 by eight (8) feet in size.

33 c. *Portable signs in the city right-of-way*. Portable signs



Farmingdale NY 11735
TEL: (631) 293-8944
FAX: (631) 293-8958

Page 2

Order: 12/19/2000	Completed: 01/03/2001	Letter: A2	rb	F.O.#:	Test Report #:	2-32322-2-
K's ification		Jertex				
Order For: Brian Lynch Ultraflex Systems Inc. 365 Franklin Avenue Rockaway, NJ 07866			Key Test: NFPA 701-96 TM#2 Flat MEA AW 1675 Tel: 1-(973)-627-8608 Fax: 1-(973)-627-7022			

VERSION FACTORS: mm ÷ 25.4 = inches
g/m² ÷ 28.35 x .835 = oz/yd²

MARKS:
1A.

VERIFICATION:
Verify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 701 - 1995 Edition Test Method #2 Flat Sheet Specimens.

Leather S. Roberson


AUTHORIZED SIGNATURE
S GOVMARK ORGANIZATION, INC.

DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME

FEB 9 2005

RECEIVED

TOTAL P.86



Farmingdale NY 11735
 TEL: (631) 293-8944
 FAX: (631) 293-8956

Page 1

Order: 12/15/2000 Completed: 12/26/2000 Letter: A1 Job No: P.O.#: Test Report #: 2-32322-1-

Client: JetFlex
 Order For: Brian Lynch
 Ultraflex Systems Inc.
 365 Franklin Avenue
 Rockaway, NJ 07865
 Key Test: NFPA 701-96 TM#2 Flat MEA WL 373
 Tel: 1-(973)-627-8608 Ext
 Fax: 1-(973)-627-7022

Category: NFPA 701-96 TM2 Specifier: NYC Flex Signs CODE: 275-375-1675
 TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Resistant Textiles and Films
 16 Edition - Test Method #2 - Flat Sheet Specimens
 adopted by The City of New York Department of Buildings Technical Policy and Procedure Notice #11/99
 Safety Standards for the Erection of Flex Sign Structures

SPECIMEN CONFIGURATION: Single Layer; Multi Layer
 TESTED: Initially
 After 72 hours water leaching
 After 100 hours accelerated weathering

SUITS - specimen #	Afterflame (seconds)	Drip Burn (seconds)	Char Length (mm)
1	0.0	0.0	250
2	0.0	0.0	230
3	0.0	0.0	230
4	0.0	0.0	200
5	0.0	0.0	225
6	0.0	0.0	240
7	0.0	0.0	210
8	0.0	0.0	200
9	0.0	0.0	210
10	0.0	0.0	225

DEPT. OF BUILDING INSPECTION
 CITY OF PORTLAND, ME
 FEB 9 2005
 RECEIVED

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 452 g/m²

FAILURE CRITERIA: For each individual specimen --

Afterflame	Drip Burn	Char Length
Exceeds 2.0 seconds	Exceeds 2.0 seconds	Exceeds 435 mm (17.1")

TEST PROVISION: Test 5 additional specimens if only 1 specimen fails.

CONCLUSION: Based on the above Results and Failure Criteria, the item tested:

Passes; Fails; Requires testing of 5 additional specimens

(continued on page 2)