CITY OF PORTLAND FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

July 10, 2017

Responsible Party 1:				
CP WESTGATE LLC				
300 THIRD AVE STE 2				
WALTHAM, MA 02451				
Location	CBL	Inspection Date		
1372 CONGRESS ST Unit #9	191 B019001	6/16/2017		
1372 CONGRESS ST Unit #9 Inspector	191 B019001 Inspection Type	-		

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101-7.9.3 EMERGENCY LIGHTS REQUIRE MAINTENANCE; 7.9.3 Periodic Testing of Emergency Equipment 7.9.3.1 Required emergency lighting systems shall be tested in accordance with one of the three options offered by 7.9.3.1.1, 7.9.3.1.2, or 7.9.3.1.3. 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted monthly with a minimum of 3 weeks and a maximum of 5 weeks between tests, for not less than 30 seconds, except as otherwise permitted by 7.9.3.1.1(2). (2) The test interval shall be permitted to be extended beyond 30 days with the approval of the authority having jurisdiction. (3) Functional testing shall be conducted annually for a minimum 1-1/2 hours if the emergency lighting system is battery powered. (4) The emergency lighting equipment shall be fully operational for the duration of the test required by 7.9.3.1.1(1) and (3). (5) Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction. Anytime Fitness: Light P2-26 needs new battery	//
NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. Anytime Fitness: Extinguishers need to be tagged.	//
NFPA 1 EXCESSIVE/DISORDERLY STORAGE; Reference NFPA 1 for excessive fuel-load. Anytime Fitness: Items stored in front of electrical panel, blocking access to panel	//

Violation		Proposed Date of Completion
FINAL DATE OF COMPLETE	D VIOLATION(S)	· / / /
FIRE PREVENTION BUREAU	RE-INSPECTION OF COMPLETED VIOLATION(S)	//
	t to reject or modify any proposed plan of action, and may nical capacity to complete the proposed plan. Please contact TION	-
understand that I must conta	ons listed within the timeframes provided. If I require add act the Fire Prevention Bureau <u>prior to the deadline</u> to requ's discretion to grant or deny.	
v	is my responsibility to schedule a reinspection of my prope . My failure to schedule a reinspection shall be deemed an nedied.	•
	greement, I understand that I am liable for penalties pursurs $\{s, s, s, 1-15\}$ and 10-25, and 30-A M.R.S. $\{s, s, s$	
Date	Responsible Party	
Date	Responsible Party	
SEEN AND AGREED		

Fire Prevention Bureau

Date