

Master Box Approval

Applicant: Charter Westgate

Emergency Contact: Myles Ostroff

App Phone #: 617-623-4333

Emergency phone #: 617-623-4333

Building Name: Westgate Shopping Plaza

Date of Application: 9/14/11

Building Address: 1364 Congress St

Billing Address:

800 Westchester Ave, STE S-632

Occupancy: Class A Mercantile

Rye Brook, NY 10573

Assembly OL>300, 20 unit apartment building, etc.

Comments:

Applicant completes red box and submits with Fire Alarm Permit

1

FIRE PREVENTION:

Approved

Denied

10 / 14 / 11

Date

B. G. Wallace
Fire Prevention Officer

Zone 1: Water flow

Zone 2: City disconnect - Water Flow

Zone 3: Pulls and detectors

Zone 4: City disconnect - Pulls and Detectors

Zone 5: Unassigned

Zone 6: Unassigned

Zone 7: Unassigned

Zone 8: AES Tamper switch

Modify City Box response to alarm sounding in CAD: YES NO

2

FIRE ALARM:

Box #: _____

ELECTRICAL DIVISION: Approved

Denied

Box Type: AES Radio Box /
New

Other

3

Test Date: ____ / ____ / ____

In Service Date: ____ / ____ / ____

Fire Alarm Technician

AES

Circuit if applicable: _____

4

FIRE ALARM: Same Running Assignment As Box: _____

Notifications: All Stations Run Books Digitizer Computer Cad Box Test

South Portland

Other

Dispatcher

5

BILLING: Entered

Financial Officer