

March 20, 2008

Ms. Jeanie Bourke, Division Director  
Inspection Services Program  
City of Portland  
389 Congress Street  
Portland, ME 04101

Building communities  
since 1870

Re: Charter Realty  
Westgate Plaza Remodel  
Chart-Block-Lot: 191-B-19  
Portland, ME  
Project No. 07182  
STRUCTURAL DEMOLITION

Dear Ms. Bourke:

I am writing to confirm that the limited demolition required for the above mentioned project will not impact the integrity of the existing structure. The items being removed, the sloping wood rafters, were added during a previous canopy remodel, and were not part of the original structure. Once they are removed, the original flat steel framed canopy structure will be exposed. We are essentially adding similar pitched roof framing in the locations of the framing demolition.

Please contact me if you have any questions, or need further assistance.

Sincerely,  
Harriman



Keith Brenner, P.E.

bkb