

City of Portland, Maine - Building or Use Permit Application
 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 011182	PERMIT ISSUED	CBL: 192 H026001
-------------------	----------------------	------------------

Location of Construction: 79 Hastings St	Owner Name: Farr-weinfeld Jonathan M &	Owner Address: 79 Hastings St	Phone: 207-871-5943
Business Name: n/a	Contractor Name: no contractor/self	Contractor Address: n/a n/a	Phone: 2078715943
Lessee/Buyer's Name: n/a	Phone: n/a	Permit Type: HVAC	Zone:

Past Use: Res. Single Fam.	Proposed Use: Same: Install Heating System	Permit Fee:	Cost of Work: \$30.00	CEO District: 3
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type:	

Proposed Project Description: Install Heating System	Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied		
Signature:	Date:	

Permit Taken By: cih	Date Applied For: 09/20/2001	Zoning Approval	
--------------------------------	--	------------------------	--

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date:	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
--	---	---	---

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.


SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
------------------------	---------	------	-------

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	DATE	PHONE
---	------	-------



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



192-H-02

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 79 Hastings St. Use of Building Garage (No. 101) / Sauna Date 9/20/01

Name and address of owner of appliance Jonathan Fair-Wentfeld 79 Hastings St.

Installer's name and address Jonathan Fair-Wentfeld

Telephone 207-871-5143

Location of appliance:

- Basement
- Floor ✓
- Attic
- Roof
- Garage Not attached to house ✓

Type of Fuel:

- Gas
- Oil
- Solid ✓

Appliance Name: Wood Burning Sauna Stove PKLE 18

U.L. Approved Yes No ?
See Attached Manual Where is The manual?

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # _____
- Other Owner Installed ✓

Type of Chimney:

Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # A218
Selkirk Metalbestos ✓

Direct Vent
Type _____ UL# _____

Type of Fuel Tank N/A

- Oil
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.



Approved

Approved with Conditions

Fire: _____
Ele.: _____
Bldg.: _____

- See attached letter or requirement
- * Fire box shall be a minimum of 18" Above garage Floor.
- * Stove shall be protected From car damage.
- * Fire Dept. must be call For inspection.
- * Install as per manufactures req.


Signature of Installer Jonathan Fair-Wentfeld
White - Inspection Yellow - File

18"
30"



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 79 Hastings St. Use of Building Garage (N/A) / Sauna Date 9/20/01

Name and address of owner of appliance Jonathan Fair-Weinfeld 79 Hastings St.

Installer's name and address Jonathan Fair-Weinfeld

Telephone 207-871-5943

Location of appliance:

- Basement
- Floor ✓
- Attic
- Roof
- Garage Not attached to house ✓

Type of Fuel:

- Gas
- Oil
- Solid ✓

Appliance Name: Wood Burning Sauna Stove PKLE18

U.L. Approved Yes No?
 See Attached Manual Where is The manual?

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # _____
- Other Owner Installed ✓

Type of Chimney:

- Masonry Lined
- Factory built _____

- Metal
- Factory Built U.L. Listing # A218
- Selkirk Metalbestos ✓

- Direct Vent
- Type _____ UL# _____

Type of Fuel Tank N/A

- Oil
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Approved

Approved with Conditions

Fire: _____ 4/1/01
Ele.: _____
Bldg.: _____ 1/1/01

- See attached letter or requirement
- * Fire box shall be a minimum of 18" Above garage Floor
- * Stove shall be protected from car damage
- * Fire Dept. must be call For inspection.
- * Install as per manufactures req.

Signature of Installer Jonathan Fair-Weinfeld

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy