

**From:** David Margolis-Pineo  
**To:** Helen Donaldson  
**CC:** David Senus; Dianne Gagnon; Marc Spiller; Tom Errico  
**Date:** 6/6/2013 2:38 PM  
**Subject:** Curb Waiver Request - Pomeroy

Nell,

**Pomeroy Street**

Public Services is agreeable to waiving the curb requirement for the Pomeroy St project. With the elevated street directing all street drainage to a soil filter for treatment, curb would impeded the drainage for this treatment.

There is currently an intermittent stream running down what will be the center of the new proposed Pomeroy St. In the past this water flowage has caused icing problems in Bancroft St. This problem has been corrected. If for some reason as a result of this project the icing problem returns, and we do not expected it to, the applicant shall be responsible for making the necessary changes to correct.