

March 2, 1936

AP - 19 Capisco Street

Owner—Antonio DiMillo  
10 Walnut Street

Contractor—Bragg Construction Co.  
36 Hestory Street

Building permit for change of use of single family dwelling at above location to two family dwelling with alterations as indicated in application for permit is issued herewith subject to the following conditions:-

- it is understood that the attic space is unfinished and is to be used for no purpose except possibly storage in connection with the living quarters in the building.
- a cleantout door is to be provided in chimney to which heater is connected and flue is to be thoroughly cleaned out.
- a shield of 3/16-inch asbestos lumber at least three times as wide as the diameter of the pipe is to be suspended about half way between the floor timbers and smokepipe of heater where it is closer than 15 inches to those timbers.
- notification is to be given this department for an inspection before any wall board is applied to new partitions.
- a certificate of occupancy for the new use of the building is required from this department before the new apartment is occupied.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings