

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1806	Issue Date: JAN - 3 2005	CBL: 194 B005001
-----------------------	-----------------------------	---------------------

Location of Construction: 27 CAPISIC ST	Owner Name: ST JOSEPH'S CONVENT & HOSP	Owner Address: 605 STEVENS AVE	Phone:
Business Name:	Contractor Name: Dodge Oil	Contractor Address: 79 New Portland Road Gorham	Phone:
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	Zone: R3

Past Use: Charitable and Benevolent - retirement housing for elderly nuns	Proposed Use: Charitable and Benevolent (retirement housing for elderly nuns) Set 2 200 gal. Tanks outside at the back of bldg	Permit Fee: \$30.00	Cost of Work: \$30.00	CEO District: 3	
Proposed Project Description: Set 2 200 gal. Tanks outside at the back of bldg		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied TO NFPA 58	INSPECTION Use Group: U Type: Tanks State Gas Reg NFPA		
		Signature:	Signature:		
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied			
		Signature:		Date:	

Permit Taken By: dmartin	Date Applied For: 12/15/2005	Zoning Approval		
-----------------------------	---------------------------------	------------------------	--	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	Historic Preservation <input type="checkbox"/> Not in District or Landmark little chapel historic building is not <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied
	Date: 12-15-05 ABN	Date:	Date:

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

_____ SIGNATURE OF APPLICANT	_____ ADDRESS	_____ DATE	_____ PHONE
_____ RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	_____ DATE	_____ PHONE	



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 27 Capic Use of Building Reflection Room Date 12/15/05
 Name and address of owner of appliance Frances wardle convent
37 Capisic Street Portland Me
 Installer's name and address Dodge Oil Co 79 New Portland Road
Gorham, Me 04038 Telephone 839-5536

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: _____

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # LP
- Other LIC# PNT586

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 200 gallons

Number of Tanks 2

Distance from Tank to Center of Flame NA feet.

Cost of Work: \$ _____

Permit Fee: \$ 30

Approved

Approved with Conditions

Fire: _____

See attached letter or requirement

Ele.: _____

Bldg.: _____

Inspector's Signature

Date Approved

Signature of Installer

Carl Coleman

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1806	Date Applied For: 12/15/2005	CBL: 194 B005001
------------------------------	--	---------------------

Location of Construction: 27 CAPISIC ST	Owner Name: ST JOSEPH'S CONVENT & HOSP	Owner Address: 605 STEVENS AVE	Phone:
Business Name:	Contractor Name: Dodge Oil	Contractor Address: 79 New Portland Road Gorham	Phone:
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	

Proposed Use: Charitable and Benevolent (retirement housing for elderly nuns) Set 2 200 gal. Tanks outside at the back of bldg	Proposed Project Description: Set 2 200 gal. Tanks outside at the back of bldg
---	--

Dept: Zoning	Status: Approved	Reviewer: Ann Machado	Approval Date: 12/16/2005
Note:			OktoIssue: <input checked="" type="checkbox"/>
Dept: Building	Status: Approved with Conditions	Reviewer: Tammy Munson	Approval Date: 12/28/2005
Note:			OktoIssue: <input type="checkbox"/>
1) The installation must comply with the State of Maine Gas Regulations.			
Dept: Fire	Status: Approved with Conditions	Reviewer: Cptn Greg Cass	Approval Date: 12/19/2005
Note:			OktoIssue: <input checked="" type="checkbox"/>
1) Install to comply with NFPA 58			



NO window
BACK
of
Building.

No Windows

Capric St.