

TABLE R502.5(1)
ORDER SPANS AND HEADER SPANS FOR EXTERIOR BEARING WALLS
(Maximum spans for Douglas fir-larch, hem-fir, southern pine and spruce-pine-fir³ and required number of jack studs)

HEADERS AND GRIDDERS SUPPORTING	SIZE	GROUND SNOW LOAD (psf)		
		50		
		Building Width ¹ (feet)		
	20	28	36	
Roof and ceiling	2-2x4	3-2	1 2-3	1 2-6
	2-2x6	4-8	1 4-1	1 3-8
	2-2x8	5-11	2 5-2	2 4-7
	2-2x10	7-3	2 6-3	2 5-7
	2-2x12	8-5	2 7-3	2 6-8
	3-2x8	7-5	1 6-5	2 5-9
	3-2x10	9-1	2 7-10	2 7-0
	3-2x12	10-7	2 8-2	2 8-2
	4-2x8	8-4	1 7-5	1 6-8
	4-2x10	10-6	1 9-1	2 8-2
Roof, ceiling and over center-bearing floor	2-2x4	2-9	1 2-3	1 2-2
	2-2x6	4-1	1 3-7	1 3-3
	2-2x8	5-2	2 4-6	2 4-1
	2-2x10	6-4	2 5-6	2 5-0
	2-2x12	7-4	2 6-5	2 5-9
	3-2x8	6-5	2 5-8	2 5-1
	3-2x10	7-11	2 6-11	2 6-3
	3-2x12	8-2	2 7-0	2 7-3
	4-2x8	7-5	1 6-8	1 5-11
	4-2x10	9-7	2 8-0	2 7-2
Roof, ceiling and one clear span floor	2-2x4	2-7	1 2-3	1 2-0
	2-2x6	3-10	2 3-4	2 3-0
	2-2x8	4-10	2 4-2	2 3-9
	2-2x10	5-11	2 5-1	2 4-7
	2-2x12	6-10	2 5-11	3 5-4
	3-2x8	6-1	2 5-11	2 4-8
	3-2x10	7-5	2 6-5	2 5-9
	3-2x12	8-7	2 7-5	2 6-8
	4-2x8	7-0	1 6-1	2 5-5
	4-2x10	8-7	2 7-5	2 6-7
Roof, ceiling and two center-bearing floor	2-2x4	2-6	1 2-2	1 1-11
	2-2x6	3-8	2 3-2	2 2-10
	2-2x8	4-7	2 4-0	2 3-8
	2-2x10	5-8	2 4-11	2 4-5
	2-2x12	6-6	2 5-9	3 5-2
	3-2x8	5-9	2 5-1	2 4-7
	3-2x10	7-1	2 6-2	2 5-7
	3-2x12	8-2	2 7-2	2 6-5
	4-2x8	6-8	1 5-10	2 5-3
	4-2x10	8-2	2 7-2	2 6-5
Roof, ceiling and two clear span floor	2-2x4	2-0	1 1-8	1 1-5
	2-2x6	3-0	2 2-7	2 2-3
	2-2x8	3-10	2 3-4	2 2-11
	2-2x10	4-8	2 4-0	3 3-7
	2-2x12	5-5	3 4-8	3 4-2
	3-2x8	4-9	2 4-1	2 3-8
	3-2x10	5-10	2 5-0	2 4-6
	3-2x12	6-9	2 5-10	3 5-3
	4-2x8	5-6	2 4-9	2 4-3
	4-2x10	6-9	2 5-10	2 5-2
4-2x12	7-9	2 6-9	2 6-0	

- For Sl: 1 inch=25.4mm, 1 pound per square foot=0.0479kN/m²
- Spans are given in feet and inches.
 - Tabulated values assume #2 grade lumber.
 - Building width is measured perpendicular to the ridge. For widths between those shown, spans are permitted to be interpolated.
 - NJ—Number of jack studs required to support each end. Where the number of required jack studs equals one, the header is permitted to be supported by an approved framing anchor attached to the full-height wall stud and to the header.
 - Use 30psf ground snow load for cases in which ground snow load is less than 30psf and the roof live load is equal to or less than 20psf

TABLE R502.5(2)
ORDER SPANS AND HEADER SPANS FOR INTERIOR BEARING WALLS
(Maximum spans for Douglas fir-larch, hem-fir, southern pine and spruce-pine-fir³ and required number of jack studs)

HEADERS AND GRIDDERS SUPPORTING	SIZE	Building Width ¹ (feet)		
		20		
		28	36	
One floor only	2-2x4	3-1	1 2-8	1 2-5
	2-2x6	4-6	1 3-11	1 3-6
	2-2x8	5-9	1 5-0	2 4-5
	2-2x10	7-0	2 6-1	2 5-5
	2-2x12	8-1	2 7-0	2 6-3
	3-2x8	7-2	1 6-3	1 5-7
	3-2x10	8-9	1 7-7	2 6-9
	3-2x12	10-2	2 8-10	2 7-10
	4-2x8	8-10	1 5-1	2 4-6
	4-2x10	10-1	1 8-9	1 7-10
Two floor only	2-2x4	2-2	1 1-10	1 1-7
	2-2x6	3-2	2 2-9	2 2-5
	2-2x8	4-1	2 3-6	2 3-2
	2-2x10	4-11	2 4-3	2 3-10
	2-2x12	5-9	2 5-0	3 4-5
	3-2x8	5-1	2 4-5	2 3-11
	3-2x10	6-2	2 5-4	2 4-10
	3-2x12	7-2	2 6-3	2 5-7
	4-2x8	4-2	2 3-7	2 3-2
	4-2x10	7-2	2 6-2	2 5-6
4-2x12	8-4	2 7-2	2 6-5	

TABLE R602.3(1)
FASTENER SCHEDULE FOR STRUCTURAL MEMBERS

DESCRIPTION OF BUILDING MATERIALS	DESCRIPTION OF FASTENER ^{h,c,d,e}	SPACING OF FASTENERS	
		Edges (inches) ¹	Intermediate support ⁴ (inches)
wood structural panels, subfloor, roof and wall sheathing to framing, and particulateboard wall sheathing to framing			
5/16" - 1/2"	6d common nail (subfloor, wall) 8d common nail (roof) ¹	6	12 ⁹
19/32" - 1"	8d common nail	6	12 ⁹
1-1/8" - 1-1/4"	10d common nail or 8d deformed nail	6	12
Other wall sheathing ¹¹			
1/2" regular cellulose fiberboard sheathing	1-1/2" galvanized roofing nail 6d common nail staple 16ga., 1-1/2" long	3	6
1/2" regular cellulose fiberboard sheathing	1-3/4" galvanized roofing nail 8d common nail staple 16ga., 1-3/4" long	3	6
25/32" structural cellulose fiberboard sheathing	1-1/2" galvanized roofing nail 6d common nail; staple galvanized, 1-1/2" long 1-1/4" screws, type W or S	3	6
1/2" gypsum sheathing	1-1/2" galvanized roofing nail 6d common nail staple 16ga., 1-1/2" long	4	8
5/8" gypsum sheathing	1-1/2" galvanized roofing nail 6d common nail staple 16ga., 1-1/2" long	4	8
wood structural panels, combination subfloor underlayment to framing			
3/4" and less	6d deformed nail or 8d common nail	6	12
7/8" - 1"	8d common nail or 8d deformed nail	6	12
1-1/8" - 1-1/4"	10d common nail or 8d deformed nail	6	12

- For Sl: 1 inch = 25.4mm, 1 foot = 304.8mm, 1 mile per hour = 1.609km/h.
- All nails are smooth-common, box or deformed shanks except where otherwise stated. Nails used for framing and sheathing connections shall have minimum average bending yield strengths as shown: 80ksi (561 MPa) for shank diameter of .192inch (20d common nail), 90ksi (620 MPa) for shank diameters larger than 0.142inch but not larger than 1.177inch, and 100ksi (689 MPa) for shank diameters of 0.142inch less.
 - Staples are 16 gage wire and have a minimum 7/16-inch on diameter crown width.
 - Nails shall be spaced at not more than 6inches on center at all supports where spans are 48inches or greater.
 - Four-foot- by-8-foot or 4-foot-by-9-foot panels shall be applied vertically.
 - Spacing of fasteners not included in this table shall be based on table R602.3(1).
 - For regions having basic wind speed of 110mph or greater, 8d deformed nails shall be used for attaching plywood and wood structural panel roof sheathing to framing within minimum 48-inch distance from gable end walls, if mean roof height is more than 25feet, up to 35feet maximum.
 - For regions having basic wind speed of 100mph or less, nails for attaching wood structural panel roof sheathing to gable end wall framing shall be spaced 6inches on center. When basic wind speed is greater than 100mph, nails for attaching panel roof sheathing to intermediate supports shall be spaced 6inches on center for minimum 48-inch distance from ridges, eaves and gable end walls; and 4inches on center to gable end wall framing.
 - Gypsum sheathing shall conform to ASTM C79 and shall be installed in accordance with GA 253. Fiberboard sheathing shall conform to either AIA 194.1 or ASTM C 208.
 - Spacing of fasteners on floor sheathing panel edges applies to panel edges supported by framing members and at all floor perimeters only. Spacing of fasteners on roof sheathing panel edges applies to panel edges supported by framing members and at all roof plane perimeters. Blocking of roof or floor sheathing panel edges perpendicular to the framing members shall not be required except at intersection of adjacent roof planes. Floor and roof perimeter shall be supported by framing members or solid blocking.

THIS INFORMATION IS PROVIDED TO OUR CUSTOMERS AS A SERVICE OF HANCOCK LUMBER. CUSTOMERS SHOULD APPRECIATE, HOWEVER, THAT THIS INFORMATION IS NOT THE WORK PRODUCT OF ANY ARCHITECT, NEITHER HANCOCK LUMBER NOR ANY OF ITS EMPLOYEES ARE LIABLE FOR ANY DAMAGE, INCLUDING REASONABLE ATTORNEY'S FEES, INCURRED BY ANY BUILDING OR STRUCTURE. CUSTOMERS SHOULD TAKE FINAL ACTION WITH REGARD TO ANY BUILDING OR STRUCTURE. CUSTOMERS SHOULD ALSO APPRECIATE THAT, BY PROVIDING CUSTOMERS WITH THIS INFORMATION, HANCOCK LUMBER DOES NOT GUARANTEE THE SOUNDNESS OR SUITABILITY OF THE INFORMATION FOR ANY PURPOSE OF THE CUSTOMER.

Revisions:

06/30/10	-

Date : 06/30/10
Scale : 1/4"=1'-0"
Drawn By: JTM
Project: GW060210
Sheet Number:
5 of 5