## CITY OF PORTLAND

#### FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

## NOTICE OF VIOLATION AND ORDER TO CORRECT

July 6, 2017

<b>Responsible Party 1:</b>				
PETERS JOHN C				
PO BOX 285				
GORHAM , ME 04038				
Location	CBL	Inspection Date		
1520 CONGRESS ST	196 D007001	6/12/2017		
Inspector	Inspection Type	Status		
Jonathan Hendricks	FP Routine Inspection	Failed		

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

#### You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<b>NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG</b> ; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. Stairway	//
<b>NFPA 720- 5.5.6.1 CO ALARMS REQUIRED</b> ; The performance, location, and mounting of notification appliances used to initiate or direct action, evacuation or relocation of the occupants, or for providing information to occupants or staff, shall comply with the requirements of Chapter 6. All Units with exception of Unit #2.	IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed.
<b>NFPA 101- 7.2.1.5.2 ILLEGAL LOCKS ON EXIT DOOR</b> ; Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. Apartment #4 Bedroom doors	IMMEDIATELY remove or disable all illegal locks on exit doors. Your signature below indicates that the illegal locks have been removed or disabled and will not be replaced.
<b>NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED</b> ; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements. Apt # 1 and #4 Bedrooms-	IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed.

Violation	Proposed Date of Completion
FINAL DATE OF COMPLETED VIOLATION(S)	//
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	//

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

# VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau <u>prior to the deadline</u> to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

**Responsible Party** 

Date

**Responsible Party** 

SEEN AND AGREED

Date

Fire Prevention Bureau