CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/28/14

SIDE ELEVATION
1/4" = 1'-0"

REAR ELEVATION
1/4" = 1'-0"

SIDE ELEVATION
1/4" = 1'-0"

SUNROOM PLAN (ANDERSON A-SERIES)

SECTION
1/4" = 1'-0"

PROVIDE 2X10 LEDGER BOARD AND SECURE WITH LedgerLOK SCREWS 16" OC IN W PATTERN. SECURE RAFTERS WITH SIMPSON LSSU410 BRACKETS

DOUBLE PRESSURE TREATED 2X10 BEAM SITTING ON EXISITNG 4 FOOTINGS SPACED APPROXIMATELY 5' - 4" APART

SUNROOM ROOF FRAMING PLAN
1/4" = 1'-0"

REVISIONS:
13-80-13 ISSUE FOR PRICING

CONSULTANTS:

TENENBAUM RESIDENCE

ADDRESS: 3 WINDSOR RUN PORTLAND, ME

CLIENT: DEB & ANDREW TENENBAUM

SUNROOM PLANS

DATE: 1/30/2013 DRAWN: MWS
PROJECT NO.: 2013-18 SCALE: 1/4" = 1'-0"

A1.1