Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/17/13
Planner: Jeanie Bourke

B-1 Zone

max Sq. footage = 32 ft
Showing 30 ft OK

max height = 16'
16' Shown
OK

Marge Schmuckal - Re: Sign

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/17/13
Planner: Jeanie Bourke

From: Marge Schmuckal
To: Cammy Reali
Date: 5/9/2013 11:09 AM
Subject: Re: Sign

Hi Cammy,
thank you for this. Can I also get a couple sketches of how the sign will actually look like? I am not understanding your written description that states a 3x6 cabinet with a 2x6 LED display. I also need in writing that the LED display will not flash, blink or scroll, nor change text more than once every 20 minutes.
Thank you,
Marge

>>> Cammy Reali <italian_heritage_center@yahoo.com> 5/9/2013 10:49 AM >>>

At the corner of Congress street and Westland Ave Italian Heritage Center

1. Excavate holes For sign base 3x4x4 Concrete base 3000psl

2. set 6x6 steel poles in grade 4 ft below grade

3. Install sign

4. (Trench Digging) Approximately 100 Ft from base of Telephone pole

5. Connect power to underground service for new sign, set a CMP certified meter

6. 3x6 Illuminated sign cabinet 18#

7. 2x6 Monochrome LED Message Center cabinet 12#

30#

Call to let me know you got all the information you needed

Frank Reali
207-318-9567

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/17/13

Planner: Jeanie Bourke

B-1 Zone

Min Setback is 5' - 8' & 25' Shown

OK

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/17/13

Planner: Jeanie Bourke

CITY OF PORTLAND, MAINE
REZURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/17/13

Planner: Jeanie Bourke