

GRAVEL COMPOUND DETAIL 1 SCALE: N.T.S. EC-1

32"x2"X4" WOOD STAKE OR EQUIVALENT 1/2"x3" WOOD STAKE 1/2"x3" REINFORCING STEEL OR EQUIVALENT WORK AREA STAKED BALES FLOW 4" EMBEDMENT (MIN.) 8"(MIN.)

HAY BALES/ SILT FENCE DETAIL SCALE: N.T.S. 2 EC-1

CONSTRUCTION SPECIFICATIONS - SILT FENCE

- 1) THE GEOTEXTILE FABRIC SHALL MEET THE DESIGN CRITERIA FOR SILT FENCES.
- 2) THE FABRIC SHALL BE EMBEDDED A MINIMUM OF 8 INCHES INTO THE GROUND AND THE SOIL COMPACTED OVER THE EMBEDDED FABRIC.
- 3) WOVEN WIRE FENCE SHALL BE FASTENED SECURELY TO THE FENCE POSTS WITH WIRE TIES OR STAPLES.
- 4) FILTER CLOTH SHALL BE FASTENED SECURELY TO THE WOVEN WIRE FENCE WITH TIES SPACED EVERY 24 INCHES AT THE TOP, MID-SECTION AND ROTTOM
- 5) WHEN TWO SECTIONS OF FILTER CLOTH ADJOIN EACH OTHER, THEY SHALL BE OVERLAPPED BY 6 INCHES, FOLDED, AND STAPLED.
- 6) FENCE POSTS SHALL BE A MINIMUM OF 36 INCHES LONG AND DRIVEN A MINIMUM OF 16 INCHES INTO THE GROUND. WOOD POSTS SHALL BE OF SOUND QUALITY HARDWOOD AND SHALL HAVE A MINIMUM CROSS SECTIONAL

MAINTENANCE - SILT FENCE

- SILT FENCES SHALL BE INSPECTED IMMEDIATELY AFTER EACH RAINFALL AND AT LEAST DAILY DURING PROLONGED RAINFALL. ANY REPAIRS THAT ARE REQUIRED SHALL BE MADE IMMEDIATELY.
- IF THE FABRIC ON A SILT FENCE SHOULD DECOMPOSE OR BECOME INEFFECTIVE DURING THE EXPECTED LIFE OF THE FENCE, THE FABRIC SHALL BE REPLACED PROMPTLY.
- SEDIMENT DEPOSITS SHOULD BE INSPECTED AFTER EVERY STORM EVENT.
 THE DEPOSITS SHOULD BE REMOVED WHEN THEY REACHED APPROXIMATELY
 ONE-HALF THE HEIGHT OF THE BARRIER.
- 4) SEDIMENT DEPOSITS THAT ARE REMOVED OR LEFT IN PLACE AFTER THE FABRIC HAS BEEN REMOVED SHALL BE GRADED TO CONFORM WITH THE EXISTING TOPOGRAPHY AND VEGETATED.
- 5) REMOVE ALL SEDIMENTATION CONTROLS AFTER SOIL IS STABILIZED.


EROSION CONTROL MEASURES:

- DISTURBED AREAS SHALL BE KEPT TO THE MINIMUM AREA NECESSARY
 TO CONSTRUCT THE ROADWAYS AND ASSOCIATED DRAINAGE FACILITIES.
- HAY BALE BARRIERS AND SEDIMENT TRAPS SHALL BE INSTALLED AS REQUIRED. BARRIERS AND TRAPS ARE TO BE MAINTAINED AND CLEANED UNTIL ALL SLOPES HAVE A HEALTHY STAND OF GRASS.
- 3) BALED HAY AND MULCH SHALL BE MOWINGS OF ACCEPTABLE HERBACEOUS GROWTH, FREE FROM NOXIOUS WEEDS OR WOODY STEMS, AND SHALL BE DRY. NO SALT HAY SHALL BE USED.
- FILL MATERIAL SHALL BE FREE FROM STUMPS, WOOD, ROOTS. ETC.
- 5) STOCKPILED MATERIALS SHALL BE PLACED ONLY IN AREAS SHOWN ON THE PLANS. STOCKPILES SHALL BE PROTECTED BY SILTATION FENCE AND SEEDED TO PREVENT EROSION. THESE MEASURES SHALL REMAIN UNTIL ALL MATERIAL HAS BEEN PLACED OR DISPOSED OFF SITE.
- 6) ALL DISTURBED AREAS SHALL BE LOAMED AND SEEDED. A MINIMUM OF 4 INCHES OF LOAM SHALL BE INSTALLED WITH NOT LESS THAN ONE POUND OF SEED PER 50 SQUARE YARDS OF AREA.
- 7) APPLICATION OF GRASS SEED, FERTILIZERS AND MULCH SHALL BE ACCOMPLISHED BY BROADCAST SEEDING OR HYDROSEEDING AT THE RATES OUTLINED BELOW:


LIMESTONE:75-100 LBS./1,000 SQUARE FEET.
FERTILIZER:RATE RECOMMENDED BY MANUFACTURER.
MULCH: HAY MULCH APPROXIMATELY 3 TONS/ACRE UNLESS
FROSION CONTROL MATTING IS LISED.

| LBS./ACRE |
|-----------|
| 20 |
| 20 |
| 2 |
| 42 |
| LBS./ACRE |
| 20 |
| 20 |
| 8 |
| 48 |
| |

- AFTER ALL DISTURBED AREAS HAVE BEEN STABILIZED THE
 TEMPORARY EROSION CONTROL MEASURES ARE TO BE REMOVED.
- ALL CATCH BASIN INLETS WILL BE PROTECTED WITH LOW POINT SEDIMENTATION BARRIER.
- 10) ALL STORM DRAINAGE OUTLETS WILL BE STABILIZED AND CLEANED AS REQUIRED, BEFORE THE DISCHARGE POINTS BECOME OPERATIONAL.
- 11) ALL DEWATERING OPERATIONS MUST DISCHARGE DIRECTLY INTO A SEDIMENT FILTER AREA.
- NO DISCHARGE SHALL BE DIRECTED TOWARDS ANY PROPOSED DITCHES, SWALES, OR PONDS UNTIL THEY HAVE BEEN PROPERLY STABULTED.








EVERGREEN PLANTING DETAIL

EC-1

SCALE: N.T.S.



NOTES:

1. COMPACT GRAVEL TO 95% MAXIMUM DRY DENSITY

2. COMPACT ALL UNDISTURBED MATERIAL PRIOR TO
PLACEMENT OF SUBBASE COURSE FOR GRAVEL DRIVEWAY.

| TYPICAL DRIVEWAY SECTION | |
|--------------------------|---|
| SCALE: N.T.S. | _ |



482 CONGRESS STREET, SUITE 100 PORTLAND, ME 04101



LICENSED ENGINEER DATE

| | REVISIONS | | | | | | |
|----|-----------|---|----------|-----------------------|--|--|--|
| | | | | | | | |
| L | | | | | | | |
| | | | | | | | |
| lΓ | | | | | | | |
| | | | | | | | |
| | 1 | | 04/04/16 | ISSUED FOR PERMITTING | | | |
| ΙC | 0 | | 03/02/16 | ISSUED FOR REVIEW | | | |
| R | EV. | # | DATE | DESCRIPTION | | | |

OJECT NO. DESIGNED BY: RP SCALE:

DRAWN BY: VP AS SHOWN

SITE NAME:

MFC PORTLAND

SITE ADDRESS:

9 WESTLAND AVENUE PORTLAND, ME 04101


SHEET TITLE

EROSION CONTROL, FENCE & MISC. DETAILS & NOTES

SHEET NO:

EC-1

EC-1



SCALE: 3/8"=1'-0'