| FIXT. TYPE | MANUFACTURER | CATALOG NO. | VOLTS | NO. OF LAMPS | LAMP TYPE | MOUNTING | DESCRIPTION |
|---------------|---|---|-------|-----------------|-----------------|----------------------------|--|
| A | PHILIPS/DAY—BRITE LIGHTING | 2-SMR-3-17-FS-01- UNV-1/3-EB | 120 | 3 | F17T8TL/835 | SURFACE | 2'x2' PRISMATIC LENS 1/8" THICK, FLUORESCENT W/ (1) 3—LAMP ELECTRONIC BALLAST. |
| AE | PHILIPS/DAY-BRITE LIGHTING | 2-SMR-3-17-FS-01- UNV-1/21-EB-E5 | 120 | 3 | F17T8TL/835 | SURFACE | 2'x2' PRISMATIC LENS 1/8" THICK, FLUORESCENT W/ (1) 2-LAMP ELECTRONIC BALLAST AND (1) 1-LAMP ELECTRONIC BALLAST WITH (1) 1-LAMP EMERGENCY BODINE BALLAST. REFER TO DETAIL E7.01/4. |
| В | PHILIPS/DAY-BRITE LIGHTING | 2-AT-N-G-2-32-DO- UNV-1/2-EB | 120 | 2 | F032/835 | RECESSED | 2'x4' RECESSED LAY-IN GRID FLUORESCENT INDIRECT W/ (1) 2-LAMP ELECTRONIC BALLAST. |
| BE | PHILIPS/DAY-BRITE LIGHTING | 2-AT-N-G-2-32-DO- UNV-1/2-EB-E5 | 120 | 2 | F032/835 | RECESSED | 2'x4' RECESSED LAY—IN GRID FLUORESCENT INDIRECT. SAME AS "B" WITH (1) 2—LAMP EMERGENCY BODINE BALLAST. REFER TO DETAIL E7.01/4. |
| B1 | PHILIPS/DAY-BRITE LIGHTING | 2-AT-N-G-2-17-DO- UNV-1/2-EB | 120 | 2 | F17T8TL/835 | RECESSED | 2'x2' RECESSED LAY-IN GRID FLUORESCENT INDIRECT W/ (1) 2-LAMP ELECTRONIC BALLAST. |
| B1E | PHILIPS/DAY-BRITE LIGHTING | 2-AT-N-G-2-17-DO- UNV-1/2-EB-E5 | 120 | 2 | F17T8TL/835 | RECESSED | 2'x2' RECESSED LAY—IN GRID FLUORESCENT INDIRECT.SAME AS "B1" WITH (1) 2—LAMP EMERGENCY BODINE BALLAST REFER TO DETAIL E7.01/4. |
| B2 | PHILIPS/DAY-BRITE LIGHTING | 2-ST-G-2-32-D-UNV- 1/2-EB | 120 | 2 | F032/835 | RECESSED | 2'x4' RECESSED LAY-IN GRID FLUORESCENT INDIRECT W/ (1) 2-LAMP ELECTRONIC BALLAST. THE ELECTRICAL CONTRACTOR SHALL CARRY AN ALLOWANCE OF \$95.00 PER LIGHTING FIXTURE. |
| B2E | PHILIPS/DAY-BRITE LIGHTING | 2-ST-G-2-32-D-UNV- 1/2-EB-E5 | 120 | 2 | F032/835 | RECESSED | 2'x4' RECESSED LAY-IN GRID FLUORESCENT INDIRECT. SAME AS "B2" WITH (1) 2-LAMP EMERGENCY BODINE BALLAST. THE ELECTRICAL CONTRACTOR SHALL CARRY AN ALLOWANCE OF \$125.00 PER LIGHTING FIXTURE. REFER TO DETAIL E7.01/4. |
| С | PHILIPS/DAY-BRITE LIGHTING | 2-SPW-G-3-32-FS-21- BLANK-120-1/3-EB | 120 | 3 | F032/835 | RECESSED | 2'x4' LAY-IN WITH 1/8" THICK PRISMATIC LENS, FLUORESCENT W/ (1) 3-LAMP ELECTRONIC BALLAST. |
| CE | PHILIPS/DAY-BRITE LIGHTING | 2-SPW-G-3-32-FS-21- BLANK-120-1/21-EB-E5 | 120 | 3 | F032/835 | RECESSED | 2'x4' LAY-IN WITH 1/8" THICK PRISMATIC LENS, FLUORESCENT W/ (1) 2-LAMP ELECTRONIC BALLAST AND (1) 1-LAMP ELECTRONIC BALLAST WITH (1) 1-LAMP EMERGENCY BODINE BALLAST. REFER TO DETAIL E7.01/4. |
| D | SIMKAR LIGHTING | CH-1-32-B11-120V | 120 | 1 | F032/835 | SURFACE/CHAIN | 6"x4' FLUORESCENT STRIP W/ (1) 1-LAMP ELECTRONIC BALLAST. |
| DE | SIMKAR LIGHTING | CH-1-32-ELS-B11-120V | 120 | 1 | F032/835 | SURFACE/CHAIN | 6"x4' FLUORESCENT STRIP W/ (1) 1-LAMP ELECTRONIC BALLAST. SAME AS "D" WITH (1) 1-LAMP EMERGENCY BODINE BALLAST. |
| E | PHILIPS/CAPRI LIGHTING | CFR62H18Q-U-F-RI- R6202 | 120 | 2 | CFQ18/G24Q/835 | RECESSED | CLEAR SPECULAR CONE DOWNLIGHT W/ (1) 2-LAMP ELECTRONIC BALLAST. |
| EE | PHILIPS/CAPRI LIGHTING | CFR62H18Q-U-F-RI-EM -R6202E | 120 | 2 | CFQ18/G24Q/835 | RECESSED | CLEAR SPECULAR CONE DOWNLIGHT. SAME AS "E" WITH (1) 2—LAMP EMERGENCY BODINE BALLAST. REFER TO DETAIL E7.01/4. |
| E1 | PHILIPS/CAPRI LIGHTING | CFR62H18Q-U-F-RI- R6232 | 120 | 2 | CFQ18/G24Q/835 | RECESSED | CLEAR SPECULAR CONE/PRISMATIC LENS DOWNLIGHT W/ (1) 2-LAMP ELECTRONIC BALLAST. |
| E1E | PHILIPS/CAPRI LIGHTING | CFR62H18Q-U-F-RI-EM -R6232E | 120 | 2 | CFQ18/G24Q/835 | RECESSED | CLEAR SPECULAR CONE/PRISMATIC LENS DOWNLIGHT. SAME AS "E1" WITH (1) 2-LAMP EMERGENCY BODINE BALLAST. REFER TO DETAIL E7.01/4. |
| E2 | PHILIPS/CAPRI LIGHTING | TBD | 120 | 1 | LED | RECESSED | CLEAR SPECULAR CONE/PRISMATIC LENS LED DOWNLIGHT. THE ELECTRICAL CONTRACTOR SHALL CARRY AN ALLOWANCE OF \$350.00 PER LIGHTING FIXTURE. |
| E2E | PHILIPS/CAPRI LIGHTING | TBD | 120 | 1 | LED | RECESSED | CLEAR SPECULAR CONE/PRISMATIC LENS LED DOWNLIGHT. THE ELECTRICAL CONTRACTOR SHALL CARRY AN ALLOWANCE OF \$350.00 PER LIGHTING FIXTURE.REFER TO DETAIL E7.01/4. |
| F | VISA LIGHTING | METRO OW1332- 1F40(120/277V)-V-SAL- SAL | 120 | 1 | FT40DL/2G11/835 | EXTERIOR/BLDG. MTD. | 7 1/4"W x 24 1/4"L x 4"D (MC 12 1/8"), BRUSHED ALUMINUM FRAME, ACCENT BAR & END CAP FINISH AND TRANSLUCENT WHITE ACRYLIC DIFFUSER W/ INTEGRAL ELECTRONIC HPF BALLAST. REFER TO ARCHITECTURAL ELEVATIONS FOR EXACT MOUNTING HEIGHT. |
| F1 | VISA LIGHTING | METRO OW1330- 1F40(120/277V)-V-SAL- SAL | 120 | 1 | FT40DL/2G11/835 | EXTERIOR/BLDG. MTD. | 7 1/4"W x 18 1/4"L x 4"D (MC 9 1/8"), BRUSHED ALUMINUM FRAME, ACCENT BAR & END CAP FINISH AND TRANSLUCENT WHITE ACRYLIC DIFFUSER W/ INTEGRAL ELECTRONIC HPF BALLAST. REFER TO ARCHITECTURAL ELEVATIONS FOR EXACT MOUNTING HEIGHT. |
| G | LIGHTOLIER | C7E17PLWHW-C770MHE1 | 120 | 1 | 70W MH ED17 | CANOPY | 7" APERTURE PRISMATIC LENSED HID DOWNLIGHT. |
| Н | C.W. COLE LIGHTING Co. | SE130A-BLK | 120 | 1 | 7WG23 | CANOPY | SIGN "OPEN/CLOSED" |
| H1 | C.W. COLE LIGHTING Co. | S351-W | 120 | 1 | 25W A19 | CANOPY | SIGN |
| | ACCULITE/JUNO LIGHTING, INC. | DR-CFTR32CF-QT120-PC | 120 | 1 | CFQ32/G24Q/835 | EXTERIOR BUILDING MOUNT | DECORATIVE HALF SPHERE STYLE. SECURITY/ACCENT LIGHTING W/WIDE THROW OPTICS, BUILT—IN PHOTO CELL AND FULL CUT—OFF—IDA SEAL OF APPROVAL. W/ REMOTE (1) 1—LAMP ELECTRONIC BALLAST AND (1) 1—LAMP EMERGENCY BODINE BALLAST. |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | , | | | |
| | | | | | | | |
| | | | | | | | |
| | PHILIPS/McPHILBEN EMERGENCY LIGHTING | CTXR6L54WCSWF | 120 | 2 | 12W HALOGEN | WALL | EMERGENCY LIGHTING BATTERY UNIT WITH SIDE MOUNTED HEADS. |
| Χ | PHILIPS/McPHILBEN EMERGENCY LIGHTING | CXXL-1-R-W | 120 | | LED | UNIVERSAL | SURFACE LED SELF-DIAGNOSTIC EXIT SIGN, WHITE WITH RED LETTERS, SINGLE FACED, AND BATTERY PACK, FOR ARROWS REFER TO DRAWINGS. |
| X1 | PHILIPS/McPHILBEN EMERGENCY LIGHTING | CXXL-3-R-W | 120 | and these | LED | UNIVERSAL | SURFACE LED SELF-DIAGNOSTIC EXIT SIGN, WHITE WITH RED LETTERS, DOUBLE FACED, AND BATTERY PACK, FOR ARROWS REFER TO DRAWINGS. |

COMMUNICATION AND SIGNAL SYMBOLS

TELEPHONE OUTLET; MOUNTED 18" A.F.F., 4" SQUARE BOX WITH SINGLE GANG PLASTER RING, 3/4" CONDUIT STUBBED UP 6" ABOVE CEILING AT 90 DEGREE ANGLE. TERMINATE WITH PLASTIC BUSHING.

"W" INDICATES MOUNTED 54" A.F.F.
"P" INDICATES PAY PHONE.

<u>DESCRIPTION</u>

"C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.

DATA OUTLET; MOUNTED 18" A.F.F., 4" SQUARE BOX WITH SINGLE GANG PLASTER RING, 3/4" CONDUIT STUBBED UP 6" ABOVE CEILING AT 90 DEGREE ANGLE. TERMINATE WITH PLASTIC BUSHING.

"W" INDICATES MOUNTED 54" A.F.F.
"C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.
"UC" INDICATES MOUNTED UNDER COUNTER — REFER TO ARCHITECTURAL DETAILS DWG. A8.01.

COMBINATION DATA/TELEPHONE OUTLET; MOUNTED 18" A.F.F., 4" SQUARE BOX WITH SINGLE GANG PLASTER RING, 3/4" CONDUIT STUBBED UP 6" ABOVE CEILING AT 90 DEGREE ANGLE. TERMINATE WITH PLASTIC RUSHING

WITH PLASTIC BUSHING.

"W" INDICATES MOUNTED 54" A.F.F.

"C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.
"UC" INDICATES MOUNTED UNDER COUNTER — REFER TO ARCHITECTURAL DETAILS DWG. A8.01.

CLOCK HANGER RECEPTACLE MOUNTED AT 7'-6" A.F.F. UNLESS OTHERWISE NOTED.

CABLE TELEVISION OUTLET MOUNTED AT 18" A.F.F. UNLESS OTHERWISE NOTED.

RECEPTACLE SYMBOLS

SYMBOL DESCRIPTION

<u>SYMBOL</u>

DUPLEX RECEPTACLE - GROUNDING TYPE - MOUNTED 18" A.F.F. UNLESS OTHERWISE INDICATED. NUMERAL INDICATES CIRCUIT NUMBER.

GFI

DUPLEX RECEPTACLE - GROUNDING TYPE - "GFI" INDICATES GROUND FAULT INTERRUPTING TYPE - MOUNTED 18" A.F.F. UNLESS OTHERWISE INDICATED.

DUPLEX RECEPTACLE — GROUNDING TYPE — MOUNTED AT 42" A.F.F. OR 6" ABOVE COUNTER TOP OR BACK SPLASH WHERE EXISTENT.

DUPLEX RECEPTACLE — GROUNDING TYPE — "GFI" INDICATES GROUND FAULT INTERRUPTING TYPE — MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER TOP OR BACK SPLASH WHERE EXISTENT.

DUPLEX RECEPTACLE — GROUNDING TYPE WITH SURGE SUPPRESSION PROTECTION MOUNTED AT 18"
A.F.F. UNLESS OTHERWISE INDICATED.

DUPLEX RECEPTACLE - ISOLATED GROUND TYPE - MOUNTED AT 18" A.F.F. UNLESS OTHERWISE INDICATED.

SINGLE RECEPTACLE -- GROUNDING TYPE - MOUNTED AT 18" A.F.F. UNLESS OTHERWISE INDICATED.

DOUBLE DUPLEX RECEPTACLE - GROUNDING TYPE - MOUNTED AT 18" A.F.F. UNLESS OTHERWISE

UC

DUPLEX RECEPTACLE - GROUNDING TYPE - "UC" INDICATES MOUNTED UNDER COUNTER - REFER TO ARCHITECTURAL DETAILS DWG. A8.01.

FLOOR OUTLET BOX WITH DUPLEX RECEPTACLE; REFER TO SPECIFICATIONS.

FLOOR OUTLET BOX WITH DOUBLE DUPLEX RECEPTACLE; REFER TO SPECIFICATIONS.

FLOOR OUTLET BOX WITH SINGLE RECEPTACLE; REFER TO SPECIFICATIONS.

CEILING MOUNTED BOX WITH DUPLEX RECEPTACLE; REFER TO SPECIFICATIONS.

A SPECIAL PURPOSE RECEPTACLE — "A" INDICATES TYPE AS SHOWN ON DRAWINGS.

SPECIAL PURPOSE RECEPTACLE - FLOOR OUTLET BOX - "A" INDICATES TYPE AS SHOWN ON DRAWINGS.

POWER POLE.

GENERAL ABBREVIATIONS

ABBREVIATIONS DEFINITION

WP WEATHERPROOF.

N.I.C. NOT IN CONTRACT.

A.F.F. ABOVE FINISHED FLOOR.

XP EXPLOSION PROOF.

ITS NOT TO SCALE.

R PASSIVE INFRARED.

TR EXISTING DEVICE SHALL REMAIN.

X EXISTING DEVICE SHALL BE REMOVED.

XR EXISTING DEVICE SHALL BE RELOCATED AS DIRECTED BY ARROW ON PLANS.

E EXISTING DEVICE RELOCATED TO LOCATION SHOWN.

HDCP HANDICAPPED ACCESSIBLE.

NOTE: ALL SYMBOLS ON THIS LIST ARE NOT NECESSARILY USED ON THIS JOB.

CONDUIT AND WIRE SYMBOLS

SYMBOL DESCRIPTION

LA-1,3,5

HOMERUN TO PANELBOARD "LA", CIRCUIT NUMBERS 1,3,5. DIAGONAL LINES INDICATE NUMBER OF
PHASE AND NEUTRAL WIRES, NO DIAGONAL LINES INDICATES 1/2"C.- 2#12 & 1#12 GND., UNLESS
OTHERWISE NOTED

- RACEWAY CONCEALED IN CEILING OR WALLS, OR EXPOSED IN UNFINISHED AREAS.

RACEWAY CONCEALED IN FLOOR SLAB.

FLEXIBLE RACEWAY; SIZE AS REQUIRED.

CONDUIT UP.

CONDUIT DOWN.

LIGHTING SYMBOLS

BOL DESCRIPTION

CEILING OR WALL, SURFACE OR RECESSED MOUNTED FLUORESCENT LIGHTING FIXTURE; "A" DENOTES TYPE (REFER TO FIXTURE SCHEDULE), NUMERAL DENOTES CIRCUIT NUMBER, "b" DENOTES FIXTURE CONTROLLED BY SWITCH "b".

SURFACE MOUNTED STRIP FLUORESCENT LIGHTING FIXTURE, "A" DENOTES TYPE (REFER TO FIXTURE SCHEDULE), NUMERAL DENOTES CIRCUIT NUMBER, "b" DENOTES FIXTURE CONTROLLED BY SWITCH "b".

CEILING RECESSED OR SURFACE MOUNTED INCANDESCENT, COMP. FLUOR OR HID LIGHTING FIXTURE. "B" DENOTES TYPE, NUMERAL DENOTES CIRCUIT NUMBER, AND "b" DENOTES FIXTURE CONTROLLED BY SWITCH "b". (WALL MOUNTED).

EXIT LIGHT CEILING MOUNTED WITH DIRECTIONAL ARROW AS INDICATED ON PLAN. (WALL MOUNTED WITHOUT ARROWS).

LIGHTING FIXTURE WIRED TO NIGHT OR EMERGENCY LIGHTING CIRCUIT.

EMERGENCY BATTERY UNIT WITH UNIT MOUNTED LIGHTHEADS. NUMBER OF LIGHTHEADS AS INDICATED ON PLANS.

REMOTE EMERGENCY LIGHTHEAD.

EB EMERGENCY BATTERY UNIT WITH REMOTE LIGHTHEADS AS INDICATED ON PLANS.

SWITCHING DESIGNATIONS

SYMBOL DESCRIPTION

S SINGLE POLE SWITCH MOUNTED 4'-0" A.F.F.

S₂ TWO POLE SWITCH MOUNTED 4'-0" A.F.F.

\$3 THREE WAY SWITCH MOUNTED 4'-0" A.F.F.

S₄ FOUR WAY SWITCH MOUNTED 4'-0" A.F.F.

 S_{K} SINGLE POLE SWITCH - KEY OPERATED - MOUNTED 4'-0" A.F.F.

S_P SINGLE POLE SWITCH AND PILOT LIGHT MOUNTED 4'-0" A.F.F.

S_M MOTOR RATED SWITCH WITH THERMAL OVERLOAD PROTECTION.

(PC) PHOTOCELL CONTROL DEVICE

PHOTOCELL CONTROL DE

DAYLIGHT SENSOR; "W" INDICATES MOUNTING HEIGHT OF 4'-0" A.F.F.

ULTRASONIC OCCUPANCY SENSOR; "W" INDICATES MOUNTING HEIGHT OF 4'-0" A.F.F. REFER TO DETAIL E7.01/1, E7.01/2 & E7.01/3.

INFRA-RED OCCUPANCY SENSOR; "W" INDICATES MOUNTING HEIGHT OF 4'-0" A.F.F. REFER TO DETAIL E7.01/1, E7.01/2 & E7.01/3.

DUAL TECHNOLOGY OCCUPANCY SENSOR; "W" INDICATES MOUNTING HEIGHT OF 4'-0" A.F.F. REFER TO DETAIL E7.01/1, E7.01/2 & E7.01/3.

MISCELLANEOUS SYMBOLS

SYMBOL DESCRIPTION

MOTOR. NUMERAL INDICATES HORSEPOWER.

NON-FUSED DISCONNECT SWITCH. 3 POLE, 30 AMP, UNLESS OTHERWISE NOTED.

FUSED 3 POLE DISCONNECT SWITCH. "30A" DENOTES SWITCH SIZE, "20A" DENOTES FUSE SIZE.

COMBINATION STARTER/NON-FUSED DISCONNECT SWITCH. 3 POLE, 30 AMP SWITCH, WITH NEMA SIZE 1

STARTER UNLESS OTHERWISE NOTED. (WITH FUSED DISCONNECT SWITCH).

MAGNETIC MOTOR STARTER.

JUNCTION BOX.

SURFACE MOUNT

SURFACE MOUNTED 120/208 VOLT PANELBOARD 6'-6" A.F.F. TO TOP. (FLUSH MOUNTED).

PLL WIR

PLUGMOLD STRIP WITH GROUNDING RECEPTACLES. SEE SPECIFICATIONS.

WIREMOLD WITH DUPLEX GROUNDING RECEPTACLES. SEE SPECIFICATIONS.

TC] TIME CLOCK. REFER TO SPECIFICATIONS.

PROGRAM OR DOOR BELL.

PUSHBUTTON STATION.

SMM A MOKEF ASSOCIATE

1000 Massachusetts Avenue Cambridge, Massachusetts 02138 617.547.5400 Fax 617.354.5758

| OWNER | REVIEW | |
|--|--|---|
| NAME | | DATE |
| ******************************* | | |
| *************************************** | | |
| *************************************** | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| *************************************** | · · · · · · · · · · · · · · · · · · · | |
| *************************************** | *************************************** | |
| *************************************** | | |
| | WATER THE PERSON AND ADDRESS OF THE PERSON ADDRESS OF THE PERSON AND ADDRESS OF THE PERSON | |
| | | |
| whatelede to the cute to the cute of the c | | *************************************** |
| *************************************** | | |
| | | |
| | *************************************** | |
| *************************************** | | |
| | 05.30.08 | ISSUED FOR BID |
| NO. ISSUE LO | DATE | DESCRIPTION |
| 1330E L | = CLOUDE | D CHANGE |
| | ~ L~ ~ L L | |

LEGEND AND SCHEDULE

1410 Congress Street Portland, ME 04102

| *************************************** | |
|---|-------|
| SCALE | NTS |
| SCALE | |
| DRAWN BY | SFM A |
| | 1/// |

CHECKED BY
PROJ. ARCH. / ENGR. SFM
PROJ. MGR. PJB
JOB NO. 07133.01

JOB NO. 07133.01

© SYMMES, MAINI & MCKEE ASSOCIATES, INC. 2008

