











## DETAIL "B" HANGING FROM BOTTOM CHORD

## JOIST HANGING NOTES:

- HANGERS AND SUPPORTING MEMBERS SHALL BE LOCATED AT PANEL POINTS OF JOISTS.
- 2. CONDUITS AND EQUIPMENT SHALL <u>NOT</u> BE HUNG FROM STEEL DECK OR FROM BRIDGING ANGLES.
- 3. WHERE POSSIBLE ALL HANGERS SHALL BE SUSPENDED FROM WIDE—FLANGED BEAMS INSTEAD OF BAR JOISTS.
- 4. CONDUITS 2 1/2" AND SMALLER RUNNING PARALLEL TO BAR JOISTS MAY BE HUNG FROM A SINGLE JOIST.
- PIPING 3" AND LARGER RUNNING PARALLEL TO BAR JOISTS SHALL BE SUPPORTED MID—WAY BETWEEN TWO JOISTS AND SHALL BE HUNG FROM PANEL POINTS AT APPROXIMATELY 5'-0" SPACING.
- 6. PIPING 4" AND LARGER IN SIZE RUNNING PERPENDICULAR TO AND SUSPENDED FROM JOISTS SHALL BE SUPPORTED FROM EVERY JOIST AT PANEL POINT.
- 7. PAIRS OF CONDUITS SHALL HAVE HANGERS STAGGERED BETWEEN ALTERNATE JOISTS OR SHALL BE HUNG FROM EVERY JOIST.
- 8. THE SUM OF ALL BUILDING TRADES HANGING FROM A PANEL POINT SHALL NOT EXCEED 200 LBS. WHEN THIS MAXIMUM IS EXCEEDED, A DETAIL OF PROPOSED METHOD OF HANGING SHALL BE SUBMITTED FOR APPROVAL.

ROOF DECK OR FLOOR SLAB

- 9. ECCENTRIC HANGERS (C-CLAMPS) WILL BE ALLOWED FOR PIPING SIZED 1~8" AND SMALLER AND OTHER TRADES WHERE THE HANGER SPACING LIMITS THE TOTAL POINT LOAD TO LESS THAN 30 LBS. ECCENTRIC HANGERS SHALL BE SECURED TO JOISTS ON TOP OR BOTTOM CHORD AT PANEL POINTS ONLY.
- 10. ALL WELDING OF JOISTS SHALL BE PARALLEL TO JOIST CHORDS.

## SYMMES MAINI & MCKEE ASSOCIATES

1000 Massachusetts Avenue Cambridge, Massachusetts 02138 617.547.5400 Fax 617.354.5758

OWNER	REVIEW

NAME	DATE
Warpanko and a spiritua and a spirit	
	anti-title

05.30.08 ISSUED FOR BID

NO. DATE DESCRIPTION

ISSUE LOG

C = CLOUDED CHANGE

Banknorth

1410 Congress Street

Portland, ME 04102

DETAILS

SCALE	NTS
DRAWN BY	SFM 0
CHECKED BY	Rl
PROJ. ARCH. / ENGR.	SFM
PROJ. MGR.	PJB
JOB NO.	07133.01
© CANNER MAINILS MOVEE ACCOUNTED INC	

ATTEND A PRE-HANGING CONFERENCE WITH GENERAL CONTRACTOR, THE ARCHITECT, AND ALL OTHER TRADES TO REVIEW HANGING METHODS AND COORDINATE HANGING SYMMES, MAINI & MCKEE ASSOCIATES, INC. 2008 COCATIONS.

E7.01

JOIST HANGING DETAILS

COORDINATE HANGING LOCATIONS AND DETAILS WITH ALL OTHER TRADES.

SUBMIT ALTERNATE METHODS FOR HANGING TO ARCHITECT FOR REVIEW AND

DO NOT USE WITHOUT WRITTEN APPROVAL FROM ARCHITECT.