

# STATEMENT TO OWNER/APPLICANT

(attachment to HHE-200)

A Site Evaluation as defined in The Maine Subsurface Wastewater Disposal Rules (January 18, 2011) is:

*“ The practice of investigating, evaluating, and reporting the basic soil and site conditions that apply to wastewater treatment and disposal along with a system design in compliance with this code.”*

All reported site features are interpreted from information supplied by the owner, applicant or representative. This information in turn is utilized as means to design a disposal system that complies with the Maine Subsurface Wastewater Disposal Rules. The owner, applicant, and/or representative prior to signing of this application must verify this information as correct.

Minimum separation distances required for disposal systems less than 1000 gpd (unless reduced by variance)

**Well (owner or neighbor) to any disposal component 100'**  
**Location of neighbor's wells is often difficult to observe. Many wells may be buried or hidden, making them unidentifiable. Confirmation from neighbor that their well is greater than 100' must be obtained prior to installation.**

• Water supply line to any disposal component	10'
• Building (full basement) to disposal area	20'
• Building (no full basement) to disposal area	15'
• Building to Septic Tank	8'
• Waterbody (major) to any septic component	100'
• Waterbody (minor) to any septic component	50'
• Property line to any septic component	10'*

\* All fill material (fill extension) to be contained within property with 4:1 slope

If after review it is agreed that all information is accurate, the following steps should be taken.

1. Sign the Owner or Applicant Statement section on page 1 of the application
2. Sign any Variance forms or any special circumstance forms that may be attached
3. If required, secure any neighbor variance/release form signatures
4. Repeat signatures on all copies
5. Submit 3 copies to your local Code Enforcement for review and approval

Prior to installation it is recommended that all abutting property owners be notified.

**Harris Septic Solutions, Inc.**  
**(207) 892-2435**