PUMP PERFORMANCE SCHEDULE

TAG	FLOW RATE (GPM)	HEAD (FT.WG)	IMPEL. SIZE	RPM	EFF %	ELECTRICAL REQUIREMENTS					BASIS OF DESIGN : TACO		
						HP	BHP	VFD	AMPS	V/PH/HZ	SERVICE	ARRANGEMENT	MODEL
CP-1	20	150	-	3250	-	1/25	-	N	0.84	120/1/60	RHW	CARTRIDGE	00865

TEMPERATURE MIXING VALVE PERFORMANCE SCHEDULE

TAG	FLOW RATE (GPM)	INLET CONNECTION (INCHES)	OUTLET CONNECTION (INCHES)	W.P.D (PSIG)	SET POINT (DEGREES F)	PROVIDE SPARE CARTRIDGE (Y) OR (N)	BASIS OF DESIGN : SYMMONS		
							SERVICE	ARRANGEMENT	MODEL
TMV-1	7.0	3/4"	3/4"	60	110°F	Y	DOM HW (EWH-1)	WALL	7-200-W

ELECTRIC BASEBOARD HEATER PERFORMANCE SCHEDULE

TAG	OUTPUT (MBH)	LENGTH (FT-IN)	MTG.HT. AFF (IN)	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN : BERKO	
				KW	V/PH/HZ	SERVICE	MODEL
EBB-1	3.4	4'-0"	*	1.0	208/1/60	MULTIPLE	BKOC2504W
EBB-2	6.8	8'-0"	*	2.0	208/1/60	MULTIPLE	BKOC2508W

* - MOUNTING HEIGHT SHALL BE PER MANUFACTURER'S RECOMMENDATIONS

PLUMBING FIXTURE CONNECTION SCHEDULE

TAG	DESCRIPTION	SAN	VENT	CW	HW
P-1	ADA TANK TYPE WATER CLOSET	3"	2"	1/2"	-
P-2	ADA WALL HUNG LAVATORY	1-1/2"	1-1/2"	1/2"	1/2"
P-3	ADA EXAM RM SINK	1-1/2"	1-1/2"	1/2"	1/2"
P-4	ADA SINGLE BOWL SS SINK	1-1/2"	1-1/2"	1/2"	1/2"
P-5	MOP BASIN	3"	2"	3/4"	3/4"

ELECTRIC WATER HEATER PERFORMANCE SCHEDULE

TAG	STORAGE (GAL)	1st HR RATE (GAL)	REC'VRY @ 90°F RISE	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN : AO SMITH	
				WATTS	V/PH/HZ	SERVICE	MODEL
EWH-1	30	40	20	4500/4500*	208/1/60	DOM. HW	DEL-30

* - WIRED FOR NON-SIMULTANEOUS OPERATION

ELECTRIC WALL HEATER PERFORMANCE SCHEDULE

TAG	OUTPUT (MBH)	AIRFLOW (CFM)	MTG.HT. AFF (IN)	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN : BERKO	
				KW	V/PH/HZ	SERVICE	MODEL
WH-1	10.2	100	12"	3.0	208/1/60	MULTIPLE	FRA4024F

FAN PERFORMANCE SCHEDULE

TAG	AIRFLOW (CFM)	T.S.P (IN.WG)	NOISE (SONES)	RPM	DRIVE	ELECTRICAL REQUIREMENTS					BASIS OF DESIGN : PANASONIC		
						HP	BHP	WATTS	AMPS	V/PH/HZ	SERVICE	ARRANGEMENT	MODEL
EF-1	110	0.25	0.4	-	DIRECT	-	-	9.8	0.2	120/1/60	BATHROOMS (MULTIPLE)	CEILING	FV-05-11VKI
EF-2	50	0.25	0.4	-	DIRECT	-	-	3.2	0.2	120/1/60	COPIER	CEILING	FV-05-11VKI
EF-3	110	0.25	0.4	-	DIRECT	-	-	9.8	0.2	120/1/60	LAB	CEILING	FV-05-11VKI

AIR DEVICE PERFORMANCE SCHEDULE

TAG	PANEL SIZE(IN)	NECK SIZE(IN)	AIRFLOW (CFM)	SP.LOSS (IN.WG.)	THROW(L)	Nc	BASIS OF DESIGN - METALAIRE		
							DUCT CONN.(IN)	PATTERN	MODEL
A	24x24	6x6	100	0.05	-	25	SEE DWGS	SEE DWGS	5000D
B	24x24	9x9	250	0.05	-	25	SEE DWGS	SEE DWGS	5000D
C	24x24	12x12	400	0.05	-	25	SEE DWGS	SEE DWGS	5000D
D	24x24	6"ϕ	100	0.05	-	25	SEE DWGS	SEE DWGS	MSE-HC*
E	24x24	8"ϕ	250	0.05	-	25	SEE DWGS	SEE DWGS	MSE-HC*
F	24x24	10"ϕ	350	0.05	-	25	SEE DWGS	SEE DWGS	MSE-HC*
G	24x24	12"ϕ	500	0.05	-	25	SEE DWGS	SEE DWGS	MSE-HC*
AA	-	18x18	800	0.05	-	25	SEE DWGS	1/2", 45°	RHD
BB	-	14x14	550	0.05	-	25	SEE DWGS	1/2", 45°	RHD
CC	-	12x12	400	0.05	-	25	SEE DWGS	1/2", 45°	RHD
DD	-	8x8	100	0.05	-	25	SEE DWGS	1/2", 45°	RHD

* - SET MINIMUM TO 50% OF MAXIMUM

MECHANICAL AND PLUMBING SYMBOLS AND ABBREVIATIONS LEGEND

NOTE - USE SYMBOLS AND ABBREVIATIONS AS APPLICABLE FOR THIS MECHANICAL DRAWING SET.
SOME SYMBOLS AND ABBREVIATIONS IN THIS LEGEND MAY NOT APPLY.

SYMBOL	DESCRIPTION
CA	COMPRESSED AIR PIPING (CA)
C	CONDENSATE DRAIN PIPING (C)
CTR	COOLING TOWER RETURN PIPING (CTR)
CTS	COOLING TOWER SUPPLY PIPING (CTS)
CWR	CHILLED WATER RETURN PIPING (CWR)
CWS	CHILLED WATER SUPPLY PIPING (CWS)
FOR	FUEL OIL RETURN PIPING (FOR)
FOS	FUEL OIL SUPPLY PIPING (FOS)
G	GAS PIPING (G)
HWR	HOT WATER RETURN PIPING (HWR)
HWS	HOT WATER SUPPLY PIPING (HWS)
RL	REFRIGERANT LIQUID PIPING (RL)
RG	REFRIGERANT GAS PIPING (RG)
	SANITARY PIPING BELOW FLOOR (SAN)
	SANITARY PIPING ABOVE FLOOR (SAN)
	SANITARY VENT PIPING
RWL	RAINWATER LEADER ABOVE SLAB (RWL)
	COLD WATER PIPING (CW)
	HOT WATER PIPING (HW)
	RECIRCULATED HOT WATER PIPING (RHW)
	PIPE CAP
	DIRECTION OF FLUID FLOW
	ELBOW UP
	ELBOW DOWN
	PIPE TEE UP
	PIPE TEE DOWN
	PIPE REDUCER
	PIPE WITH GUIDE
	PIPE WITH ANCHOR
	BUTTERFLY VALVE
	OS & Y GATE VALVE

SYMBOL	DESCRIPTION
	BACKFLOW PREVENTER (BFP)
	CHECK VALVE
	BALANCING VALVE (ADJUSTABLE)
	AUTOMATIC FLOW CONTROL VALVE
	RELIEF VALVE (RV)
	BALL VALVE
	BALL VALVE
	3/4" BALL VALVE WITH 3/4" HOSE END
	GATE VALVE
	PRESSURE REDUCING VALVE
	FUSIBLE VALVE
	STRAINER W/BLOWDOWN BALL VALVE
	2-WAY CONTROL VALVE
	SOLENOID VALVE
	3-WAY CONTROL VALVE
	3-WAY CONTROL VALVE (TOP VIEW)
	4-WAY CONTROL VALVE (TOP VIEW)
	2 BUTTERFLY VALVES W/SINGLE ACTUATOR
	BUTTERFLY VALVE W/ACTUATOR
	TRIPLE-DUTY VALVE
	UNION
	PIPE FLANGE
	PUMP WITH FLANGES
	BASE MOUNTED PUMP
	CARTRIDGE TYPE INLINE PUMP
	VERTICAL INLINE PUMP
FC	FLEXIBLE PIPE CONNECTION (FC)
	PITCH DOWN
	PETCOCK
	CONNECT TO EXISTING

SYMBOL	DESCRIPTION
	PRESSURE GAGE WITH GAGE COCK
	THERMOMETER IN WELL
	WATER FLOW SWITCH
	PRESSURE SWITCH OR SENSOR
	EMURSION TEMPERATURE SENSOR
	DUCT MOUNTED SMOKE DETECTOR
	ROOM TEMPERATURE SENSOR
	THERMOSTAT OR SENSOR ON WALL
TG	TSTAT OR SENSOR W/ TAMPERPROOF GUARD
	MANUAL AIR VENT
2	NOTE TAG (NUMBER)
A 250	AIR DEVICE TAG (LETTER) WITH CFM
101	ROOM NUMBER
	TURNING VANES
	DUCT W/MANUAL DAMPER
	DUCT W/FLEXIBLE CONNECTION (FC)
	LAGGED DUCT
	DUCT W/ACOUSTIC LINING
	DUCT W/SQUARE-TO-ROUND TRANSITION
	FLEXIBLE DUCT
MOD	MOTOR OPERATED DAMPER
	AIRFLOW OUT
	AIRFLOW IN
ϕ	DIAMETER OR FLAT OVAL
	FIRE DAMPER
	ROUND OR FLAT OVAL DUCT DOWN
	ROUND OR FLAT OVAL DUCT UP
	SUPPLY DIFFUSER
	RETURN GRILLE
	STEAM TRAP
	WATER HAMMER ARRESTOR

ABBREVIATION	DESCRIPTION
AAV	AUTOMATIC AIR VENT
AD	ACCESS DOOR
AFF	ABOVE FINISHED FLOOR
AHU-*	AIR HANDLING UNIT TAG
AMS	AIRFLOW MONITORING STATION
AMPS	AMPERES
AP	ACCESS PANEL
APD	AIR PRESSURE DROP
AS-*	AIR SEPARATOR TAG
ATC	AUTOMATIC TEMPERATURE CONTROL
B-*	BOILER TAG
BD-*	BYPASS DAMPER TAG
BFP-*	BACKFLOW PREVENTER TAG
BHP	BRAKE HORSEPOWER
BTUH	BRITISH THERMAL UNITS PER HOUR
CBD	COUNTER BALANCED DAMPER
CC-*	COOLING COIL TAG
CFM	CUBIC FEET PER MINUTE
CHLR-*	CHILLER TAG
CO	CLEANOUT
CONV-*	CONVECTOR TAG
CUH-*	CABINET UNIT HEATER TAG
CP-*	CIRCULATING PUMP TAG
CT-*	COOLING TOWER TAG
Cv	VALVE COEFFICIENT
CW	COLD WATER
CHWS/R	CHILLED WATER SUPPLY AND RETURN
DB	DRY BULB
dB RE	DECIBELS RELATIVE TO
DC	DOUBLE CHECK
DCA	DOUBLE CHECK ATMOSPHERIC
DEG F	DEGREES FAHRENHEIT
DIA	DIAMETER
DIW	DOWN IN WALL
DN	DOWN
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE

ABBREVIATION	DESCRIPTION
EDB	ENTERING DRY BULB
EDC-*	ELECTRIC DUCT COIL TAG
EER	ENERGY EFFICIENCY RATIO
EFWH-*	EXHAUST FAN TAG
EFF	EFFICIENCY
EG-*	EXHAUST GRILLE TAG
ER-*	EXHAUST REGISTER TAG
ESP	EXTERNAL STATIC PRESSURE
ET-*	EXPANSION TANK TAG
EWB	ENTERING WET BULB
EWH-*	ELECTRIC WATER HEATER TAG
EWT	ENTERING WATER TEMPERATURE
EXG	EXISTING
EXH	EXHAUST
FC	FLEXIBLE CONNECTION
FCO	FLOOR CLEANOUT
FD	FIRE DAMPER
FD-*	FLOOR DRAIN TAG
FLA	FULL LOAD AMPS
FOR	FUEL OIL RETURN
FOS	FUEL OIL SUPPLY
FPHB	FROST PROOF HOSE BIBB
FPM	FEET PER MINUTE
FS-*	FLOOR SINK TAG
FT	FEET
FTR-*	FINTUBE RADIATION TAG
GA.	GAGE
GAL	GALLONS
GFWH-*	GAS FIRED WATER HEATER TAG
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
GUH-*	GAS UNIT HEATER TAG
HC-*	HEATING COIL TAG
HP	HORSEPOWER
HRV-*	HEAT RECOVERY VENTILATOR TAG
HW	HOT WATER
HWS/R	HOT WATER SUPPLY AND RETURN

ABBREVIATION	DESCRIPTION
I=B=R	INSTITUTE OF BOILER AND RADIATOR MANUFACTURERS
IFWH-*	INDIRECT FIRED WATER HEATER TAG
IN.	INCHES
IV-*	INTAKE VENT TAG
L-*	LOUVER TAG
LAT	LEAVING AIR TEMPERATURE
LB	POUNDS
LD-*	LINEAR DIFFUSER TAG
LTHWS/R	LOW TEMPERATURE HOT WATER
LRA	LOCKED ROTOR AMPS
LWCO	LOW WATER CUTOUT
LWT	LEAVING WATER TEMPERATURE
MAX	MAXIMUM
MBH	THOUSANDS OF BTU PER HOUR
MCA	MINIMUM CIRCUIT AMPACITY
MIN	MINIMUM
NC	NOISE CRITERION
NIC	NOT IN CONTRACT
NTS	NOT TO SCALE
OA	OUTSIDE AIR
OBD	OPPOSED BLADE DAMPER
O.D.	OUTSIDE DIAMETER
OED	OPEN ENDED DUCT
OFWH-*	OIL FIRED WATER HEATER TAG
OPD	OVERCURRENT PROTECTIVE DEVICE
P-*	PLUMBING FIXTURE TAG
PENET'N	PENETRATION
PF-*	PADDLE FAN TAG
PSIA	POUNDS PER SQUARE INCH ABSOLUTE
PSIG	POUNDS PER SQUARE INCH GAGE
PVC	POLYVINYL CHLORIDE (PIPE)
RA	RETURN AIR
RD	ROOF DRAIN
RDE	RECOMMENDED DUAL ELEMENT FUSE AMPS
RG-*	RETURN GRILLE TAG
RHW	RECIRCULATED HOT WATER

ABBREVIATION	DESCRIPTION
RLA	RUNNING LOAD AMPS
RPM	REVOLUTIONS PER MINUTE
RPS	REVOLUTIONS PER SECOND
RPZ	REDUCED PRESSURE ZONE
RR-*	RETURN REGISTER TAG
RTU	ROOM TEMPERATURE SENSOR
RV	RELIEF VALVE
RWL	RAINWATER LEADER
SA	SUPPLY AIR
SAN	SANITARY (DRAIN & WASTE)
SD	SMOKE DAMPER
SEER	SEASONAL ENERGY EFFICIENCY RATIO
SF	SUPPLY FAN
SG-*	SUPPLY GRILLE TAG
SP	STATIC PRESSURE
SP-*	SUMP PUMP TAG
SR-*	SUPPLY REGISTER TAG
SQFT	SQUARE FEET
ΔT	TEMPERATURE DIFFERENTIAL
TEMP.	TEMPERATURE
TCP	TEMPERATURE CONTROL PANEL
TMV-*	THERMOSTATIC MIXING VALVE TAG
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
UH-*	UNIT HEATER TAG
VAV-*	VARIABLE AIR VOLUME BOX TAG
VB	VACUUM BREAKER
VFD	VARIABLE FREQUENCY INVERTER DRIVE
VTR	VENT THRU ROOF
V/PH/HZ	VOLTS/PHASES/HERTZ
WB	WET BULB
WCO	WALL CLEANOUT
WG	WATER GAGE
WPD	WATER PRESSURE DROP
WSA	WIRE SIZING AMPS
WTD	WATER TEMPERATURE DROP
W/	WITH

© 2016 Michael R. Charek, Architect

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/07/16

Michael Charek Architects
25 Hartley Street
Portland, Maine
04103
(207) 761-0556

STATE OF MAINE
LICENSED
PROFESSIONAL ENGINEER
Michael R. Bennett
No. 7267
5/17/2017

Offices for Casco Bay Eyecare
1440 Congress Street
Portland, ME 04102

Title
MECHANICAL SCHEDULES AND LEGEND

Scale: 1/4" = 1'-0"

Date: 5/17/16

Revisions
05/17/16 ISSUED FOR CONSTRUCTION

Sheet
M3