


# SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services  
 Division of Health Engineering, Station 10 SHS  
 (207) 287-5672 FAX (207) 287-4172



## SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole **TP 1** ■ Test Pit □ Boring  
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
10	FINE SANDY LOAM	FROZEN	DARK BROWN	
20	LOAMY FINE SAND TO SANDY LOAM	FIRM	OLIVE BROWN	COMMON DISTINCT
30				
40	LIMIT OF EXCAVATION			
50				

Soil Classification	Slope	Limiting Factor	Ground Water
<b>B</b> Profile	<b>C</b> Condition	<b>20"</b>	<input type="checkbox"/> Restrictive Layer <input type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth

Observation Hole **TP 2** ■ Test Pit □ Boring  
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
10	SANDY LOAM (FILL)	FROZEN	DARK BROWN	
20				
30	FINE SAND	FRIABLE	OLIVE BROWN	
40				
50				

Soil Classification	Slope	Limiting Factor	Ground Water
<b>FILLED LAND</b> Profile			<input type="checkbox"/> Restrictive Layer <input type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth

*Albert Frick*  
 Site Evaluator Signature

163  
 SE \*

4/26/2004  
 Date