

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

WAYNFLETE SCHOOL THE /North Yarmouth
Construction/Paul Hryniewich

Located at

100 OSGOOD ST

PERMIT ID: 2013-00825

ISSUE DATE: 05/20/2013

CBL: 198 F001001

has permission to **Build 2 dugouts, one on the first base line the 2nd the third base line**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Footings/Setbacks
Framing Only
Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-00825	Date Applied For: 04/26/2013	CBL: 198 F001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Waynflete School Field Activities		Proposed Project Description: Build 2 dugouts, one on the first base line the 2nd the third base line		
Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 05/07/2013	Ok to Issue: <input checked="" type="checkbox"/>
Note: the Administrative Authorization must be granted prior to issuing permit				
Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 05/17/2013	Ok to Issue: <input type="checkbox"/>
Note:				
1) The dugouts must meet ADA requirements.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
Dept: DRC	Status: Not Applicable	Reviewer:	Approval Date: 05/02/2013	Ok to Issue: <input type="checkbox"/>
Note:				