



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 947 Westbrook St

CBL 199 A001002

Issued to Starbucks/Lester Lloyd Architects

Date of Issue 11/10/2003

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 03-1171, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire Kiosk

APPROVED OCCUPANCY

Retail/Commercial

Use Group: B

Type: 2

BOCA '99

Limiting Conditions:

None

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

11/3/03 - for Capt - Throwing & Fresh ok
Plenty & also with ready D

11/6/03 - for Capt & Rec - NO
X Can on bins, Missing trap
on handlink, Refig not down
to tank D

11/7/03 for Capt
all good ok - construction
to approved plans -
ok by release rec -
ok for Capt
D

10/16/03 - Framing for new ("STAR bucks")
no load bearing walls/metal studs - no problems seen
OK to class in after Mike Calmes (electrical inspector)
does his inspection. JRM M

11/3/03 - For final & FSE lic - not ready yet
Power in p120, some glow stick, still packed
to eliminate trip hazard - pull call back
Mike Nady R

11/6/03 - for final & FSE - NO
1) See mark & then indirect drain
close home air gap
2) No trap on handwash sink

11/16/03 - Complete B. Specialty
ok to install FSE for
ok for sign