

SERIES FAN POWERED VARIABLE AIR VOLUME BOX SCHEDULE - WITH REHEAT																			
UNIT NO.	AREA SERVED	COOLING CFM		HTG CFM	VAV BOX FAN HP	VAV BOX FAN VOLT	LxWxH IN	UNIT INLET S.P. IN WC	INLET DIM.	HOT WATER COIL							CONTROL VALVE CV (SEE NOTE 5 BELOW)	MANUFACTURER AND MODEL NUMBER	NOTES
		MAX.	MIN.							COIL HTG MBH	EAT °F	LAT °F	FLOW GPM	EWT °F	LWT °F	WPD FT			
LEVEL 2 - ZONE 3																			
2-3-01	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-3-02	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-3-03	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-3-04	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
LEVEL 2 - ZONE 4																			
2-4-01	IDF 1523	800	240	240	1/2	277	44x48x12	0.38	14x8	33	65	103	1.7	180	140	2	1.9	TRANE LSWF14	1-5
2-4-02	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	3	TRANE LSWF14	1-5
2-4-03	EXISTING TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	3	TRANE LSWF14	1-5
LEVEL 2 - ZONE 5																			
2-5-01	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-02	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-03	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-04	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-05	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-06	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-07	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-08	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-09	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-10	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-11	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-12	TICKETING	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-16	WOMENS 1519 & MENS 1522	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
2-5-18	CSR 1537	800	240	240	1/2	277	47x30x22	0.38	8x9	33	65	103	1.85	180	140	2	1.9	TRANE VSWF08	1-5
2-5-19	ETD 1599	1800	600	600	2x1/2	277	47x30x22	0.13	14x9	22.8	55	90	1.2	180	140	3	3	TRANE VSWF14	1-5
2-5-20	ETD 1599	1800	600	600	2x1/2	277	47x30x22	0.13	14x9	22.8	55	90	1.2	180	140	3	3	TRANE VSWF14	1-5
2-5-21	ETD 1599	1800	600	600	2x1/2	277	47x30x22	0.13	14x9	22.8	55	90	1.2	180	140	3	3	TRANE VSWF14	1-5
2-5-22	BAGGAGE HANDLING OFFICES	800	240	240	1/2	277	44x48x12	0.38	14x8	33	65	103	1.7	180	140	2	1.9	TRANE LSWF14	1-5
LEVEL 3 - ZONE 1																			
3-1-01	LOCKERS 2006 & RECEPTION 2107	310	100	100	1/2	277	26x40x11	0.19	6x9	14.6	63	122	1.0	180	140	1.8	3	TRANE LSWF06	1-5
3-1-03	ACTIVE FILE & COPY 2007	200	75	75	1/2	277	26x40x11	0.06	6x9	2.8	63	120	0.73	180	140	1.7	3	TRANE LSWF06	1-5
3-1-04	STAFF LOUNGE 2020	370	115	115	1/2	277	26x40x11	0.29	6x9	4.4	55	90	0.2	180	140	3	3	TRANE LSWF0600W	1-5
3-1-06	MENS 2006 & WOMENS 2027	800	240	240	1/2	277	44x48x12	0.38	14x8	33	65	103	1.7	180	140	2	1.9	TRANE LSWF14	1-5
3-1-09	LARGE CONFERENCE 2012	1220	600	600	1	277	44x48x12	1.0	14x8	33.8	60	86	1.7	180	140	0.4	3.9	TRANE LSWF14	1-5
3-1-11	SMALL CONFERENCE 2015	670	200	200	1/2	277	26x40x11	0.31	8x9	23.4	64	96	0.75	180	140	0.5	1.7	TRANE LSWF08	1-5
3-1-15	SMALL CONFERENCE 2014	530	200	200	1/2	277	26x40x11	0.18	8x9	27.5	62.5	110	1.4	180	140	1.3	1.8	TRANE LSWF08	1-5
LEVEL 3 - ZONE 4																			
3-4-02	CONCESSIONS 2502	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-4-03	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-4-04	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-4-05	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-4-06	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-4-07	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
LEVEL 3 - ZONE 5																			
3-5-01	SECURITY SCREENING CHECKPOINT 2521	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-02	STERILE CORRIDOR 2525	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-03	MDP 2518 & ELECTRICAL CLOSET 2519	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-04	CONCESSION 2517	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-05	CONCESSION 2517	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-06	FOOD COURT 2516	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-07	CONCESSION 2514	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-08	WOMENS 2507 & MENS 2510	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-09	CORRIDOR 2504	1500	600	600	1	277	44x48x12	1.8	14x8	33.6	64.5	85	1.68	180	140	0.6	4	TRANE LSWF14	1-5
3-5-10	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-11	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-12	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-13	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-14	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-15	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-16	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
3-5-17	HOLDROOM	1750	600	600	1	277	44x48x12	2.0	14x8	39.1	64.5	85	1.95	180	140	0.6	4	TRANE LSWF14	1-5
LEVEL 4 - ZONE 5																			
4-5-01	SECURITY QUEUE 3503 & CIRCULATION 3500	1800	600	600	1	277	47x30x22	0.13	14x9	52.2	63	90	2.6	180	140	2.1	2.7	TRANE VSWF14	1-5
4-5-02	SECURITY QUEUE 3503 & CIRCULATION 3500	1800	600	600	1	277	47x30x22	0.13	14x9	52.2	63	90	2.6	180	140	2.1	2.7	TRANE VSWF14	1-5
4-5-03	SECURITY QUEUE 3503 & CIRCULATION 3500	1800	600	600	1	277	47x30x22	0.13	14x9	52.2	63	90	2.6	180	140	2.1	2.7	TRANE VSWF14	1-5
4-5-04	SECURITY QUEUE 3503 & CIRCULATION 3500	1800	600	600	1	277	47x30x22	0.13	14x9										