

**SHEET NOTES**

- 01 FURNISH AND INSTALL MULTIWALL BOILERWATER HEATER STACK
- 02 MOUNT DRUM LOUVER IN DUCT TAKEOFF ABOVE OPEN ARCHITECTURAL RETURN AIR PLENUM. MOUNT BOTTOM OF LOUVER FLUSH WITH TOP OF OUTER WALL. HOLD DUCT TAKEOFF AND LOUVER TIGHT TO MECHANICAL ROOM WALL TO CONCEAL DRUM LOUVER. PROVIDE GSM BLANK OFF AT TOP OF CHASE DIRECTLY IN FRONT OF LOUVER TO MAINTAIN AIRFLOW INTO CIRCULATION AREA.

**Portland International Jetport**

1001 Westbrook Street  
Portland, Maine 04102

**Gensler**  
2020 K Street, NW  
Suite 200  
Washington, DC 20006  
Telephone 202.721.5200  
Facsimile 202.872.8587

**oest ASSOCIATES, INC.**  
363 Galloway Road, South Portland, ME 04106 P (207) 741-1770 F (207) 774-2461 www.oest.com  
engineers • architects • surveyors • construction managers

**GENERAL NOTES**

- A SEE SHEET M00.00 FOR LEGEND AND GENERAL NOTES.
- B SUPPLY DUCTWORK SHALL BE SMACNA 10 INCH PRESSURE CLASS FROM AIR HANDLER OUTLET CONNECTIONS TO THE FAN POWERED VAV BOXES IN ALL AREAS AND TO THE SUPPLY REGISTERS AND GRILLES IN THE BAGGAGE HANDLING SPACE. RETURN DUCTWORK SHALL BE SMACNA 10 INCH PRESSURE CLASS FROM THE INLET OPENINGS TO THE AIR HANDLER CONNECTIONS.


Issue	Date & Issue Description	By	Check
01	07/11/08	PWZ	RHB
02	09/22/08	PWZ	RHB
03	12/03/08	PWZ	RHB
04	01/23/09	PWZ	RHB
05	10/26/09	PWZ	RHB

Seal/Signature

Project Name: PWM Terminal Enhancement  
Date: 10/26/09

Project Number: 09-6395-000  
CAD File Name: T:\6330\101\Sheets\M04.04.06.dwg  
Description: MECHANICAL DUCTWORK PLAN - LEVEL 4 - ZONE 6

**KEY PLAN**



Scale: 1/8" = 1'-0"

Ref. North

**M04.04.06**

©2009 Gensler

**MECHANICAL DUCTWORK PLAN - LEVEL 4 - ZONE 6**  
SCALE: 1/8" = 1'-0"