



**DUCTWORK SECTION - LEVEL 4 - ZONE 6**  
SCALE: 1/4" = 1'-0"

**1**

**SHEET NOTES**

01 FURNISH AND INSTALL (5) 18"x18" PRESSURE RELIEF DOORS EQUAL TO RUSKIN PRD18 ON 32" SIDE OF SUPPLY DUCT. FABRICATE AND INSTALL A 108"x24" BYPASS DUCT BETWEEN THE SUPPLY AND RETURN DUCTS AS SHOWN. DUCT SHALL BE RATED FOR 10" W.G. PRESSURE. FURNISH AND INSTALL (5) 18"x18" HIGH PRESSURE ACCESS DOORS ON THE BYPASS DUCT FOR ACCESS TO PRESSURE RELIEF DOORS.

**Portland International Jetport**

1001 Westbrook Street  
Portland, Maine 04102

**Gensler**

2020 K Street, NW  
Suite 200  
Washington, DC 20006  
Telephone 202.721.5200  
Facsimile 202.872.8587

**nest ASSOCIATES, INC.**  
363 Goshen Road, South Portland, ME 04106 P: (207) 741-1770 F: (207) 774-2461 www.nest.com  
engineers • architects • surveyors • construction managers

Issue	Date & Issue Description	By	Check
01	01/23/09 95% DESIGN DEVELOPMENT	PWZ	RHB
02	10/26/09 ISSUED FOR PERMIT	PWZ	RHB

**GENERAL NOTES**

A SEE SHEET M00.00 FOR LEGEND AND GENERAL NOTES.

\_\_\_\_\_  
Seal/Signature

Project Name: PWM Terminal Enhancement  
Project Number: 09-6395-000  
CAD File Name: T:\6330\101\Sheets\M09.02.dwg  
Description: MECHANICAL SECTIONS  
Scale: AS NOTED

**M09.02**