

SHEET NOTES

- 01 POWER FOR PTZ CAMERA. COORDINATE EXACT LOCATION WITH SECURITY CONTRACTOR.
- 02 ROLL DOWN SHUTTER. COORDINATE EXACT CONNECTION POINT WITH VENDOR.
- 03 PROVIDE GFCI TYPE RECEPTACLE IN THE ESCALATOR UPPER LEVEL MACHINE SPACE. COORDINATE LOCATION AND INSTALLATION WITH THE ESCALATOR CONTRACTOR.
- 04 CONNECT DISCONNECT SWITCH TO JUNCTION BOX/TERMINAL BOX PROVIDED BY THE ESCALATOR CONTRACTOR IN THE UPPER LEVEL MACHINE SPACE. COORDINATE LOCATION AND INSTALLATION WITH ESCALATOR CONTRACTOR.
- 05 REFER TO ONE-LINE DIAGRAM FOR NOTES ASSOCIATED WITH THIS PANELBOARD.
- 06 CONTRACTOR SHALL RUN 4-4" CONDUITS FROM THIS AREA TO AN AREA NEXT TO PANEL THA1. EXACT LOCATION OF STUB-UPS SHALL BE COORDINATED WITH TENANT.
- 07 CONTRACTOR SHALL EXTEND CONDUIT & WIRE OVERHEAD FOR EXISTING GATE 11 SIGN LOCATION TO NEW TEMPORARY SIGN LOCATION.
- 08 PROVIDE JUNCTION BOX MOUNTED TO CEILING OF LEVEL 2. PROVIDE TWO LENGTHS OF MC CABLE AS INDICATED AND CONNECT TO EAST & WEST SIDES OF JUNCTION BOX. LEAVE COILED FOR FUTURE CONNECTION TO HOLDROOM 2501 FURNITURE. WHERE TWO HOME RUNS ARE SHOWN TO A JUNCTION BOX, RUN BOTH CIRCUITS IN A SINGLE 3/4", WITH 4-#10 AWG & #10 GND. ONE CIRCUIT SHALL FEED MC CABLE TO THE EAST & OTHER TO THE WEST. LOCKOUT OR TAGOUT CIRCUIT BREAKER, OR USE ALTERNATIVE SAFE WIRING PROCEDURES UNTIL WIRING TO FURNITURE IS COMPLETED.
- 09 PROVIDE HUBBELL PEDESTAL STYLE FLOOR BOX #SC3098A WITH SINGLE RECEPTACLE PLATE #SS3095 AND SINGLE 20 AMP HEAVY DUTY RECEPTACLE #HBL8310, OR EQUAL FOR CONNECTION TO HOLD ROOM MODULAR FURNITURE. MOUNT DIRECTLY OVER EXISTING CORE DRILLED HOLE. UTILIZE EXISTING JUNCTION BOXES IN SECOND LEVEL CEILING FOR WIRING. REFERENCE SHEET NOTE #8
- 10 (2) 3" CONDUITS FROM TRANSCIEVER CABINETS ON FIRST LEVEL TO ROOF


GENERAL NOTES

- A SEE SHEET E00.00 FOR LEGEND AND GENERAL NOTES.
- B CONTRACTOR SHALL REFER TO FIRE ALARM, SECURITY, IT, AND PUBLIC ADDRESS SYSTEMS DRAWINGS FOR CONDUITS & WIRING REQUIREMENTS.

THESE DRAWINGS ARE ISSUED FOR CONSTRUCTION AND REFLECT ALL AMEC ISSUED BULLETINS AND SKETCHES.

Issue	Date & Issue Description	By	Check
01	07/11/08	LAM	BHG
02	09/22/08	LAM	BHG
03	12/03/08	LAM	BHG
04	01/23/09	LAM	BHG
05	10/28/09	LAM	BHG
06	11/02/09	LAM	BHG
02	07 11/12/09	LAM	BHG
03	08 11/20/09	LAM	BHG
06	09 01/15/10	PWZ	BHG
89	10 03/14/11	LAM	BHG
10	06/01/11	LAM	BHG
10	06/01/11	LAM	BHG

See Signature



Project Name
PWM Terminal Enhancement



Project Number
03-0395-000
CAD File Name
C:\AMEC\0330101\E02.03.04.dwg
Description
ELECTRICAL POWER PLAN - LEVEL 3 - ZONE 4

Scale
1/8" = 1'-0"

E02.03.04

©2009 Gensler

KEY PLAN



ELECTRICAL POWER PLAN - LEVEL 3 - ZONE 4

SCALE: 1/8" = 1'-0"