



**SHEET NOTES**

- 01 SEE ONE-LINE DIAGRAM ON SHEET E12.01 FOR CONDUIT & CONDUCTOR SIZES AS WELL AS DISCONNECTS & CONTROLLERS ASSOCIATED WITH THIS EQUIPMENT.
- 02 BRANCH CIRCUIT FOR LIGHTS & RECEPITS WITHIN AIR HANDLING UNITS ENCLOSURE. TWO CIRCUITS FOR NORMAL LIGHTING, ONE CIRCUIT FOR UV LIGHTING, AND ONE CIRCUIT FOR RECEPITACLES.

**Portland International Jetport**  
 1001 Westbrook Street  
 Portland, Maine 04102

**Gensler**  
 2020 K Street, NW  
 Suite 200  
 Washington, DC 20006  
 Telephone 202.771.5200  
 Facsimile 202.872.8587

**oest ASSOCIATES, INC.**  
 343 Gorham Road, South Portland, ME 04106  
 P: (207) 761-1770 F: (207) 774-1246 www.oest.com  
 engineers - architects - surveyors - construction managers

**amec**  
 343 Gorham Road, South Portland, ME 04106  
 P: (207) 761-1770 F: (207) 774-1246 www.amec.com

THESE DRAWINGS ARE ISSUED FOR CONSTRUCTION AND REFLECT ALL AMEC ISSUED BULLETINS AND SKETCHES.

Issue	Date & Issue Description	By	Check
01	9/22/08	LAM	BHG
02	12/03/08	LAM	BHG
03	01/23/09	LAM	BHG
04	10/26/09	LAM	BHG
05	11/02/09	LAM	BHG
24	05/21/10	LAM	BHG
15	09/01/11	LAM	BHG

**GENERAL NOTES**

- A SEE SHEET E00.00 FOR LEGEND AND GENERAL NOTES.
- B CONTRACTOR SHALL REFER TO FIRE ALARM, SECURITY, IT, AND PUBLIC ADDRESS SYSTEMS DRAWINGS FOR CONDUITS & WIRING REQUIREMENTS.

Project Name  
PJM Terminal Enhancement

Project Number  
09-0395-000

CAD File Name  
C:\AMEC\330101\E02.05.06.dwg

Description  
ELECTRICAL POWER PLAN - LEVEL 5 - ZONE 6

Scale  
1/8" = 1'-0"

Ref. North

**E02.05.06**

©2009 Gensler

**KEY PLAN**

