

- ### SHEET NOTES
- COORDINATE SPRINKLER LOCATION & PIPING WITH MECHANICAL DUCTWORK IN SAME CEILING BAY. FOLLOW OBSTRUCTION RULES OF NFPA 13.
 - SPRINKLER PIPING TO DROP TO CONCEALED PENDANT SPRINKLERS AT ACT CEILING LEVEL. ALSO SEE LEVEL 1 DRAWINGS.
 - UNIT HEATER - COORDINATE SPRINKLER TEMPERATURE RATINGS WITH THIS & ALL HEAT SOURCES PER NFPA 13(TYPICAL).

Portland International Jetport
 1001 Westbrook Street
 Portland, Maine 04102

2020 K Street, NW
 Suite 200
 Washington, DC 20006
 Telephone 202.721.5200
 Facsimile 202.872.8587

Gensler

oest ASSOCIATES, INC.
343 Gorham Road, South Portland, ME 04106 P: (207) 761-1770 F: (207) 774-1246 www.oest.com
 engineers • architects • surveyors • construction managers

amec
343 Gorham Road, South Portland ME 04106 P: (207) 761-1770 F: (207) 774-1246 www.amec.com

FIRE RISK MANAGEMENT, INC.
1 First Street
 Portland, ME 04106
 (207) 445-7208
 www.fire-risk.com

THESE DRAWINGS ARE ISSUED FOR CONSTRUCTION AND REFLECT ALL FRM ISSUED BULLETINS AND SKETCHES.

Issue	Date & Issue Description	By	Check
01	07/11/08	PWZ	RHB
02	09/22/08	SKD	WMC
03	12/03/08	SKD	WMC
04	01/23/09	MHY	JLD
05	10/26/09	JLD	SKD
06	11/12/09	RDV	SKD
07	05/03/10	RDV	SKD
08	03/09/11	SKD	JLD
09	09/01/11	SKD	JLD

GENERAL NOTES

A SEE SHEET FP00.01 FOR LEGEND, SCHEDULES & GENERAL NOTES.

Project Name
 P1W Terminal Enhancement

Project Number
 08.0395.000


CAD File Name
 FP04.02.05

Description
 FIRE PROTECTION PLAN - LEVEL 2 - ZONE 5

Scale
 1/8" = 1'-0"

FP04.02.05

C2009 Gensler



FIRE PROTECTION PLAN - LEVEL 2 - ZONE 5
 SCALE: 1/8"=1'-0"