


Item	Date
PERMIT	5-27-11



Burger King
 Portland Int'l Jetport PWM
 1001 Westbrook Street
 Portland ME 04102



HMS Host
 6905 Rockledge Drive
 Bethesda, MD 20817
 T: (240) 694-4746
 F: (240) 694-4643
 C: (240) 274-6417
 E: scott.seminski@hmshost.com

Building Engineering
 Resources, Inc.
 66 Main Street
 North Easton, MA 02356
 T: (508) 230-0200
 F: (508) 230-0265
 E: ber@ber-engineering.com



L2M Foodservice
 Design Group
 811 Cromwell Park Drive, Suite 113
 Glen Burnie, Maryland 21061
 T: (410) 863-1302
 F: (410) 863-1308
 E: FSDO@L2MFoodServiceDesign.com

LLOYD ARCHITECTS
 Two High Cliff, Plymouth MA 02360
 TEL: (508) 746-4646
 FAX: (508) 746-1236
 E-MAIL: info@lloydarch.com

Job No.:
 Scale: As noted
 Issued: 5-27-11


BURGER KING
 ELECTRICAL
 PLANS

E-2.01



1 BURGER KING LIGHTING PLAN
 1/4"=1'-0"

2 BURGER KING POWER PLAN
 1/4"=1'-0"



3 EXHAUST HOOD SHUT-DOWN DETAIL
 NOT TO SCALE

REFER TO FOOD SERVICE DRAWINGS FOR EXACT EQUIPMENT LAYOUTS, CONNECTION TYPES, AND DEVICE MOUNTING HEIGHTS

- NOTES:**
- ALL RECEPTACLES WITHIN KITCHEN, PREP SERVICE, BACK-BAR, AND SIMILAR AREAS SHALL BE GROUND FAULT CIRCUIT INTERRUPTER (GFCI) TYPE PER NEC ARTICLE 210.8(B)(2).
 - E.C. SHALL COORDINATE ALL FINAL POWER LOCATIONS AND MOUNTING HEIGHTS FOR KITCHEN EQUIPMENT WITH EQUIPMENT SHOP DRAWINGS AS PROVIDED BY TENANT'S VENDOR.
 - COLOR AND TYPE OF ALL DEVICES AND DEVICE PLATES SHALL BE APPROVED BY ARCHITECT PRIOR TO PURCHASE/INSTALLATION.
 - G.C. SHALL PROVIDE 3/4" CONDUIT WITH PULL STRING FROM EACH POS. TERMINAL AND REMOTE PRINTER LOCATION TO THE EXISTING SERVER ROOM ADJACENT TO THE EXISTING SHIPYARD BREWERY ON THE 2ND LEVEL. COORDINATE EXACT LOCATION IN FIELD.
 - COORDINATE EXACT REQUIREMENTS OF WALK-IN COOLER/FREEZER WITH EQUIPMENT SUPPLIER. E.C. SHALL BE RESPONSIBLE FOR ALL WIRING ASSOCIATED WITH COOLER/FREEZER EQUIPMENT AND INTERNAL PARTS AS NECESSARY.
 - ALL EQUIPMENT LOCATED UNDER HOOD SHALL BE WIRED THROUGH A N.C. CONTACTOR FOR AUTOMATIC SHUT-DOWN DURING AN ALARM CONDITION. SEE DETAIL THIS DRAWING.