



## ALL OTHER ELECTRICAL MATERIALS INCLUDING SWITCHES, CONTACTORS, AND RECEPTACLES, ETC. SHALL BE SUPPLIED & INSTALLED BY THE ELECTRICAL CONTRACTOR. ALL LIGHTING FIXTURES AND LAMPS IN THIS SCHEDULE SHALL BE SUPPLIED BY THE ELECTRICAL CONTRACTOR (EXCEPT AS NOTED) AND INSTALLED BY THE ELECTRICAL CONTRACTOR. MANUFACTURER AND CATALOG NUMBER LISTED ESTABLISHES THE MINIMUM LEVEL OF QUALITY ACCEPTABLE. ANY PROPOSED SUBSTITUTION MUST MEET OR EXCEED THIS LEVEL OF QUALITY, AS DETERMINED BY PAVLIK DESIGN TEAM, AND MUST BE SUBMITTED FOR PRIOR APPROVAL. SUBMITTALS MUST BE MADE VIA A BIDDING GENERAL CONTRACTOR WITH COMPLETE SPECIFICATION INFORMATION.

LIGHTING FIXTURE SUPPLIER SHALL FURNISH (4) COPIES OF THE LIGHTING FIXTURE CATALOG CUTS AND RECEIVE APPROVAL BY ELECTRICAL ENGINEER AND PAVLIK DESIGN TEAM PRIOR TO SUPPLYING FIXTURES. (3) APPROVED COPIES TO BE SUPPLIED TO CONTRACTOR FOR HIS USE.

DRAWING NAME:

2780

Power

 $\bigcirc$ 

Signal

THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLING ALL FIXTURES AND EMERGENCY LIGHTING TO MEET STATE AND LOCAL CODES.

ALL LIGHTING FIXTURES NOT DIMENSIONED ARE TO BE LOCATED IN THE CENTER OF CEILING TILE OR CEILING GRID AS SHOWN.

 $\dot{\Omega}$ 

LIGHTING FIXTURES AND CUT SHEETS SHALL BE CONSIDERED PART OF THE PLANS FOR BIDDING AND CONSTRUCTION PURPOSES.

ENERAL

**LIGHTING** 

NOTE

## **PRE-SECURITY VENDING SHOP**

THE

PARADIES

SHOPS

**Portland International Jetport 1001 Westbrook Street** Portland, Maine

SYMBOLS

DESCRIPTION

CEILING - DUPLEX RECEPTACLE

FLOOR - PHONE / DATA

CONTRACTOR TO VERIFY LOCATION OF ALL PHONE, ELECTRICAL, CABLE AND DATA WITH OWNER.

CONTRACTOR TO VERIFY NUMBER OF PHONE AND DATA RECEPTACLES AT EACH LOCATION WITH OWNER.

WALL - PHONE / DATA

GENERAL NOTES:

FLOOR BOX - POWER / DATA / PHONE

FLOOR - QUAD RECEPTACLE

FLOOR - DUPLEX RECEPTACLE

EXISTING RECEPTABI

DUPLEX RECEPTABLE

WALL - DUPLEX RECEPTACLE MOUNTED @ 18" A.F.F. UNLESS OTHERWISE NOTED

WALL - QUAD RECEPTACLE

GFCI RECEPTACLE

WALL MOUNTED PHONE

SMOKE DETECTOR

TO BE LOCATED BY FIRE SUPP MOUNTED. CONNECT TO BUILDI INDICATES WALL MOUNTED FIRE TO BE LOCATED BY FIRE SUPP BUILDING FIRE ALARM CIRCUIT.

LOAD (KVA)

LOAD (KVA)

LTG REC MTR A/C HTG 1

1.2

0.3

PANELBOARI

DATE 02.12.10 02.24.10