



STATE OF MAINE  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

JOHN ELIAS BALDACCI  
GOVERNOR

DAVID P. LITTELL  
COMMISSIONER

June 24, 2010

Portland International Airport  
1001 Westbrook Street  
Portland, ME. 04102  
Attn: Roy Williams

RE: Portland International Jetport

Dear Mr. Williams:

This letter is to acknowledge the Department's receipt of your registration materials on June 23, 2010 for either a new tank and piping or the replacement of ancillary equipment at Portland International Airport, Portland, Maine. Maine Statute dictates that the installation may take place ten (10) business days following Department notification (38 M.R.S.A., Section 563 1. A.). This installation may begin on June 29, 2010. Have a copy of your registration and display this letter in a prominent place during the construction or replacement activities.

**NOTE:** Please note it is the owners responsibility to ensure that the installer complete and submit the Certification of Proper Installation to the Department within thirty (30) days of completing the project (Chapter 691, Section 5 B. (4) (g).

If you have any questions or concerns, I can be reached at (207) 287- 2651.

Sincerely,

John M Dunlap  
Division of Oil and Hazardous Waste Facilities Regulation  
Bureau of Remediation and Waste Management

P.c. Arthur Grant # 021

AUGUSTA  
17 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0017  
(207) 287-7688 FAX: (207) 287-7826  
RAY BLDG., HOSPITAL ST.

BANGOR  
106 HOGAN ROAD  
BANGOR, MAINE 04401  
(207) 941-4570 FAX: (207) 941-4584

PORTLAND  
312 CANCO ROAD  
PORTLAND, MAINE 04103  
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE  
1235 CENTRAL DRIVE, SKYWAY PARK  
PRESQUE ISLE, MAINE 04769-2094  
(207) 764-0477 FAX: (207) 760-3143



STATE OF MAINE

Date of Certificate:

06/24/2010

DEPARTMENT OF ENVIRONMENTAL PROTECTION

FACILITY REGISTRATION CERTIFICATE FOR  
Above Ground and Underground Storage Tanks

Please display this certificate in a visible location at the registered facility.

Facility:

PORTLAND INTERNATIONAL JETPORT  
1001 WESTBROOK ST  
PORTLAND

Facility Registration Number:

6743

Date of Registration:

September 25, 1986

Facility Phone:

207-772-0690

Operator:

PORTLAND CITY OF  
1001 WESTBROOK ST  
PORTLAND  
ME 04102

207-772-0466

Sensitive Area Status:

Owner:

PORTLAND CITY OF  
1001 WESTBROOK ST  
PORTLAND  
ME 04102

207-772-0466

Facility Use:

Town "&" School

Above Ground and Underground Storage Tanks

Number of Active Aboveground Tanks: 1

Number of Active Underground Tanks: 1

If the information on this form is accurate and complete, please retain for your records.

The Maine Department of Environmental Protection must be notified of any errors or changes in the information on this form. To accomplish this, please draw a line through the incorrect or outdated information, insert the correct information, and return this form to:

Department of Environmental Protection Bureau of Remediation and Waste Management  
State House Station # 17 Augusta, ME 04333

Attn: Underground Tanks Program

If you have any questions concerning this process, please call (207)287-2651 and ask for the administrator of the Underground Storage Tanks program.

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 1    | Underground                 | Steel - bare or asphalt<br>coated. | 8000      | Unknown         | 01/01/1978             | Removed     | 09/11/1995          |

  

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 8000            | #2 Fuel Oil       | Underground                 | 01/01/1978        | Unknown            | Copper         | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 2    | Underground                 | Steel - bare or asphalt<br>coated. | 10000     | Unknown         | 01/01/1980             | Removed     | 11/01/1994          |

  

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 10000           | #2 Fuel Oil       | Underground                 | 01/01/1980        | Unknown            | Copper         | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 3    | Underground                 | Steel - bare or asphalt<br>coated. | 2000      | Unknown         | 01/01/1975             | Removed     | 09/01/1991          |

  

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 2000            | #2 Fuel Oil       | Underground                 | 01/01/1975        | Unknown            | Copper         | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 4    | Underground                 | Steel - bare or asphalt<br>coated. | 2000      | Unknown         | 01/01/1978             | Removed     | 12/05/1996          |

  

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 2000            | #2 Fuel Oil       | Underground                 | 01/01/1978        | Unknown            | Copper         | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring                       | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|---------------------------------------|------------------------|-------------|---------------------|
| 5    | Underground                 | Steel with cathodic<br>protection. | 6000      | SIA Statistical Inventory<br>Analysis | 11/01/1987             | Removed     | 10/07/1999          |

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring                    | Piping<br>Type                     | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|---------------------------------------|------------------------------------|------------------------|
| 1       | 6000            | Diesel            | Underground                 | 11/01/1987        | SIA Statistical Inventory<br>Analysis | Steel with cathodic<br>protection. | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring                       | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|---------------------------------------|------------------------|-------------|---------------------|
| 6    | Underground                 | Steel with cathodic<br>protection. | 4000      | SIA Statistical Inventory<br>Analysis | 11/01/1987             | Removed     | 10/07/1999          |

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring                    | Piping<br>Type                     | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|---------------------------------------|------------------------------------|------------------------|
| 1       | 4000            | Unleaded Gasoline | Underground                 | 11/01/1987        | SIA Statistical Inventory<br>Analysis | Steel with cathodic<br>protection. | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 7    | Underground                 | Steel - bare or asphalt<br>coated. | 5000      | Unknown         | 10/01/1969             | Removed     | 10/01/1987          |

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 5000            | Unknown Substance | Underground                 | 10/01/1969        | Unknown            | Other          | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank | Tank Under/<br>Above ground | Tank Type                          | Tank Size | Tank Monitoring | Date Tank<br>Installed | Tank Status | Tank Status<br>Date |
|------|-----------------------------|------------------------------------|-----------|-----------------|------------------------|-------------|---------------------|
| 8    | Underground                 | Steel - bare or asphalt<br>coated. | 4000      | Unknown         | 10/01/1969             | Removed     | 10/01/1987          |

| Chamber | Chamber<br>Size | Product<br>Stored | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring | Piping<br>Type | Overfill<br>Protection |
|---------|-----------------|-------------------|-----------------------------|-------------------|--------------------|----------------|------------------------|
| 1       | 4000            | Diesel            | Underground                 | 10/01/1969        | Unknown            | Other          | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank    | Tank Under/<br>Above ground | Tank Type                          | Tank Size                   | Tank Monitoring   | Date Tank<br>Installed | Tank Status    | Tank Status<br>Date    |
|---------|-----------------------------|------------------------------------|-----------------------------|-------------------|------------------------|----------------|------------------------|
| 9       | Underground                 | Steel - bare or asphalt<br>coated. | 4000                        | Unknown           | 10/01/1969             | Removed        | 10/01/1987             |
| Chamber | Chamber<br>Size             | Product<br>Stored                  | Pipe Under/<br>Above ground | Date<br>Installed | Pipe<br>Monitoring     | Piping<br>Type | Overfill<br>Protection |
| 1       | 4000                        | Diesel                             | Underground                 | 10/01/1969        | Unknown                | Other          | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank    | Tank Under/<br>Above ground | Tank Type                                  | Tank Size                   | Tank Monitoring                          | Date Tank<br>Installed                   | Tank Status               | Tank Status<br>Date    |
|---------|-----------------------------|--|-----------------------------|--|--|---------------------------|------------------------|
| 10      | Underground                 | F/glass - sec contain -<br>petro & alcohol | 10000                       | Secondary Containment /<br>Cont Elec Mon | 10/20/1995                               | Active                    | 10/20/1995             |
| Chamber | Chamber<br>Size             | Product<br>Stored                          | Pipe Under/<br>Above ground | Date<br>Installed                        | Pipe<br>Monitoring                       | Piping<br>Type            | Overfill<br>Protection |
| 1       | 10000                       | #2 Fuel Oil                                | Underground                 | 04/06/2006                               | Secondary Containment<br>/ Cont Elec Mon | Flexible<br>double-walled | Electronic             |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank    | Tank Under/<br>Above ground | Tank Type                            | Tank Size                   | Tank Monitoring                          | Date Tank<br>Installed                   | Tank Status               | Tank Status<br>Date    |
|---------|-----------------------------|--------------------------------------|-----------------------------|--|--|---------------------------|------------------------|
| 11      | Aboveground                 | Steel with secondary<br>containment. | 10000                       | Secondary Containment /<br>Cont Elec Mon | 11/01/1999                               | Active<br>In Service      | 12/12/2006             |
| Chamber | Chamber<br>Size             | Product<br>Stored                    | Pipe Under/<br>Above ground | Date<br>Installed                        | Pipe<br>Monitoring                       | Piping<br>Type            | Overfill<br>Protection |
| 1       | 4000                        | Unleaded Gasoline                    | Underground                 | 11/01/1999                               | Secondary Containment<br>/ Cont Elec Mon | Flexible<br>double-walled | Unknown                |
| 2       | 6000                        | Diesel                               | Underground                 | 11/01/1999                               | Secondary Containment<br>/ Cont Elec Mon | Flexible<br>double-walled | Unknown                |

**INDIVIDUAL TANK DATA FOR SITE NUMBER: 6743**

| Tank    | Tank Under/<br>Above ground | Tank Type                                 | Tank Size                   | Tank Monitoring                          | Date Tank<br>Installed                   | Tank Status                 | Tank Status<br>Date    |
|---------|-----------------------------|---|-----------------------------|--|--|-----------------------------|------------------------|
| 12      | Underground                 | F/glass - sec containment -<br>petro only | 12000                       | Secondary Containment /<br>Cont Elec Mon | 06/23/2010                               | planned for<br>installation | 06/23/2010             |
| Chamber | Chamber<br>Size             | Product<br>Stored                         | Pipe Under/<br>Above ground | Date<br>Installed                        | Pipe<br>Monitoring                       | Piping<br>Type              | Overfill<br>Protection |
| 1       | 12000                       | #2 Fuel Oil                               | Underground                 | 06/23/2010                               | Secondary Containment<br>/ Cont Elec Mon | Flexible<br>double-walled   | Drop Tube              |