

SECTION 08110 - STEEL DOORS AND FRAMES

PART 1 - GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. This Section includes the following:
 - 1. Steel doors
 - 2. Steel frames
- B. Related Sections include the following:
 - 1. Division 4 Section "Unit Masonry Assemblies" for building anchors into and grouting steel frames in masonry construction.
 - 2. Division 8 Section "Glazing" for glazed lites in steel doors and frames.
 - 3. Division 8 Sections for door hardware and weatherstripping for steel doors.
 - 4. Division 9 painting Sections for field painting steel doors and frames.
 - 5. Division 16 for electrical service and connections of electrified door hardware and controls.

1.03 DEFINITIONS

- A. Minimum Steel Sheet Thickness: Minimum thickness of base metal without coatings.

1.04 SUBMITTALS

- A. General: Submit in accordance with Section 01300.
 - 1. Submittals for Sections 08110 and 08710 shall be made concurrently.
- B. Product Data: Include door designation, type, level and model, construction details, material descriptions, core descriptions, label compliance, fire-resistance rating, and finishes for each type of hollow-metal door and frame specified.
- C. Shop Drawings: In addition to requirements below, provide a schedule of steel doors and frames using same reference numbers for details and openings as those on Drawings:
 - 1. Elevations of each door design.
 - 2. Details of doors, including vertical and horizontal edge details.
 - 3. Frame details for each frame type, including dimensioned profiles.
 - 4. Details and locations of reinforcement and preparations for hardware.
 - 5. Details of each different wall opening condition.
 - 6. Details of anchorages, accessories, joints, and connections.
 - 7. Details of glazing frames and stops showing glazing.
 - 8. Details of conduit and preparations for electrified door hardware and controls.
- D. Door Schedule: Use same reference designations indicated on Drawings in preparing schedule for doors and frames.
- E. Product Test Reports: Based on evaluation of comprehensive fire tests performed by a qualified testing agency, for each type of steel door and frame.
- F. Material Certificates: Signed by manufacturers certifying that each fire-rated door complies with requirements.

1.05 QUALITY ASSURANCE

- A. Source Limitations: Obtain steel doors and frames through one source from a single manufacturer.
- B. Fire-Rated Door, Sidelight and Transom Frame Assemblies: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire-protection ratings indicated.
 - 1. Test Pressure: Test at atmospheric (neutral) pressure according to NFPA 252 or UL 10B.
- C. Smoke-Control Door Assemblies: Comply with NFPA 105 or UL 1784.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver doors and frames palletized, wrapped, or crated to provide protection during transit and Project-site storage. Do not use non-vented plastic.
- B. Deliver welded frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
- C. Inspect doors and frames on delivery for damage; notify shipper and supplier if damage is found. Minor damages may be repaired provided refinished items match new work and are acceptable to Architect. Remove and replace damaged items that cannot be repaired as directed.
- D. Store doors and frames under cover at Project site. Place units in a vertical position with heads up, spaced by blocking, on minimum 4-inch- high wood blocking. Avoid using non-vented plastic or canvas shelters that could create a humidity chamber.
 - 1. If wrappers on doors become wet, remove cartons immediately. Provide minimum 1/4-inch space between each stacked door to permit air circulation.

1.07 COORDINATION

- A. Coordinate installation of anchorages for steel frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in masonry. Deliver such items to Project site in time for installation.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Ceco Door Products; a United Dominion Company.
 - 2. CURRIES Company; an ASSA ABLOY Group Company.
 - 3. Steelcraft; an Ingersoll-Rand Company.

2.02 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B; suitable for exposed applications.
- B. Hot-Rolled Steel Sheet: ASTM A 101 I/A 1011M, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with minimum A40 zinc-iron-alloy (galvannealed) coating designation.
- D. Supports and Anchors: After fabricating, galvanize units to be built into exterior walls according to ASTM A 153/A 153M, Class B.
- E. Inserts, Bolts, and Fasteners: Provide items to be built into exterior walls, hot-dip galvanized according to ASTM A 153/A 153M.
- F. Powder-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching standard steel door frames of type indicated.
- G. Grout: Comply with Division 4 Section "Unit Masonry Assemblies."
- H. Mineral-Fiber Insulation: ASTM C 665, Type I (blankets without membrane facing); consisting of fibers manufactured from slag or rock wool with 6- to 12-lb/cu. ft. density; with maximum flame-spread and smoke-developed indexes of 25 and 50 respectively; passing ASTM E 136 for combustion characteristics.
- I. Glazing: Comply with requirements in Division 8 Section "Glazing."
- J. Bituminous Coating: Cold-applied asphalt mastic, SSPC-Paint 12, compounded for 15-mil dry film thickness per coat. Provide inert-type non-corrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.

2.03 STEEL DOORS

- A. General: Provide doors of design indicated, not less than thickness indicated; fabricated with smooth surfaces, without visible joints or seams on exposed faces, unless otherwise indicated. Comply with ANSI A250.8, unless more stringent requirements are specified.
 - 1. Design: Flush panel.
 - 2. Core Construction: Manufacturer's standard kraft-paper honeycomb, polystyrene, polyurethane, mineral-board with internal sound deadener on inside of face sheets, or vertical steel-stiffener core that produces doors complying with ANSI A250.8.
 - a. Fire Door Core: As required to provide fire-protection ratings indicated.

- E. Floor Anchors: Formed from same material as frames, not less than 0.042 inch thick (18 gage), and as follows:
 1. Monolithic Concrete Slabs: Clip-type anchors, with two holes to receive fasteners.
- F. Fabricate concealed stiffeners and hardware reinforcement from either cold- or hot-rolled steel sheet.
- G. Plaster Guards: Formed from same material as frames, not less than 0.016-inch thick (28 gage) steel sheet to close off interior of openings; place at back of hardware cutouts where mortar or other materials might obstruct hardware operation.

2.05 STOPS AND MOLDINGS

- A. Moldings for Glazed Lites in Doors: Minimum 0.012 inch thick (20 gage), fabricated from same material as door face sheet in which they are installed.
 1. Provide non-removable stops on outside of exterior doors and on secure side of interior doors for glass, louvers, and other panels in doors.
 2. Provide screw-applied, removable, glazing stops on inside of glass, louvers, and other panels in doors.
- B. Fixed Frame Moldings: Formed integral with steel frames, minimum 5/8 inch high, unless otherwise indicated.
- C. Loose Stops for Glazed Lites in Frames: Minimum 0.032 inch thick (20 gage), fabricated from same material as frames in which they are installed.
- D. Astragals: As required by NFPA 80 to provide fire ratings indicated.

2.06 FABRICATION

- A. General: Fabricate steel doors and frames to be rigid and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for thickness of metal. Where practical, fit and assemble units in manufacturer's plant. To ensure proper assembly at Project site, clearly identify work that cannot be permanently factory assembled before shipment.
- B. Steel Doors:
 1. Exterior Doors: For exterior locations and elsewhere as indicated, fabricate doors, panels, and frames from metallic-coated steel sheet. Close top and bottom edges of doors flush as an integral part of door construction or by addition of 0.053-inch-thick (16 gage), metallic-coated steel channels with channel webs placed even with top and bottom edges. Seal joints in top edges of doors against water penetration.
 2. Interior Door and Panel Faces: Fabricate exposed faces of doors and panels, including stiles and rails of non flush units, from cold-rolled steel sheet, unless otherwise indicated.
 3. Glazed Lites: Factory cut openings in doors.
- C. Steel Frames: Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of same thickness metal as frames.
 1. Welded Frames: Weld flush face joints continuously; grind, fill, dress, and make smooth, flush, and invisible.
 2. Sidelight and Transom Bar Frames: Provide closed tubular members with no visible face seams or joints; fabricated from same material as door frame. Fasten members at crossings and to jambs by butt welding; grind smooth and invisible.

3. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners, unless otherwise indicated.
 4. Plaster Guards: Weld guards to frame at back of hardware mortises in frames installed in concrete or masonry.
 5. Where installed in masonry, leave vertical mullions in frames open at top for grouting.
 6. Floor Anchors: Weld anchors to bottom of jambs and mullions with at least four spot welds per anchor. Provide floor anchors for all frames.
 7. Jamb Anchors: Locate anchors not more than 18 inches from top and bottom of frame. Space anchors not more than 32 inches o.c. and as follows:
 - a. Masonry Type:
 - 1) Two anchors per jamb up to 60 inches in height.
 - 2) Three anchors per jamb from 60 to 90 inches in height.
 - 3) Four anchors per jamb from 90 to 120 inches in height.
 - 4) Four anchors per jamb plus 1 additional anchor per jamb for each 24 inches or fraction thereof more than 120 inches in height.
 - b. Stud-Wall Type:
 - 1) Three anchors per jamb up to 60 inches in height.
 - 2) Four anchors per jamb from 60 to 90 inches in height.
 - 3) Five anchors per jamb from 90 to 96 inches in height.
 - 4) Five anchors per jamb plus 1 additional anchor per jamb for each 24 inches or fraction thereof more than 96 inches in height.
 - 5) Two anchors per head for frames more than 42 inches wide and mounted in metal-stud partitions.
 8. Door Silencers: Except on weather-stripped doors, drill stops to receive door silencers as follows. Provide plastic plugs to keep holes clear during construction.
 - a. Single-Door Frames: Drill stop in strike jamb to receive three door silencers.
 - b. Double-Door Frames: Drill stop in head jamb to receive two door silencers.
 9. Provide welded frames with temporary spreader bars for shipping.
- D. Hardware Preparation: Factory prepare standard steel doors and frames to receive templated mortised hardware; include cutouts, reinforcement, mortising, drilling, and tapping, according to the Door Hardware Schedule and templates furnished as specified in Division 8 Section "Door Hardware."
1. Reinforce doors and frames to receive non-templated mortised and surface-mounted door hardware. Through bolting will not be acceptable.
 2. Comply with applicable requirements in ANSI A250.6 and ANSI/DHI A1 15 Series specifications for door and frame preparation for hardware. Locate hardware as indicated on Shop Drawings or, if not indicated, according to ANSI A250.8.
- E. Stops and Moldings: Provide stops and moldings around glazed lites where indicated. Form corners of stops and moldings with butted or mitered hairline joints.
1. Single Glazed Lites: Provide fixed stops and moldings welded on secure side of door or frame.
 2. Multiple Glazed Lites: Provide fixed and removable stops and moldings such that each glazed lite is capable of being removed independently.
 3. Provide fixed frame moldings on outside of exterior and on secure side of interior doors and frames.
 4. Provide loose stops and moldings on inside of doors and frames.
 5. Coordinate rabbet width between fixed and removable stops with type of glazing and type of installation indicated.
- F. Astragals: As required by NFPA 80 to provide fire ratings indicated.

2.07 STEEL FINISHES

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
 - I. Apply primers to steel doors and frames after assembly.
- B. Comply with SSPC-PA1, "Paint Application Specification No. 1," for steel sheet finishes.
- C. Metallic-Coated Steel Surface Preparation: Clean surfaces with non-petroleum solvent so surfaces are free of oil and other contaminants. After cleaning, apply a conversion coating suited to the organic coating to be applied over it. Clean welds, mechanical connections, and abraded areas, and apply galvanizing repair paint specified below to comply with ASTM A 780.
 - 1. Galvanizing Repair Paint: High-zinc-dust-content paint for re-galvanizing welds in steel, complying with SSPC-Paint 20.
- D. Steel Surface Preparation: Clean surfaces to comply with SSPC-SP 1, "Solvent Cleaning"; remove dirt, oil, grease, or other contaminants that could impair paint bond. Remove mill scale and rust, if present, from uncoated steel; comply with SSPC-SP 3, "Power Tool Cleaning," or SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning."
- E. Factory Priming for Field-Painted Finish: Apply shop primer specified below immediately after surface preparation and pretreatment. Apply a smooth coat of even consistency to provide a uniform dry film thickness of not less than 0.7 mils.
 - 1. Shop Primer: Manufacturer's standard, fast-curing, lead- and chromate-free primer complying with ANSI A250.10 acceptance criteria; recommended by primer manufacturer for substrate; compatible with substrate and field-applied finish paint system indicated; and providing a sound foundation for field-applied topcoats despite prolonged exposure.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of steel doors and frames.
 - 1. Examine roughing-in for embedded and built-in anchors to verify actual locations of steel frame connections before frame installation.
 - 2. If unacceptable conditions are encountered, prepare written report, endorsed by Installer, listing conditions detrimental to performance of work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Remove welded-in shipping spreaders installed at factory.
- B. Paint backside of frames to be set in masonry with bituminous coating.
- C. Prior to installation, adjust and securely brace steel door frames for squareness, alignment, twist, and plumb to the following tolerances:
 - 1. Squareness: Plus or minus 1/16 inch, measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
 - 2. Alignment: Plus or minus 1/16 inch, measured at jambs on a horizontal line parallel to plane of wall.
 - 3. Twist: Plus or minus 1/16 inch, measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
 - 4. Plumbness: Plus or minus 1/16 inch, measured at jambs on a perpendicular line from head to floor.
- D. Drill and tap doors and frames to receive non-templated mortised and surface-mounted door hardware.

3.03 INSTALLATION

- A. General: Provide doors and frames of sizes, thicknesses, and designs indicated. Install steel doors and frames plumb, rigid, properly aligned, and securely fastened in place; comply with Drawings and manufacturer's written instructions.
- B. Steel Frames: Install standard steel frames for doors, sidelights, transoms borrowed lights, and other openings, of size and profile indicated. Comply with SDI 105.
 - 1. Set frames accurately in position; plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces, leaving surfaces smooth and undamaged.
 - a. At fire-protection-rated openings, install frames according to NFPA 80.
 - b. Where frames are fabricated in sections due to shipping or handling limitations, field splice at approved locations by welding face joint continuously; grind, fill, dress, and make splice smooth, flush, and invisible on exposed faces.
 - c. Install frames with removable glazing stops located on secure side of opening.
 - d. Install door silencers in frames before grouting.

- e. Remove shipping straps at bottom of frames. Properly space frame using wood template that is full depth of frame and of proper spacing width during setting and anchoring of frames to maintain proper width, with frame plumb and square without twists. Remove temporary braces necessary for installation only after frames have been properly set and secured.
 - f. Check plumb, squareness, and twist of frames as walls are constructed. Shim as necessary to comply with installation tolerances.
 - g. Apply bituminous coating to backs of frames that are filled with mortar, grout, and plaster.
2. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor and secure with post installed expansion anchors. Floor anchors are in addition to wall anchors.
 - a. Floor anchors may be set with powder-actuated fasteners instead of post installed expansion anchors if so indicated and approved on Shop Drawings.
 3. Metal-Stud Partitions: Attach wall anchors to studs with screws. Provide floor anchor at each jamb, in addition to the wall anchors.
 4. Masonry Walls: Anchors shall be masonry T-shaped anchors. Provide floor anchor at each jamb, in addition to the wall anchors. Coordinate installation of frames to allow for solidly filling space between frames and masonry with mortar as specified in Division 4 Section "Unit Masonry Assemblies."
 5. Installation Tolerances: Adjust steel door frames for squareness, alignment, twist, and plumb to the following tolerances:
 - a. Squareness: Plus or minus 1/16 inch, measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
 - b. Alignment: Plus or minus 1/16 inch, measured at jambs on a horizontal line parallel to plane of wall.
 - c. Twist: Plus or minus 1/16 inch, measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
 - d. Plumbness: Plus or minus 1/16 inch, measured at jambs at floor.
 6. Mineral Fiber Insulation: Fill head and jambs of frames scheduled to receive sound seals with mineral fiber insulation.
- C. Steel Doors: Fit hollow-metal doors accurately in frames, within clearances specified below. Shim as necessary.
1. Non-Fire-Rated Steel Doors:
 - a. Jambs and Head: 1/8 inch plus or minus 1/16 inch.
 - b. Between Edges of Pairs of Doors: 1/8 inch plus or minus 1/16 inch.
 - c. Between Bottom of Door and Top of Threshold: Maximum 3/8 inch.
 - d. Between Bottom of Door and Top of Finish Floor (No Threshold): Maximum 3/4 inch.
 2. Fire-Rated Doors: Install doors with clearances according to NFPA 80.
 3. Smoke-Control Doors: Install doors according to NFPA 105.
- D. Glazing: Comply with installation requirements in Division 8 Section "Glazing" and with steel door and frame manufacturer's written instructions.
1. Secure stops with countersunk flat- or oval-head machine screws spaced uniformly not more than 9 inches o.c, and not more than 2 inches o.c. from each corner.

3.04 ADJUSTING AND CLEANING

- A. Final Adjustments: Remove and replace defective work, including steel doors or frames that are warped, bowed, or otherwise unacceptable.
- B. Clean grout and other bonding material off steel doors and frames immediately after installation.
- C. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying primer.

END OF SECTION