

NOTES:

1. SEE SHEET 2.E-001 FOR LEGEND AND GENERAL NOTES.

REMOVE EXISTING COVE LIGHT TO THE EXTENT REQUIRED TO ALLOW CEILING REMOVAL AND INSTALLATION OF NEW ELEVATORS.

RELOCATE SECURITY CAMERA AT LOCATION TO BE DETERMINED BY OWNER. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW LOCATION. COORDINATE ALL WORK WITH OWNER.

EXISTING SPEAKER AND HEAT DETECTOR TO BE RELOCATED TO NEW LOCATIONS SHOWN ON

REMOVE EXISTING RECEPTACLES AND RE-USE BRANCH CIRCUIT THAT CURRENTLY FEEDS

SHOWN ON 2.EP101.

RECEPTACLES TO FEED NEW RECEPTACLES

EXISTING FIRE ALARM NOTIFICATION STROBE AND SPEAKER TO BE REMOVED TO ALLOW FOR

DISCONNECT POWER FOR EXISTING ESCALATOR AND REMOVE EMO SWITCHES, ALL CONDUIT AND WIRING BACK TO SOURCE.

RE-ROUTE FIVE 1" CONDUITS, TWO 2" CONDUITS
AND FOUR 3/4" CONDUITS TO ALLOW INSTALLATION
OF NEW ELEVATORS. FIELD VERIFY QUAINTLY AND
TYPE OF WIRES IN EACH CONDUIT.

REMOVAL OF WALL FINISHES AND RE-INSTALLED AFTER NEW FINISHES ARE INSTALLED.

2.EY101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATIONS.

 UTILIZE EXISTING LIGHTING BRANCH CIRCUIT THAT CURRENTLY FEEDS LIGHTS TO FEED NEW LIGHTS SHOWN ON 2.EL101.

KEYED NOTES:

NOT FOR CONSTRUCTION

ECTURE 144 Fore Street/P.O. Box 618

ERING

tel. (207) 772-3846

fax. (207) 772-1070

www.smrtinc.com

S NO PROJECT NG PLANNING INTERIORS ENERGY ENERGY

REV: BY: DATE: STATUS:
THIS PLAN SHALL NOT BE MODIFIED WITHOUT WRITTEN PERMISSION FROM SEBAGITECHNICS, INC. ANY ALTERATIONS, AUTHORIZED OR OTHERWISE, SHALL BE AT THE USER'S SOLE RISK AND WITHOUT LOSEBAGO TECHNICS. INC.

South Portland, ME 04106
Tel. 207-200-2100
Tel. 207-200-2100
Tel. 207-200-2100
Tel. 207-200-2100
Tel. 207-200-2100
Tel. 207-200-2100
Tel. 207-303-5656
Tel. 207-783-5656

1ST FLOOR - DEMOLITION PLAN

OF:
PORTLAND INTERNATIONAL JETPORT
VERTICAL CIRCULATION IMPROVEMENTS
1001 WESTBROOK STREET
PORTLAND, MAINE 04102

PROJECT NORTH:

DATE SCALE

10-27-17 1/8" = 1'-0"

2.ED101