


1 LIGHTING PLAN - 1ST FLOOR
1/8" = 1'-0"



NOTES:

- SEE SHEET 2.E-001 FOR LEGEND AND GENERAL NOTES.

KEYED NOTES:

- UTILIZE EXISTING BRANCH CIRCUIT TO FEED NEW LIGHTS THAT CURRENTLY FEEDS LIGHTS SHOWN TO BE REMOVED ON 2.ED101. PROVIDE NEW OCCUPANCY SENSORS FOR CONTROL OF LIGHTS.
- MOUNT NEW LIGHTS AND SWITCHES IN PIT OF ELEVATOR HOISTWAY. COORDINATE EXACT MOUNTING LOCATIONS WITH ELEVATOR INSTALLER.

NOT FOR CONSTRUCTION

ARCHITECTURE 144 Fore Street P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070
www.smrtinc.com

ENGINEERING INTERIORS ENERGY

SMRT PROJECT NO. 17033

PROJECT MGR. JCDRAWN A/E OF RECORD
DRL CDS DJT

REV.	BY:	DATE:	ISSUED FOR PERMIT
		12/21/17	STATUS:
THIS PLAN SHALL NOT BE MODIFIED WITHOUT WRITTEN PERMISSION FROM SEBAGO TECHNICS, INC. ALL BE AT THE USER'S SOLE RISK AND WITHOUT LIABILITY TO SEBAGO TECHNICS, INC.			

SEBAGO TECHNICS

WWW.SEBAGOTECHNICS.COM
75 John Roberts Rd., Suite 1A 250 Goddard Rd., Suite B
Scarborough, ME 04107 Tel. 207.200.2100 Tel. 207.783.6666

PROJECT NO. | FIELD BOOK | DESIGN | CHKD | DRAWN

1ST FLOOR - LIGHTING PLAN
OF:
PORTLAND INTERNATIONAL JETPORT
VERTICAL CIRCULATION IMPROVEMENTS
1001 WESTBROOK STREET
PORTLAND, MAINE 04102

DATE	SCALE
10-27-17	1/8" = 1'-0"

2.EL101