



**SITE WORK
DAILY FIELD REPORT**

PROJECT: Terminal Enhancement at the Portland International Jetport

DATE: 6/13/2011

PROJECT LOCATION: Portland, Maine

PROJECT NO.: 0557-014

CLIENT: City of Portland

WEATHER: partly cloudy, warm

CONTRACTOR: Turner Construction Co.

PREVIOUS DATE ON SITE: 6/10/2011

Time on-site: 1.5 hrs, 28 mi travel, Tolls: \$0.00

Picked up cylinders made 10 June 2011.

MJK

Michael J Kramlich

Prepared By

MTC

Matthew Grady

Reviewed By

R. W. Gillespie & Associates 86 industrial Park Rd., Suite 4, Saco, ME 04072- (207)286-8008



**SITE WORK
DAILY FIELD REPORT**

PROJECT: Terminal Enhancement at the Portland International Jetport

DATE: 6/15/2011

PROJECT LOCATION: Portland, Maine

PROJECT NO.: 0557-014

CLIENT: City of Portland

WEATHER: partly cloudy, warm

CONTRACTOR: Turner Construction Co.

PREVIOUS DATE ON SITE: 6/13/2011

Time on-site: 4.5 hrs, 28 mi travel, Tolls: \$0.00

Approximately 26 yd. concrete placed in 180' of sidewalk. 1st load when sampled had a slump of 6.5". Shaun Winner of TCCO and Lacey Fogg of AMEC notified. Water was added to 1st truck after sampling against recommendation. New slump of 7" recorded. Truck sent away by Shaun Winner after finishing current panel. Lacey Fogg also notified. 1 set of cylinders made.

MSK

Michael J Kramlich

Prepared By

MTC

Matthew Grady

Reviewed By

R. W. Gillespie & Associates 86 industrial Park Rd., Suite 4, Saco, ME 04072- (207)286-8008



**SITE WORK
DAILY FIELD REPORT**

PROJECT: Terminal Enhancement at the Portland International Jetport

DATE: 6/16/2011

PROJECT LOCATION: Portland, Maine

PROJECT NO.: 0557-014

CLIENT: City of Portland

WEATHER: partly cloudy, warm

CONTRACTOR: Turner Construction Co.

PREVIOUS DATE ON SITE: 6/15/2011

Time on-site: 1.25 hrs, 28 mi travel, Tolls: \$0.00

Picked up cylinders made 15 June 2011.

MJK

Michael J Kramlich

Prepared By

MTG

Matthew Grady

Reviewed By

R. W. Gillespie & Associates 86 industrial Park Rd., Suite 4, Saco, ME 04072- (207)286-8008