



**SHEET NOTES**

- 01 REFER TO ENGINEERING DRAWINGS, E02.SERIES FOR ADDITIONAL INFORMATION
- 02 ALL OUTLET LOCATIONS TO BE LAID OUT PER APPROVED TSA LANE CONFIGURATIONS. CONFIRM OUTLET TYPES PER APPROVED TSA EQUIPMENT. TYPICAL AT ALL TSA AREAS.
- 03 COORDINATE POWER REQUIREMENTS AND LOCATIONS WITH SECURITY, IT AND FIRE ALARM EQUIPMENT. RE: ENGINEERING DRAWINGS, SS, TC AND FA SERIES FOR ADDITIONAL INFORMATION
- 04 COORDINATE POWER REQUIREMENTS AND LOCATIONS WITH SECURITY, IT AND FIRE ALARM EQUIPMENT. RE: ENGINEERING DRAWINGS, SS, TC AND FA SERIES FOR ADDITIONAL INFORMATION
- 05 REFER TO ENGINEERING DRAWINGS FOR POWER AND LIGHTNING PROTECTION REQUIREMENT ON ALL ROOF LEVELS.
- 06 WALKER DUCT, RE: ELECTRICAL DRAWINGS FOR ADDITIONAL INFORMATION.
- 07 SURFACE MOUNTED
- 08 COORDINATE EXACT LOCATION AND POWER REQUIREMENTS. PLACE STUB UP WITHIN PYLONMILLWORK. REFER TO DETAIL SHEET XX.XX
- 09 RECEPTACLES TO BE TERMINATED ABOVE FINISHED CEILING AND NOT VISIBLE TO THE PUBLIC. COORDINATE MOUNTING OF CPU. REFER TO TC.02 SERIES FOR ADDITIONAL INFORMATION
- 11 COORDINATE IN-WALL AND UNDERSLAB ROUTING FROM ELEC. CLOSET 3516 TO WALKER DUCT. ROUTING SHOWN FOR DIAGRAMMATICAL PURPOSES ONLY. DO NOT RUN CONDUIT IN-SLAB, RADIANT FLOORING INSTALLATION IN THIS AREA.

Portland International Jetport  
 1001 Westbrook Street  
 Portland, Maine 04102

**Gensler**  
 2020 K Street, Northwest  
 Suite 200  
 Washington DC 20006  
 Telephone 202.721.5200  
 Facsimile 202.872.8587

**GENERAL NOTES**

- A COORDINATE ALL WALL MOUNTED DEVICES WITH ASSOCIATED PARTITION TYPES AND FIRE RATING REQUIREMENTS. SEE ALIGNMENT LOCATIONS OF DEVICES ON SHEET A00.13.
- B COORDINATE ALL CEILING MOUNTED DEVICES WITH ASSOCIATED CEILING TYPES, LIGHT FIXTURE AND EQUIPMENT DEPTHS AND ALL REQUIRED SYSTEMS CLEARANCES.
- C REFER TO EQUIPMENT SCHEDULE IN PROJECT MANUAL SECTION APPENDIX 'A'.
- D REFER TO ELECTRICAL DRAWINGS FOR OUTLET TYPES.
- E REFER TO ELECTRICAL, FIRE ALARM, IT AND SECURITY DRAWINGS, PROJECT MANUAL FOR ADDITIONAL INFORMATION.
- F REFER TO MANUFACTURER AND LOCAL CODE REQUIREMENTS FOR ELEVATOR AND ESCALATOR INSTALLATIONS.
- G REFER TO ELECTRICAL DRAWINGS FOR GFI OUTLET LOCATIONS.
- H PROVIDE ELECTRICAL ROUTING AND IT STUB-UP AT TICKET COUNTERS. 1 SET OF STUB UP FOR EVERY 4 COUNTERS. REFER TO ELECTRICAL AND IT DRAWINGS FOR CABLE AND CIRCUIT INFORMATION. SIZE STUB UP ACCORDINGLY.
- I PROVIDE WEATHER PROOF DEVICES AT LOCATIONS WHERE REQUIRED.
- J COORDINATE POWER/DATA ROUTING REQUIREMENTS WITH DOOR HARDWARE. RELAY TIE IN WITH FIRE ALARM SYSTEM AS INDICATED OR REQUIRED BY CODE. ALSO REFER TO SECURITY DRAWINGS.
- K REFER TO PARTITION TYPES FOR ADDITIONAL INFORMATION ON FIRE RATED ASSEMBLIES. FIRESTOPPING SHALL BE PROVIDED AS REQUIRED BY CODE.
- L COORDINATE ALL FLOOR BOXES, CORE DRILLS AND STUB-UPS, ETC. WILL RADIANT FLOORING LAYOUT AND INSTALLATION. DO NOT RUN CONDUITS WITHIN SLAB.

Date	Description
09/22/08	DESIGN DEVELOPMENT
12/03/08	75% CONSTRUCTION DOCUMENTS
01/23/09	95% CONSTRUCTION DOCUMENTS
10/26/09	ISSUED FOR PERMIT
145 09/01/11	ISSUED FOR CONSTRUCTION

Seal/Signature  
  
 Project Name  
 PWM Terminal Enhancement

Project Number  
 09.6395.000  
 Description  
 POWER & COMMUNICATION PLAN - LEVEL 4 - ZONE 5

Scale  
 As indicated

**A03.04.05**

**KEY PLAN**

