



... Fire Protection by Computer Design

Dean and Allyn Inc
116 Lewiston Road
Your Street Address 2
Gray ME, 04039
(207)657-5646

Job Name : Portland Jetport Repipe '13 ZONE 1
Building : Parking Garage
Location : Portland Maine
System : Zone 3
Contract : C131180
Data File : PJPREPIPEzone3.WXF

HYDRAULIC CALCULATIONS
for

Project name: Portland Jetport Repipe '13
Location: Portland Maine
Drawing no: Parking Garage
Date: 12/31/2013

Design

Remote area number: Zone 3
Remote area location:
Occupancy classification:
Density: .15 - Gpm/SqFt
Area of application: 1950 - SqFt
Coverage per sprinkler: 120 - SqFt
Type of sprinklers calculated: Reliable F1FR56
No. of sprinklers calculated: 17
In-rack demand: - GPM
Hose streams: 0 - GPM
Total water required (including hose streams): 356.884 - GPM @ 55.5515 - Psi
Type of system: Dry
Volume of dry or preaction system: - Gal

Water supply information

Date:
Location:
Source:

Name of contractor: Dean and Allyn Inc
Address: 116 Lewiston Road Gray, ME 04039
Phone number: (207)657-564
Name of designer: Scott Cote
Authority having jurisdiction: Portland Fire Department
Notes: (Include peaking information or gridded systems here.)

Fittings Used Summary

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 2
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dvc	Dry Vic 756	0	0	0	0	3	9	8	17	0	21	0	22	50	0	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziu	Wilkins 975	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
300	13.0	5.6	10.46	na	18.11	0.15	22	7.0
301	11.667	5.6	12.4	na	19.72	0.15	84	7.0
302	11.667	5.6	12.92	na	20.13	0.15	84	7.0
303	11.542	5.6	14.12	na	21.04	0.15	84	7.0
304	11.417	5.6	16.19	na	22.53	0.15	84	7.0
300A	11.667		13.22	na				
301A	11.667		13.26	na				
302A	11.542		13.87	na				
303A	11.417		15.13	na				
304A	11.417		17.29	na				
306	13.0	5.6	10.19	na	17.88	0.15	22	7.0
306A	11.667		12.91	na				
307	11.667	5.6	12.94	na	20.14	0.15	84	7.0
308	11.542	5.6	13.55	na	20.61	0.15	84	7.0
309	11.417	5.6	14.84	na	21.58	0.15	84	7.0
310	11.417	5.6	17.06	na	23.13	0.15	84	7.0
311	13.0	5.6	10.33	na	18.0	0.15	120	10.32
311A	11.667		13.07	na				
312	11.667	5.6	13.11	na	20.27	0.15	126	11.391
313	11.542	5.6	13.72	na	20.75	0.15	126	11.391
314	11.417	5.6	15.04	na	21.71	0.15	126	11.391
315	11.417	5.6	17.28	na	23.28	0.15	126	11.391
316	11.417	5.6	24.23	na	27.57	0.15	126	11.391
317	11.417	5.6	24.54	na	27.74	0.15	126	11.391
69	10.167		26.72	na				
68	10.167		26.79	na				
67	10.167		27.12	na				
66	10.167		27.97	na				
66A	9.75		28.29	na				
65	9.75		31.11	na				
64	9.708		33.7	na				
63	10.167		38.23	na				
62	10.167		40.59	na				
TR	21.458		36.86	na				
BR	17.458		40.04	na				
BASE	16.417		51.6	na				
HOSE	13.417		53.02	na				
TEST	13.417		53.3	na				

The maximum velocity is 16.39 and it occurs in the pipe between nodes 315 and 67

Final Calculations - Hazen-Williams

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
300 to 300A	18.11	1.049 120.0 0.1083	3E 6.0 1T 5.0	9.208 11.000 20.208	10.459 0.577 2.189		K Factor = 5.60		
	0.0 18.11					13.225	K Factor = 4.98		
301 to 301A	19.72	1.049 120.0 0.1268	1T 5.0	1.750 5.000 6.750	12.404 0.0 0.856		K Factor = 5.60		
	0.0 19.72					13.260	K Factor = 5.42		
302 to 302A	20.13	1.049 120.0 0.1317	1T 5.0	1.750 5.000 6.750	12.923 0.054 0.889		K Factor = 5.60		
	0.0 20.13					13.866	K Factor = 5.41		
303 to 303A	21.04	1.049 120.0 0.1430	1T 5.0	1.750 5.000 6.750	14.116 0.054 0.965		K Factor = 5.60		
	0.0 21.04					15.135	K Factor = 5.41		
304 to 304A	22.53	1.049 120.0 0.1624	1T 5.0	1.750 5.000 6.750	16.193 0.0 1.096		K Factor = 5.60		
	0.0 22.53					17.289	K Factor = 5.42		
300A to 301A	18.11	1.61 120.0 0.0133	0.0	2.625 0.0 2.625	13.225 0.0 0.035			Vel = 2.85	
301A to 302A	19.72	1.61 120.0 0.0526	0.0	10.500 0.0 10.500	13.260 0.054 0.552			Vel = 5.96	
302A to 303A	20.13	1.61 120.0 0.1157	0.0	10.500 0.0 10.500	13.866 0.054 1.215			Vel = 9.13	
303A to 304A	21.04	1.61 120.0 0.2051	0.0	10.500 0.0 10.500	15.135 0.0 2.154			Vel = 12.45	
304A to 69	22.54	1.61 120.0 0.3263	1E 4.0 1T 8.0	15.250 12.000 27.250	17.289 0.541 8.893			Vel = 16.00	
	0.0 101.54					26.723	K Factor = 19.64		
306 to 306A	17.88	1.049 120.0 0.1058	3E 6.0 1T 5.0	9.208 11.000 20.208	10.191 0.577 2.137		K Factor = 5.60		
306A to 307	0.0 17.88	1.61 120.0 0.0132	0.0	2.583 0.0 2.583	12.905 0.0 0.034			Vel = 2.82	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
307 to 308	20.14 38.02	1.61 120.0 0.0530		0.0	10.500	12.939 0.054 0.557			K Factor = 5.60	
308 to 309	20.61 58.63	1.61 120.0 0.1182		0.0	10.500	13.550 0.054 1.241			K Factor = 5.60	Vel = 9.24
309 to 310	21.58 80.21	1.61 120.0 0.2110		0.0	10.500	14.845 0.0 2.215			K Factor = 5.60	Vel = 12.64
310 to 68	23.13 103.34	1.61 120.0 0.3371	1E 1T	4.0 8.0 0.0	15.250 12.000 27.250	17.060 0.541 9.187			K Factor = 5.60	Vel = 16.29
	0.0 103.34					26.788			K Factor = 19.97	
311 to 311A	18.00 18.0	1.049 120.0 0.1071	3E 1T	6.0 5.0 0.0	9.208 11.000 20.208	10.332 0.577 2.164			K Factor = 5.60	Vel = 6.68
311A to 312	0.0 18.0	1.61 120.0 0.0132		0.0	2.583	13.073 0.0 0.034				Vel = 2.84
312 to 313	20.27 38.27	1.61 120.0 0.0537		0.0	10.500	13.107 0.054 0.564			K Factor = 5.60	Vel = 6.03
313 to 314	20.75 59.02	1.61 120.0 0.1196		0.0	10.500	13.725 0.054 1.256			K Factor = 5.60	Vel = 9.30
314 to 315	21.71 80.73	1.61 120.0 0.2135		0.0	10.500	15.035 0.0 2.242			K Factor = 5.60	Vel = 12.72
315 to 67	23.28 104.01	1.61 120.0 0.3412	1E 1T	4.0 8.0 0.0	15.250 12.000 27.250	17.277 0.541 9.298			K Factor = 5.60	Vel = 16.39
	0.0 104.01					27.116			K Factor = 19.97	
316 to 317	27.57 27.57	1.61 120.0 0.0292		0.0	10.500	24.235 0.0 0.307			K Factor = 5.60	Vel = 4.34
317 to 66	27.74 55.31	1.61 120.0 0.1061	1E 1T	4.0 8.0 0.0	15.250 12.000 27.250	24.542 0.541 2.891			K Factor = 5.60	Vel = 8.72
	0.0 55.31					27.974			K Factor = 10.46	
69 to 68	101.54 101.54	4.26 120.0 0.0028	1E	13.167 0.0 0.0	9.750 13.167 22.917	26.723 0.0 0.065				Vel = 2.29
68 to 67	103.34 204.88	4.26 120.0 0.0105	1T	26.334 0.0 0.0	5.000 26.334 31.334	26.788 0.0 0.328				Vel = 4.61

Final Calculations - Hazen-Williams

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
67	104.01	4.26	1T	26.334	12.000	27.116				
to		120.0		0.0	26.334	0.0				
66	308.89	0.0224		0.0	38.334	0.858		Vel =	6.95	
66	55.31	4.26		0.0	4.542	27.974				
to		120.0		0.0	0.0	0.181				
66A	364.2	0.0302		0.0	4.542	0.137		Vel =	8.20	
66A	0.0	4.26	1F	5.267	87.792	28.292				
to		120.0		0.0	5.267	0.0				
65	364.2	0.0303		0.0	93.059	2.823		Vel =	8.20	
65	0.0	4.26	1F	5.267	79.333	31.115				
to		120.0		0.0	5.267	0.018				
64	364.2	0.0303		0.0	84.600	2.566		Vel =	8.20	
64	0.0	4.26	4E	52.668	103.292	33.699				
to		120.0		0.0	52.668	-0.199				
63	364.2	0.0303		0.0	155.960	4.731		Vel =	8.20	
63	0.0	4.26	2E	26.334	51.500	38.231				
to		120.0		0.0	26.334	0.0				
62	364.2	0.0303		0.0	77.834	2.361		Vel =	8.20	
62	0.0	4.26	2E	26.334	12.000	40.592				
to		120.0		0.0	26.334	-4.890				
TR	364.2	0.0303		0.0	38.334	1.163		Vel =	8.20	
TR	0.0	4.26	1Dvc	27.651	4.000	36.865				
to		120.0	1B	15.8	43.451	1.732				
BR	364.2	0.0303		0.0	47.451	1.439		Vel =	8.20	
BR	0.0	8.249	1Ziu	0.0	7.000	40.036				
to		120.0		0.0	0.0	11.550				
BASE	364.2	0.0013		0.0	7.000	0.009		* Fixed loss = 11.1		
								Vel =	2.19	
BASE	0.0	8.27	3E	85.404	50.000	51.595				
to		140.0	1G	6.326	91.730	1.299				
HOSE	364.2	0.0009		0.0	141.730	0.128		Vel =	2.18	
HOSE	0.0	12.34	6F	121.897	2000.000	53.022				
to		140.0	1E	42.195	164.092	0.0				
TEST	364.2	0.0001		0.0	2164.092	0.278		Vel =	0.98	
	0.0									
	364.20					53.300		K Factor =	49.89	

Water Supply Curve (C)

Dean and Allyn Inc
Portland Jetport Repipe '13 ZONE 1

Page 7
Date

City Water Supply:

C1 - Static Pressure : 86
C2 - Residual Pressure: 73
C2 - Residual Flow : 2781

Demand:

D1 - Elevation : -0.181
D2 - System Flow : 364.202
D2 - System Pressure : 53.300
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 364.202
Safety Margin : 32.397

