Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/23/14



SPRINKLER SYSTEM LAYOUT IN CRF AREAS (SEE DETAIL ON SHEET 3 OF 4)



BUILDING SECTION

SCALE: 1/4" = 1'-0"



4" MAINS NEED 9'-6" CLEARENCE TO BOTTOM OF PIPE @ 30" IBEAMS.

SECTION "B"

SCALE: 1/4" = 1'-0"



4" MAINS NEED 10'-2" CLEARENCE TO BOTTOM OF PIPE @ 21" IBEAMS.

SECTION "C"

SCALE: 1/4" = 1'-0"

DEAN & ALLYN, INC.
FIRE PROTECTION · SPECIAL HAZARD
PO BOX 709, GRAY, MAINE 04039
(207)657-5646 FAX:(207)657-5647

					SCALE 1/8"=1'-0"	DANA A. STEWART NICET IV - #064544			DRAWING TITLE: PJP GARAGE REPIPE ZONES 1&2	REV. 0
					APPROVED BY	DATE	SURVEYED BY	SEC 11/25/13	JOB: Portland Jetport 2013 Parking Garage RePipe Portland Maine	NO. OF SPRINKLERS SHOWN ON THIS SHEET XXX
						/ /	DRAWN BY	SEC 12/01/13		
						/ /	CHECKED BY	DAS		NO. OF SPRINKLERS ON JOB 387
						/ /	AT DEAN & ALLYN, INC			
		0	SUBMIT FOR APPROVAL	xx/xx/xx		/ /	SCALE 1/8"=1'-0" U/N		CONTRACT WITH: Owner XXX	CONTRACT NO. C131180
			REVISIONS	DATE		/ /	SHEET NO. 2 OF 2			