1 FS.G.4 ENLARGED SITE\KEY PLAN

0 4' 8' 16'

CODE REVIEW:

NFPA 30A (2003) PROPOSED 6,000 GALLON ABOVEGROUND TANK CONSTRUCTION: UL2085 IS DESIGN TO STORE REGULAR GASOLINE. (CLASS I FLAMMABLE LIQUID)

3.3.15.4 PROTECTED ABOVEGROUND TANK
DEFINES A PROTECTED ABOVEGROUND TANK WHICH IS A TANK LISTED IN ACCORDANCE WITH UL 2085 OR EQUIVALENT.

TABLE 4.3.2.4 MINIMUM SEPARATION REQUIREMENTS FOR ABOVEGROUND TANKS
PROTECTED ABOVEGROUND TANK INDIVIDUAL TANK CAPACITY (GAL) LESS THAN OR EQUAL 6,000 GALLONS:

	REQUIRED	ACTUAL
FROM NEAREST IMPORTANT BUILDING ON SAME PROPERTY:	5 FEET	77 FEET
FROM NEAREST FUEL DISPENSING DEVICE:	0 FEET	159 FEET
FROM LOT LINE THAT IS OR CAN BE BUILT UPON, INCLUDING THE OPPOSITE SIDE OF THE PUBLIC WAY:	15 FEET	25 FEET
DISTANCE FROM NEAREST SIDE OF ANY PUBLIC WAY:	5 FEET	25 FEET
MINIMUM DISTANCE BETWEEN TANKS:	3 FEET	N/A
6.4.3 REQUIREMENTS FOR REMOTE/SUBMERSIBLE PUMPS		
PUMPS INSTALL ABOVE GRADE OUTSIDE OF BUILDINGS:		
FROM LINES OF ADJOURNING PROPERTY:	10 FEET	29 FEET
FROM ANY BUILDING OPENING:	5 FEET	78 FEET
5.6 VENT PIPING		
TERMINATE ABOVE GRADE:	12 FEET	12 FEET

Stantec
Stantec Co
5 Dartmou
Auburn NH
03032-39
Tel. 603.6
Fax. 603.6
www.stantec.com

Reviewed for Code Compliance Inspections Division Approved with Conditions
Date: 10/31/13

Copyright Reserved
The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing – any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Consultants

Legend

Notes

Revision	By	Appd.	YY.MM.DD
ISSUE FOR PERMIT	JES	JES	13.09.27
ISSUE FOR BID	JES	JES	13.09.10

Issued	By	Appd.	YY.MM.DD
File Name: 01_191711186_FS.G.dwg	JKM	JSW/JES	JKM	13.07.31
	Dwn.	Chkd.	Dsgn.	YY.MM.DD

Hertz

Client/Project
THE HERTZ CORPORATION
ABOVEGROUND STO DRAFT
INSTALLATION AND RELATED WORK
PORTLAND, ME

Title
ENLARGED SITE/KEY PLAN

Project No. 191711186
Scale AS NOTED
Drawing No. FS.G.4
Sheet 4 of 19
Revision 0

ORIGINAL SHEET – ARCH D