PER UPP INSTALLATION INSTRUCTIONS, INSTALL PIPING OVER 39' IN LENGTH ON GENTLE "S" CURVES AND NOT IN A STRAIGHT LINE FOR THERMAL CONTRACTION\EXPANSION

1 FS.P.1 UNDERGROUND PIPING PLAN

0 8' 16' 24'

N

Stantec
Stantec Con
5 Dartmout
Auburn NH
03032-398
Tel. 603.66
Fax. 603.66
www.stantec.com

CITY OF PORTLAND, MAINE RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/31/13

Copyright Reserved
The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing – any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Consultants

Legend

Notes

STATE OF MAINE
JAMES E. STEWART
No. 9848
LICENSED
PROFESSIONAL ENGINEER
9-27-13

Revision	By	Appd.	YY.MM.DD
ISSUE FOR PERMIT	JES	JES	13.09.27
ISSUE FOR BID	JES	JES	13.09.10
Issued	By	Appd.	YY.MM.DD

File Name: 03_191711186_FS.P.dwg	JSW	JKM/JSC	JSW	1-20-12
	Dwn.	Chkd.	Dsgn.	YY.MM.DD

Hertz

Client/Project
THE HERTZ CORPORATION

ABOVEGROUND STORAGE TANK INSTALLATION AND RELATED WORK
PORTLAND, ME

Title
UNDERGROUND PIPING PLAN

Project No.	Scale	
191711186	AS NOTED	
Drawing No.	Sheet	Revision
FS.P.1	13 of 19	0

ORIGINAL SHEET – ARCH D