WARNING

DO NOT INITIATE FUEL OR OIL TRANSFERS PRIOR TO CHECKING IN WITH FACILITY PERSONNEL.

Tank Truck Drivers are responsible for following DOT Procedures (49 CFR Parts 177.834 ans 177.837

- Shut down engine unless used for transfer pumping operation
- Set brakes and chock wheels prior to and for the duration of all fuel transfers
- Perform bonding/grounding prior to fuel and oil transfers. If necessary
- No smoking during fuel and oil transfers
- Use drip pells below hose connections during fuel and oil transfers
- Remain within 25 feet and maintain unobstructed view of cargo tank and hose at all times during fuel and oil transfers
- Inspect vehicle drains and outlets for leakage prior to loading and prior to vehicle departure: make necessary adjustments or repairs prior to departure
- Verify complete disconnect of hoses and bonding/grounding prior to removal of wheel chocks

DO NOT DEPART PRIOR TO CHECKING OUT WITH FACILITY PERSONNEL.

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR
SIGN#: CAS–HTZ2

1 FS.C.6 DRIVER WARNING SIGN
SCALE: NOT TO SCALE

12"

WARNING

No smoking within 50 ft. of dispenser

Engine Off

Fill approved containers only

Only fill containers on ground

If fire:
- Leave nozzle in
- Sound fire alarm
- Shut off fuel
- Evacuate

16"

NOTES:
16"X12" SINGLE FACED, COLUMN MOUNTED SIGN. RED BACKGROUND WITH WHITE LETTERS.
GASOLINE ADVERTISING PRODUCTS
MODEL NUMBER: AS–47

LOCATIONS:
TO BE MOUNTED NEAR FUELING OPERATIONS AREA, ONE PER DISPENSER.

2 FS.C.6 WARNING SIGN
SCALE: NOT TO SCALE

6,000 GALLONS

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR
SIGN#: CVD–HTZ11

3 FS.C.6 TANK CONTENT LABEL
SCALE: NOT TO SCALE

GASOLINE

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR
SIGN#: CVD–HTZ15

5 FS.C.6 MAIN TANK LABEL
SCALE: NOT TO SCALE

VAULT TANK

NO SMOKING

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR
SIGN#: CVD–HTZ10

4 FS.C.6 VAULT TANK LABEL
SCALE: NOT TO SCALE

3
1 0

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR

6 FS.C.6 NFPA 704 PLACARD
SCALE: NOT TO SCALE

1'–6"

Overfill Alarm
When Alarm Sounds
Tank is Full

8"

OWNER SUPPLIED SIGN TO BE INSTALLED BY CONTRACTOR
SIGN#: CAS–HTZ4

7 FS.C.6 OVERFILL SIGN
SCALE: NOT TO SCALE

EMERGENCY
FUEL
SHUT-OFF
SWITCH

18"

NOTES:
18"X18" SINGLE FACED, COLUMN MOUNTED SIGN. RED BACKGROUND WITH WHITE LETTERS.

LOCATIONS:
TO BE MOUNTED ABOVE EMERGENCY FUEL PUMP SHUT–OFF SWITCH

8 FS.C.6 EMERGENCY SHUT–OFF SIGN
SCALE: NOT TO SCALE

18"

IN CASE
OF SPILL

- Use Emergency Shut-Off
- Call 911

24"

NOTES:
24"X18" SINGLE FACED, COLUMN MOUNTED SIGN. RED BACKGROUND WITH WHITE LETTERS.

LOCATIONS:
TO BE MOUNTED NEAR FUELING OPERATIONS AREA AND TANK FILL AREA.

9 FS.C.6 EMERGENCY PROCEDURE SIGN
SCALE: NOT TO SCALE

Stantec

Stantec Con
5 Dartmouth
Auburn NH
03032–398
Tel. 603.669
Fax. 603.669
www.stantec.com

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/31/13

Copyright Reserved
The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing – any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Consultants

Legend

Notes

STATE OF MAINE
JAMES E. STEWART
No. 9848
LICENSED PROFESSIONAL ENGINEER
9-27-13

Revision	By	Appd.	YY.MM.DD
ISSUE FOR PERMIT	JES	JES	13.09.27
ISSUE FOR BID	JES	JES	13.09.10

Issued	By	Appd.	YY.MM.DD

File Name: 02_191711186_FS.C.dwg	JSW	JKM/JSC	JSW	1–20–12
	Dwn.	Chkd.	Dsgn.	YY.MM.DD

Hertz

Client/Project
THE HERTZ CORPORATION

ABOVEGROUND STORAGE TANK INSTALLATION AND RELATED WORK
PORTLAND, ME

Title
ABOVEGROUND STORAGE TANK SIGN DETAILS

Project No. 191711186
Scale AS NOTED
Drawing No. FS.C.6
Sheet 11 of 19
Revision 0

ORIGINAL SHEET – ARCH D