



Portland Fire Department

12/11/2019

CERTIFIED MAIL

RE:

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 5/10/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 1/17/2020 1:00:00PM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 10- 7.2.4.4	Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method.	Room 2519B no tag and needs to be mounted.	5/24/2018
Portland Code Ch. 10	Buildings must comply with Ch. 10 of the Portland Code of Ordinances.	This requires a Haz-Mat Management cabinet as well as No 704 marking system.	6/9/2018
NFPA 101-4.5.8, 7.9.3	Emergency lights must be kept in good working order.	All Emergency lighting must be in working order.	6/9/2018