

Crede Associates, LLC  
 776 Main St.  
 Westbrook, Maine 04092  
 Project # 12-017

Testing Date: 02/15/2012

**Asbestos Bulk Sample Summary  
 Thompson's Point**

			Building #8
B-1A	Through-Out	2 x 4 (Wormhole Pattern) Ceiling Tile - Gray/White	None Detected
B-1B	"	"	None Detected
B-1C	"	"	None Detected
B-2A	Through-Out	Joint Compound - White	None Detected
B-2B	"	"	None Detected
B-2C	"	"	None Detected
B-3A	Through-Out	Sheetrock - White	None Detected
B-3B	"	"	None Detected
B-3C	"	"	None Detected
B-3D	"	"	None Detected
B-3E	"	"	None Detected
B-4A	Through-Out	Roof Vapor Barrier on Insulation - Black	None Detected
B-4B	"	"	None Detected
B-4C	"	"	None Detected
B-5A	Through-Out	Roof Deck - Gray/Black	None Detected
B-5B	"	"	None Detected
B-5C	"	"	None Detected