DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

THOMPSON'S POINT INC

Located at

1 Thompsons Point

PERMIT ID: 2015-00615

ISSUE DATE: 05/29/2015

201 A005001 CBL:

has permission to

Phase 2 - build 2 egress stair enclosures & infill a portion of the deck on the second floor for new tenant - office use. No fit up of tenant space

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning office use on partial second floor - Brick North, West Wing

Building Inspections

Fire Department

Use Group: B

Type: 3B Business (tenant unknown at this time)

Occupant load = 26 NFPA 13 Sprinkler System 2nd Floor, West Wing

MUBEC/IBC 2009

PERMIT ID: 2015-00615 Located at: 1 Thompsons Point CBL: 201 A005001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing Framing Only Fire Inspection Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2015-00615 Located at: 1 Thompsons Point CBL: 201 A005001

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 8	74-8716	2015-00615	03/30/2015	201 A005001
Proposed Use:	Proposed Project Description:			
Phase 2 - Brick North Building - Warehouse - West Wing - Circus Conservatory & retail pottery studio with new Office use on 2nd Floor		the second floor f	tair enclosures & inf for new tenant - offic	
Dept: Zoning Status: Approved w/Conditions R	eviewer:	Ann Machado	Approval Da	ate: 04/30/201
Note:				Ok to Issue:
Conditions:				
1) Separate permits shall be required for any new signage.				
2) This permit is being approved on the basis of plans submitted. A work.	Any deviat	ions shall require a	separate approval b	efore starting that
Dept: Building Inspecti Status: Approved w/Conditions R	eviewer:	Jeanie Bourke	Approval Da	ate: 05/15/201
Note:				Ok to Issue:
Conditions:				
 Separate permits are required for any electrical, plumbing, sprink pellet/wood stoves, commercial hood exhaust systems, fire supprapproval as a part of this process. Penetrations through fire resistance rated assemblies shall be protested in accordance with ASTM E814 or UL 1479 	ression and	d fuel tanks. Separ	ate plans may need t	o be submitted for
3) This permit is approved based upon information provided by the approved plans requires separate review and approval prior to we establishes the Business use.				
Dept: Engineering DPS Status: Not Applicable R	eviewer:	Benjamin Pearson	n Approval Da	ate: 04/10/201
Note: Conditions:		·		Ok to Issue:
		Control Maria		05/00/00:
•	eviewer:	Craig Messinger	Approval Da	
Note:				Ok to Issue:
Conditions:	'.1 NIEDA	25 G. 1 16 T	·	134.
 The entire sprinkler system shall be maintained in accordance with Water-Based Fire Protection Systems, 2008 edition. 	ith NFPA	25, Standard for In	ispection, Testing an	d Maintenance of
2) A separate Fire Alarm Permit is required for new systems; or for fire alarm panel with a different model. This review does not inc				
3) Shall comply with NFPA 101, Chapter 38, New Business occupa	ancies.		-	

5) Shall meet the requirements of 2009 NFPA 1 Fire Code

4) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and

6) All construction shall comply with City Code Chapter 10.

circuit and on the same circuit as the lighting for the area they serve.

PERMIT ID: 2015-00615 Located at: 1 Thompsons Point CBL: 201 A005001