

**PACKAGED ROOFTOP UNIT PERFORMANCE SCHEDULE**

• • (NET) AT 95°F AMBIENT

TAG	NOMINAL COOLING (TONS)	TOTAL COOLING (MBH)	SENSIBLE COOLING (MBH)	EDB/EWB (°F)	LDB/LWB (°F)	TOTAL AIRFLOW (CFM)	E.S.P. (IN.WG)	SUPPLY FAN RPM	MINIMUM O.A. (CFM)	MINIMUM EXHAUST (CFM)	FUEL INPUT (MBH)	HEATING OUTPUT (MBH)	HEATING EAT (°F)	HEATING LAT (°F)	SEER (BTU/H·WATT)	WEIGHT W/ CURBS (LBS)	TYPE OF REFRIGERANT	FUEL	ELECTRICAL REQUIREMENTS				BASIS OF DESIGN - TRANE	
																			HP	MCA	MOCP	V/PH/Hz	SERVICE	MODEL
HVAC-1	4.0	49.1	32.1	79.9/68.4	58.6/51.0	1310	0.75	857	540	-	120	96	371	105.1	115	1300	R-410a	NAT GAS	-	13.7	200	460/3/60	FUNCTION	YHC041
HVAC-2	6.0	70.6	54.9	71.9/65.0	56.1/54.6	2200	0.75	1002	615	-	120	97	471	88.3	-	1100	R-410a	NAT GAS	-	18.7	250	460/3/60	KITCHEN	YHC074
HVAC-3	3.0	35.5	24.5	81.7/68.7	59.3/57.5	960	0.50	747	585	-	100	80	212	98.5	115	1050	R-410a	NAT GAS	-	23.3	300	208/3/60	DINING	YHC031
HVAC-4	3.0	32.7	24.3	71.1/64.0	55.0/52.7	960	0.50	746	195	-	60	48	53.6	100.1	115	1050	R-410a	NAT GAS	-	23.3	300	208/3/60	BAR	YHC031

PROVIDE ALL UNITS WITH DUAL ENTHALPHY ECONOMIZERS, HOT GAS REHEAT, STAINLESS STEEL HEAT EXCHANGERS (WHERE AVAILABLE) AND TWO STAGE OR MODULATING HEAT (WHERE AVAILABLE)

**ENERGY RECOVERY VENTILATOR PERFORMANCE SCHEDULE**

• • AT ARI. STANDARD CONDITIONS.

TAG	MINIMUM O.A. (CFM)	MAXIMUM O.A. (CFM)	FAN	DRIVE	AIRFLOW (CFM)	T.S.P. (IN.WG)	E.S.P. (IN.WG)	ELECTRICAL REQUIREMENTS				TAG HEAT RECOVER.	FURNACE INPUT (MBH)	FURNACE OUTPUT (MBH)	FURNACE FUEL	WT. (LBS)	BASIS OF DESIGN - GREENHECK			
								HP	BHP	FREHEAT kW	MCA						MOCP	V/PH/Hz	SERVICE	MODEL
ERV-1	1600	1600	SUPPLY EXHAUST	BELT	1600	1.61	0.15	15	119	4.1	315	500	208/3/60	ERV-1	100	80	NAT GAS	2500	ANNEX CORRIDOR/RESTROOMS	ERCH-20-30L
ERV-2, ERV-3, ERV-4, ERV-5	6310	6310	SUPPLY EXHAUST	BELT	6310	1.53	0.15	5.0	3.33	15.5	988	1000	208/3/60	ERV-2	400	320	NAT GAS	4000	MULTIPURPOSE ASSEMBLY	ERCH-90-30L

PROVIDE ALL UNITS WITH VARIABLE FREQUENCY DRIVES ON BOTH SUPPLY AND EXHAUST FANS, MODULATING GAS HEAT WITH DIRECT SPARK IGNITION AND MODULATING WHEEL ECONOMIZER  
PROVIDE ERV-1 WITH PACKAGED DX-COOLING, 915 MBH TOTAL AND 382 MBH SENSIBLE CAPACITY (11.1°F/65.4°F EDB/EWB, 55.1°F/55.0°F LDB/LWB)

**ENERGY RECOVERY WHEEL PERFORMANCE SCHEDULE**

BASIS OF DESIGN - GREENHECK

TAG	AIR STREAM	AIRFLOW (CFM)	S.P. (IN.WG)	WINTER OPERATION				SUMMER OPERATION				WEIGHT (LBS)	TAG AHU			
				E.D.B.(°F)	E.W.B.(°F)	RH.(%)	L.D.B.(°F)	L.W.B.(°F)	EFF.(%)	E.D.B.(°F)	E.W.B.(°F)			RH.(%)	L.D.B.(°F)	L.W.B.(°F)
ERV-1	OUTSIDE AIR	1600	-	-10.0	-11.0	-	53.0	42.2	18.8	87.8	73.3	-	71.7	65.4	18.8	ERV-1
	EXHAUST AIR	1600	-	70.0	-	25.0	7.0	6.6	-	75.0	-	50.0	85.1	71.5		
ERV-2	OUTSIDE AIR	6310	-	-10.0	-11.0	-	52.7	42.0	18.4	87.8	73.3	-	71.8	65.1	18.4	ERV-2
	EXHAUST AIR	6310	-	70.0	-	25.0	7.3	6.8	-	75.0	-	50.0	85.0	71.4		

**GAS UNIT HEATER PERFORMANCE SCHEDULE**

TAG	INPUT (MBH)	OUTPUT (MBH)	THERMAL EFF. %	AIRFLOW (CFM)	FUEL	ELECTRICAL REQUIREMENTS			BASIS OF DESIGN - REZNR			
						HP	FLA	MOCP	V/PH/Hz	SERVICE	ARRANGEMENT	MODEL
GFUH-1	260	239	92	4430	NAT GAS	1/4	6.3	15.0	115/1/60	MULTIFUNCTION SPACE	HORIZONTAL	UEA5-260

**FAN PERFORMANCE SCHEDULE**

TAG	AIRFLOW (CFM)	T.S.P. (IN.WG)	NOISE (SONES)	RPM	DRIVE	ELECTRICAL REQUIREMENTS				BASIS OF DESIGN - (G) GREENHECK, (C) CAPTIVEAIRE			
						HP	BHP	WATTS	AMPS	V/PH/Hz	SERVICE	ARRANGEMENT	MODEL
EF-1	1260	0.75	10.5	1061	BELT	2.0	0.4	-	-	460/3/60	KITCHEN HOOD (KH-1)	UPBLAST	(C) NCA4MFA
EF-2	3525	1.50	19	939	BELT	2.0	1.5	-	-	460/3/60	KITCHEN HOOD (KH-2)	UPBLAST	(C) NCA24HFFA
EF-3	3225	1.50	17.9	921	BELT	2.0	1.4	-	-	460/3/60	KITCHEN HOOD (KH-3)	UPBLAST	(C) NCA24HFFA
EF-4	1000	0.50	13.1	1357	BELT	0.5	0.3	-	-	120/1/60	DISHWASHER HOOD (KH-4)	UPBLAST	(C) DUS0HFA
EF-5	150	0.50	5.6	1107	DIRECT	1/10	-	-	2.6	120/1/60	KITCHEN RESTROOM/JANITOR	DOWNBLAST	(G) G-070-VG

**MAKE-UP AIR HANDLER PERFORMANCE SCHEDULE**

BASIS OF DESIGN - CAPTIVEAIRE

TAG	AIRFLOW (CFM)	MIN.O.A. (CFM)	E.S.P. (IN.WG)	FUEL	RPM	COOLING COIL				CONDENSER			HEATING				ELECTRICAL REQUIREMENTS				WEIGHT (POUNDS)	MODEL						
						EDB/EWB	LDB/LWB	TOTAL (MBH)	SENSIBLE (MBH)	SEER	NOMINAL (TONS)	REFRIGERANT	MCA	MOCP	VOLTAGE	E.D.B. (°F)	L.D.B. (°F)	INPUT CAP (MBH)	OUTPUT CAP (MBH)	HP			BHP	VFD	MCA	LRA	MOCP	VOLTAGE
MAU-1	1134	1134	0.35	NAT GAS	823	84/70	72/65	218	15.3	14.0	3.0	R-410a	7.1	15.0	460/3/60	-5	66	95	81	1.0	0.3	NO	-	-	-	460/3/60	1550	AI-D250-G10-MPU
MAU-2	6074	6074	0.50	NAT GAS	911	84/70	72/64	1319	92.5	14.0	5.0, 5.0, 5.0	R-410a	8.5/8.5/8.5	15/15/15	460/3/60	-5	66	510	465	5.0	4.1	NO	-	-	-	460/3/60	3000	A3-D500-G18-MPU

CONDENSING UNITS ARE PART OF MAU BUT REQUIRE SEPARATE POWER (EACH) - MAU-1 HAS ONE CONDENSER, MAU-2 HAS THREE CONDENSERS  
PROVIDE WITH 25-1 MODULATING GAS HEAT, ROOM OVERRIDE SENSOR.

**MECHANICAL AND PLUMBING SYMBOLS AND ABBREVIATIONS LEGEND**

NOTE - USE SYMBOLS AND ABBREVIATIONS AS APPLICABLE FOR THIS MECHANICAL DRAWING SET. SOME SYMBOLS AND ABBREVIATIONS IN THIS LEGEND MAY NOT APPLY.

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	ABBREVIATION	DESCRIPTION	ABBREVIATION	DESCRIPTION	ABBREVIATION	DESCRIPTION	ABBREVIATION	DESCRIPTION	ABBREVIATION	DESCRIPTION
—CA—	COMPRESSED AIR PIPING (CA)	⊗	BACKFLOW PREVENTER (BFP)	⊕	PRESSURE GAGE WITH GAGE COCK	AAV	AUTOMATIC AIR VENT	EDB	ENTERING DRY BULB	I:B:R	INSTITUTE OF BOILER AND RADIATOR MANUFACTURERS	RLA	RUNNING LOAD AMPS		
—C—	CONDENSATE DRAIN PIPING (C)	⊗	CHECK VALVE	⊕	THERMOMETER IN WELL	AD	ACCESS DOOR	EDC	ELECTRIC DUCT COIL TAG	IN	INCHES	RPM	REVOLUTIONS PER MINUTE		
—CTR—	COOLING TOWER RETURN PIPING (CTR)	⊗	BALANCING VALVE (ADJUSTABLE)	⊕	WATER FLOW SWITCH	AFF	ABOVE FINISHED FLOOR	EER	ENERGY EFFICIENCY RATIO	L	LEVER TAG	RP5	REVOLUTIONS PER SECOND		
—CTS—	COOLING TOWER SUPPLY PIPING (CTS)	⊗	AUTOMATIC FLOW CONTROL VALVE	⊕	PRESSURE SWITCH OR SENSOR	AHU	AIR HANDLING UNIT TAG	EF	EXHAUST FAN TAG	LAT	LEAVING AIR TEMPERATURE	RPZ	REDUCED PRESSURE ZONE		
—CWR—	CHILLED WATER RETURN PIPING (CWR)	⊗	RELIEF VALVE (RV)	⊕	EMURSION TEMPERATURE SENSOR	AMS	AIRFLOW MONITORING STATION	EF	EFFICIENCY	LB	POUNDS	RTU	ROOM TEMPERATURE SENSOR		
—CWS—	CHILLED WATER SUPPLY PIPING (CWS)	⊗	BALL VALVE	⊕	DUCT MOUNTED SMOKE DETECTOR	AMPS	AMPERES	ESP	EXTERNAL STATIC PRESSURE	LB	POUNDS	RV	RELIEF VALVE		
—FOR—	FUEL OIL RETURN PIPING (FOR)	⊗	BALL VALVE	⊕	ROOM TEMPERATURE SENSOR	AP	ACCESS PANEL	ET	EXPANSION TANK TAG	LU5/R	LOOP WATER SUPPLY/RETURN	RUL	RAINWATER LEADER		
—FOS—	FUEL OIL SUPPLY PIPING (FOS)	⊗	3/4" BALL VALVE WITH 3/4" HOSE END	⊕	THERMOSTAT OR SENSOR ON WALL	APD	AIR PRESSURE DROP	ET	ENTERING WET BULB	LRA	LOCKED ROTOR AMPS	SA	SUPPLY AIR		
—G—	GAS PIPING (G)	⊗	GATE VALVE	⊕	TSTAT OR SENSOR W/ TAMPERPROOF GUARD	AS	AIR SEPARATOR TAG	EUB	ENTERING WET BULB	LU0	LOW WATER CUTOFF	SAN	SANITARY (DRAIN & WASTE)		
—HUR—	HOT WATER RETURN PIPING (HUR)	⊗	PRESSURE REDUCING VALVE	⊕	MANUAL AIR VENT	ATC	AUTOMATIC TEMPERATURE CONTROL	EUT	ENTERING WATER TEMPERATURE	LWC	LEAVING WATER TEMPERATURE	SD	SMOKE DAMPER		
—HUS—	HOT WATER SUPPLY PIPING (HUS)	⊗	FUSIBLE VALVE	⊕	NOTE TAG (NUMBER)	ATC	AUTOMATIC TEMPERATURE CONTROL	EXG	EXISTING	LWT	LEAVING WATER TEMPERATURE	SP	SEASONAL ENERGY EFFICIENCY RATIO		
—RL—	REFRIGERANT LIQUID PIPING (RL)	⊗	2-WAY CONTROL VALVE	⊕	AIR DEVICE TAG (LETTER) WITH CFM	BD	BYPASS DAMPER TAG	EXH	EXHAUST	MAX	MAXIMUM	SB	SUPPLY FAN		
—RG—	REFRIGERANT GAS PIPING (RG)	⊗	3-WAY CONTROL VALVE	⊕	ROOM NUMBER	BFP	BACKFLOW PREVENTER TAG	FC	FLEXIBLE CONNECTION	MCA	MINIMUM CIRCUIT AMPACITY	SP	STATIC PRESSURE		
-----	SANITARY PIPING BELOW FLOOR (SAN)	⊗	SOLENOID VALVE	⊕	TURNING VANES	BHP	BRAKE HORSEPOWER	FCO	FLOOR CLEANOUT	MIN	MINIMUM	SQFT	SQUARE FEET		
-----	SANITARY PIPING ABOVE FLOOR (SAN)	⊗	3-WAY CONTROL VALVE	⊕	DUCT W/MANUAL DAMPER	BTH	BRITISH THERMAL UNITS PER HOUR	FD	FIRE DAMPER	NC	NOISE CRITERION	ΔT	TEMPERATURE DIFFERENTIAL		
-----	SANITARY VENT PIPING	⊗	4-WAY CONTROL VALVE (TOP VIEW)	⊕	DUCT W/FLEXIBLE CONNECTION (FC)	BTU	BRITISH THERMAL UNITS PER HOUR	FD	FLOOR DRAIN TAG	NIC	NOT IN CONTRACT	TEMP	TEMPERATURE		
-----	RAINWATER LEADER ABOVE SLAB (RWL)	⊗	BUTTERFLY VALVES W/SINGLE ACTUATOR	⊕	LAGGED DUCT	CFM	CUBIC FEET PER MINUTE	FLA	FULL LOAD AMPS	NTS	NOT TO SCALE	TCF	TEMPERATURE CONTROL PANEL		
-----	COLD WATER PIPING (CW)	⊗	BUTTERFLY VALVE W/ACTUATOR	⊕	DUCT W/ACOUSTIC LINING	CFP	CIRCULATING PUMP TAG	FFHB	FROST PROOF HOSE BIBB	OA	OUTSIDE AIR	TMV	THERMOSTATIC MIXING VALVE TAG		
-----	HOT WATER PIPING (HW)	⊗	TRIPLE-DUTY VALVE	⊕	DUCT W/SQUARE-TO-ROUND TRANSITION	CV	VALVE COEFFICIENT	FFM	FEET PER MINUTE	OBD	OPPOSED BLADE DAMPER	TSP	TOTAL STATIC PRESSURE		
-----	RECIRCULATED HOT WATER PIPING (RHW)	⊗	UNION	⊕	FLEXIBLE DUCT	CW	COLD WATER	FSD	COMBINATION FIRE & SMOKE DAMPER	OD	OUTSIDE DIAMETER	TYP	TYPICAL		
—	PIPE CAP	⊗	PUMP WITH FLANGES	⊕	MOTOR OPERATED DAMPER	DB	DRY BULB	FT	FEET	OED	OPEN ENDED DUCT	UH	UNIT HEATER TAG		
→	DIRECTION OF FLUID FLOW	⊗	BASE MOUNTED PUMP	⊕	AIRFLOW OUT	dB RE	DECIBELS RELATIVE TO	GA	GAGE	OPD	OVERCURRENT PROTECTIVE DEVICE	VB	VACUUM BREAKER		
⊕	ELBOW UP	⊗	PIPE FLANGE	⊕	AIRFLOW IN	DC	DOUBLE CHECK	GAL	GALLONS	P	PLUMBING FIXTURE TAG	VFD	VARIABLE FREQUENCY INVERTER DRIVE		
⊕	ELBOW DOWN	⊗	PUMP WITH FLANGES	⊕	DIAMETER OR FLAT OVAL	DCA	DOUBLE CHECK ATMOSPHERIC	GPH	GALLONS PER HOUR	FENET	PENETRATION	VTR	VENT THRU ROOF		
⊕	PIPE TEE UP	⊗	BASE MOUNTED PUMP	⊕	FIRE DAMPER	DEG F	DEGREES FAHRENHEIT	GPM	GALLONS PER MINUTE	FF	PADDLE FAN TAG	V/PH/Hz	VOLTS/PHASES/HERTZ		
⊕	PIPE TEE DOWN	⊗	CARTRIDGE TYPE INLINE PUMP	⊕	ROUND OR FLAT OVAL DUCT DOWN	DIA	DIAMETER	HC	HEATING COIL TAG	FSIA	POUNDS PER SQUARE INCH ABSOLUTE	WB	WET BULB		
⊕	PIPE REDUCER	⊗	VERTICAL INLINE PUMP	⊕	ROUND OR FLAT OVAL DUCT UP	DIW	DOWN IN WALL	HP	HORSEPOWER	FSIG	POUNDS PER SQUARE INCH GAGE	WCO	WALL CLEANOUT		
⊕	PIPE WITH GUIDE	⊗	FLEXIBLE PIPE CONNECTION (FC)	⊕	SUPPLY DIFFUSER	DN	DOWN	HRV	HEAT RECOVERY VENTILATOR TAG	FVC	POLYVINYL CHLORIDE (PIPE)	WG	WATER GAGE		
⊕	PIPE WITH ANCHOR	⊗	PITCH DOWN	⊕	STEAM TRAP	EA	EXHAUST AIR	HU	HOT WATER	RA	RETURN AIR	WPD	WATER PRESSURE DROP		
⊕	BUTTERFLY VALVE	⊗	PETCOCK	⊕	WATER HAMMER ARRESTOR	EAT	ENTERING AIR TEMPERATURE	HWS/R	HOT WATER SUPPLY AND RETURN	RD	ROOF DRAIN	WSD	WATER TEMPERATURE DROP		
⊕	OS & Y GATE VALVE	⊗		⊕						RDE	RECOMMENDED DUAL ELEMENT FUSE AMPS	W	WITH		

**ELECTRIC WALL HEATER PERFORMANCE SCHEDULE**

TAG	OUTPUT (MBH)	AIRFLOW (CFM)	MTGHT AFF (IN)	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN - BERKO	
				KW	V/PH/Hz	SERVICE	MODEL
WH-1	5.1	100	12"	2.0	120/1/60	MULTIPLE	HTB0256

**ELECTRIC CABINET UNIT HEATER PERFORMANCE SCHEDULE**

TAG	OUTPUT (MBH)	AIRFLOW (CFM)	MTGHT AFF (IN)	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN - BERKO	
				KW	V/PH/Hz	SERVICE	MODEL
CUH-1	34.1	500	6"	10.0	480/3/60	VESTIBULE	CUH8945

**PADDLE FAN PERFORMANCE SCHEDULE**

TAG	AIRFLOW (CFM)	RPM	QTY BLADES & DIA(IN)	ELECTRICAL REQUIREMENTS		BASIS OF DESIGN - BIG ASS FANS		
				WATTS	AMPS	V/PH/Hz	SERVICE	ARRANGEMENT
FF-1	-	56	8, 168"	-	10.0	208/1/60	MULTIFUNCTION	AIRFOIL BLADES