

501 Danforth Street

Portland | Maine | 04102

775.233.7434 Cell

207.747.5288 x108 Office

soleil@thompsonspointmaine.com

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Brian Spencer <brian@wallaceevents.com>

Thu, Mar 23, 2017 at 4:02 PM

Reply-To: brian@wallaceevents.com

To: Soleil Dufour <soleil@thompsonspointmaine.com>, Jake Taylor <jake@wallaceevents.com>

Cc: buildinginspections@portlandmaine.gov

There are no heaters mounted in the tent,

The heaters will be located at least 12' from the edge of the tent.

There will be lighted exit signs above all exits with built in emergency lights.

2 updated diagrams to follow



WALLACE EVENTS

Brian Spencer / Owner - President

brian@wallaceevents.com

Wallace Events

36 Commerce Park, Ellsworth, ME 04605

(207) 667-6000

34 Union Street, Rockland, ME 04841

(207) 593-7643

http://wallaceevents.com



From: Soleil Dufour [mailto:soleil@thompsonspointmaine.com]

Sent: Thursday, March 23, 2017 2:54 PM

3. If the tent is heated explain how it will be heated, including fuel tank locations.

***The Tent will be heated with (2) Generac MAC 750F heaters. The heaters are trailer mounted with on board diesel tanks. See link below for specs.

https://www.generacmobileproducts.com/GeneracMobile/media/library/Downloads/Heaters/Flameless%20Air/Generac-Mobile-Products_manual_Heater-Flameless-750F.pdf

4. Please show how you will be providing power to the tent for exit signs and emergency lights, with battery backup.

<https://mail.google.com/mail/u/1/?ui=2&ik=aec6340d23&view=pt&search=inbox&type=15afc843c7109e92&th=15afc843c7109e92&siml=15afc843c7109e92&sim...> 2/9