

Hydraulic Design Information Sheet

Name - Brick North East Wing Dry System Date - 9-10-14  
Location -  
Building - Brick North East wing System No. - 1 of 1  
Contractor - Residential Fire Protection Contract No. - C14022  
Calculated By - SJC Drawing No. - 1 of 1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - Varies  
Occupancy - Mixed use

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other  
T Specific Ruling Made By Date

E  
M Area of Sprinkler Operation - 2016 System Type Sprinkler/Nozzle  
Density - .2 (X) Wet Make Viking  
D Area Per Sprinkler - 126 ( ) Dry Model VK300  
E Elevation at Highest Outlet - 27 ( ) Deluge Size 1/2"  
S Hose Allowance - Inside ( ) Preaction K-Factor 5.6  
I Rack Sprinkler Allowance - ( ) Other Temp.Rat.155  
G Hose Allowance - Outside - 250

N Note Safety Margin: 8.48

Calculation Flow Required - 688.781 Press Required - 88.135  
Summary C-Factor Used: 100 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 9-13-11 Cap. -  
T Time of Test - Rated Cap.- Elev.-  
E Static Press - 98 @ Press -  
R Residual Press - 92 Elev. - Well  
Flow - 1519 Proof Flow  
S Elevation - 0

U  
P Location -  
P  
L Source of Information -  
Y

C Commodity Class Location  
O Storage Ht. Area Aisle W.  
M Storage Method: Solid Piled % Palletized % Rack  
M  
S R ( ) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
T A ( ) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
O C ( ) Mult. Row ( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
A Longitudinal Transverse  
G

E Horizontal Barriers Provided:

# Water Supply Curve (C)


Residential Fire Protection  
BRICK NORTH EAST WING

## City Water Supply:

C1 - Static Pressure : 98  
C2 - Residual Pressure: 92  
C2 - Residual Flow : 1519

## Demand:

D1 - Elevation : 3.032  
D2 - System Flow : 438.781  
D2 - System Pressure : 88.134  
Hose ( Adj City ) : 250  
Hose ( Demand ) : 688.781  
D3 - System Demand : 688.781  
Safety Margin : 8.476



# Fittings Used Summary

Residential Fire Protection  
BRICK NORTH EAST WING

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
BRICK NORTH EAST WING

Page 4  
Date 9-10-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
60	27.0	5.6	20.25	na	25.2	0.2	126	7.0
61	27.0	5.6	21.08	na	25.71	0.2	126	7.0
62	27.0	5.6	24.13	na	27.51	0.2	126	7.0
63	27.0	5.6	29.08	na	30.2	0.2	126	7.0
64	27.0	5.6	20.35	na	25.26	0.2	126	7.0
65	27.0	5.6	21.18	na	25.77	0.2	126	7.0
66	27.0	5.6	24.25	na	27.57	0.2	126	7.0
67	27.0	5.6	29.21	na	30.27	0.2	126	7.0
68	27.0	5.6	20.69	na	25.47	0.2	126	7.0
69	27.0	5.6	21.54	na	25.99	0.2	126	7.0
70	27.0	5.6	24.65	na	27.8	0.2	126	7.0
71	27.0	5.6	29.7	na	30.52	0.2	126	7.0
72	27.0	5.6	21.35	na	25.88	0.2	126	7.0
73	27.0	5.6	22.22	na	26.4	0.2	126	7.0
74	27.0	5.6	25.43	na	28.24	0.2	126	7.0
75	27.0	5.6	30.62	na	30.99	0.2	126	7.0
80	27.0		30.1	na				
81	27.0		30.24	na				
82	27.0		30.74	na				
83	27.0		31.69	na				
90	16.0		37.65	na				
91	16.0		37.8	na				
92	16.0		38.34	na				
93	16.0		39.38	na				
94	16.0		62.86	na				
95	16.0		67.66	na				
TRD	9.5		78.72	na				
BR	27.0		81.23	na				
UG1	27.0		81.81	na	250.0			
TEST	20.0		88.13	na				

The maximum velocity is 16.87 and it occurs in the pipe between nodes 93 and 94

# Final Calculations - Hazen-Williams

Residential Fire Protection  
BRICK NORTH EAST WING

Page 5  
Date 9-10-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
60	25.20	1.442		14.000	20.250			K Factor = 5.60	
to		100		0.0	0.0				
61	25.2	0.0594		14.000	0.831			Vel = 4.95	
61	25.71	1.442		14.000	21.081			K Factor = 5.60	
to		100		0.0	0.0				
62	50.91	0.2181		14.000	3.053			Vel = 10.00	
62	27.51	1.442	1T	5.304	7.000	24.134		K Factor = 5.60	
to		100		0.0	5.304	0.0			
80	78.42	0.4850		0.0	12.304	5.967		Vel = 15.41	
	0.0								
	78.42					30.101		K Factor = 14.29	
63	30.20	1.442	1T	5.304	7.000	29.080		K Factor = 5.60	
to		100		0.0	5.304	0.0			
80	30.2	0.0830		0.0	12.304	1.021		Vel = 5.93	
	0.0								
	30.20					30.101		K Factor = 5.50	
64	25.26	1.442		0.0	14.000	20.345		K Factor = 5.60	
to		100		0.0	0.0	0.0			
65	25.26	0.0596		0.0	14.000	0.835		Vel = 4.96	
65	25.77	1.442		0.0	14.000	21.180		K Factor = 5.60	
to		100		0.0	0.0	0.0			
66	51.03	0.2190		0.0	14.000	3.066		Vel = 10.03	
66	27.58	1.442	1T	5.304	7.000	24.246		K Factor = 5.60	
to		100		0.0	5.304	0.0			
81	78.61	0.4871		0.0	12.304	5.993		Vel = 15.44	
	0.0								
	78.61					30.239		K Factor = 14.30	
67	30.27	1.442	1T	5.304	7.000	29.214		K Factor = 5.60	
to		100		0.0	5.304	0.0			
81	30.27	0.0833		0.0	12.304	1.025		Vel = 5.95	
	0.0								
	30.27					30.239		K Factor = 5.50	
68	25.47	1.442		0.0	14.000	20.690		K Factor = 5.60	
to		100		0.0	0.0	0.0			
69	25.47	0.0606		0.0	14.000	0.848		Vel = 5.00	
69	25.99	1.442		0.0	14.000	21.538		K Factor = 5.60	
to		100		0.0	0.0	0.0			
70	51.46	0.2224		0.0	14.000	3.114		Vel = 10.11	
70	27.81	1.442	1T	5.304	7.000	24.652		K Factor = 5.60	
to		100		0.0	5.304	0.0			
82	79.27	0.4946		0.0	12.304	6.086		Vel = 15.57	
	0.0								
	79.27					30.738		K Factor = 14.30	
71	30.52	1.442	1T	5.304	7.000	29.697		K Factor = 5.60	
to		100		0.0	5.304	0.0			
82	30.52	0.0846		0.0	12.304	1.041		Vel = 6.00	
	0.0								
	30.52					30.738		K Factor = 5.50	

# Final Calculations - Standard

Residential Fire Protection  
BRICK NORTH EAST WING

Page 6  
Date 9-10-14

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
72	25.88	1.442		0.0	14.000	21.350				
to		100		0.0	0.0	0.0				
73	25.88	0.0624		0.0	14.000	0.873				K Factor = 5.60
73	26.39	1.442		0.0	14.000	22.223				Vel = 5.08
to		100		0.0	0.0	0.0				K Factor = 5.60
74	52.27	0.2289		0.0	14.000	3.205				Vel = 10.27
74	28.24	1.442	1T	5.304	7.000	25.428				K Factor = 5.60
to		100		0.0	5.304	0.0				
83	80.51	0.5092		0.0	12.304	6.265				Vel = 15.82
	0.0									
	80.51					31.693				K Factor = 14.30
75	30.99	1.442	1T	5.304	7.000	30.622				K Factor = 5.60
to		100		0.0	5.304	0.0				
83	30.99	0.0870		0.0	12.304	1.071				Vel = 6.09
	0.0									
	30.99					31.693				K Factor = 5.50
80	108.62	2.067	1T	7.137	11.000	30.101				
to		100		0.0	7.137	4.764				
90	108.62	0.1534		0.0	18.137	2.783				Vel = 10.39
	0.0									
	108.62					37.648				K Factor = 17.70
81	108.87	2.067	1T	7.137	11.000	30.239				
to		100		0.0	7.137	4.764				
91	108.87	0.1541		0.0	18.137	2.795				Vel = 10.41
	0.0									
	108.87					37.798				K Factor = 17.71
82	109.78	2.067	1T	7.137	11.000	30.738				
to		100		0.0	7.137	4.764				
92	109.78	0.1565		0.0	18.137	2.838				Vel = 10.50
	0.0									
	109.78					38.340				K Factor = 17.73
83	111.50	2.067	1T	7.137	11.000	31.693				
to		100		0.0	7.137	4.764				
93	111.5	0.1611		0.0	18.137	2.921				Vel = 10.66
	0.0									
	111.50					39.378				K Factor = 17.77
90	108.62	3.26		0.0	9.000	37.648				
to		100		0.0	0.0	0.0				
91	108.62	0.0167		0.0	9.000	0.150				Vel = 4.18
91	108.88	3.26		0.0	9.000	37.798				
to		100		0.0	0.0	0.0				
92	217.5	0.0602		0.0	9.000	0.542				Vel = 8.36
92	109.78	3.26		0.0	8.083	38.340				
to		100		0.0	0.0	0.0				
93	327.28	0.1284		0.0	8.083	1.038				Vel = 12.58
93	111.50	3.26	1E	6.714	99.660	39.378				
to		100		0.0	6.714	0.0				
94	438.78	0.2208		0.0	106.374	23.483				Vel = 16.87

# Final Calculations - Standard

Residential Fire Protection  
BRICK NORTH EAST WING

Page 7  
Date 9-10-14

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
94	0.0	4.26		80.000	62.861				
to		100		0.0	0.0				
95	438.78	0.0600		80.000	4.799		Vel = 9.88		
95	0.0	4.26	5E 46.987	90.500	67.660				
to		100	0.0	46.987	2.815				
TRD	438.78	0.0600		137.487	8.248		Vel = 9.88		
TRD	0.0	4.26	1Zia 0.0	8.000	78.723				
to		100	2T 37.589	85.290	-3.087		* Fixed loss = 4.492		
BR	438.78	0.0600	2E 18.795	93.290	5.596		Vel = 9.88		
			1D 26.313						
			1G 1.879						
			1Eq 0.94						
BR	0.0	6.16	1E 20.084	40.000	81.232				
to		140	1G 4.304	67.425	0.0				
UG1	438.78	0.0053	1T 43.037	107.425	0.574		Vel = 4.72		
UG1	250.00	8.27	2G 12.652	1000.000	81.806		Qa = 250		
to		140	2E 56.936	124.942	3.032				
TEST	688.78	0.0029	1T 55.354	1124.942	3.296		Vel = 4.11		
	0.0								
	688.78				88.134		K Factor = 73.37		