



PO Box 2551  
2257 West Broadway  
South Portland, ME 04106

1.800.370.3473  
fax 207.879.0540

[www.norrisinc.com](http://www.norrisinc.com)

December 18, 2014

Re: Scope of Work West End Place

Seabee Electric will be installing a new addressable fire alarm system for the Brick North West Wing. The building is classified as a place of assembly as it will be occupied by a Circus Conservatory. Therefore, the fire alarm system will include a voice evacuation system per code.

The building will be fully sprinkled. The panel will be located in the electrical room on the second floor. There will be a remote annunciator and remote microphone located at the main entrance of the building. The building will have an AES Radio Masterbox and the panel will be monitored via a 24-hour central station of the customer's choice.

Norris Inc. will provide the fire alarm equipment, submittal documents, fire alarm permits, and final connections and testing per City of Portland requirements.